

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Thursday				Date : 07.12.23				
Probable Maximum Demand : 10700 MW				Probable Maximum Generation : 12515 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.22 ft	Today = 97.10 ft			Rule Curve = 105.55 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.12.23 (Yesterday)		07.12.23 (Today)		06.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	71	73	74	74	37		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	450	450	450	70		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	354	353	350	360			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	283	272	280	280	63		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	52	92	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	15	15			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	35	20	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	24	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	52	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	136	149	149	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	18	130	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	49	35	60			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	5	71	90	90			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	12	162	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	74	90	90			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	26	80	92			
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	51	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	28	36	36			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1706	2372	2391	2640	1360	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	15	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	18			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	192	193	190	190			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	43	102	100	100			
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	0	0			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	73	50	65			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	15	30			
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	17	36			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	0	0	0			
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	12	0	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	39	35	150	150			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	485	490	500	500			
	Metarbari 2*600 MW (CPGCL)	Coal				0	152	0	550			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run
Chattogram Zone Total				3829	3769	917	1279	1220	1844	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	45	45	45			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	350	275	300	300		85	Under Maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	350	280	320	320			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	320	240	320	350			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8			
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	43	43	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	15	48	12	50			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	19	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	48	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	10	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.45+1*9.78	114	114	21	80	60	100			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	25	53	28	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	52	17	53			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	16	32	10	33			
**	Import (Tirupura)	India		160	160	96	104	128	140			
Cumilla Zone Total				2959	2896	1394	1414	1457	1683	0	469	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	35	75	50	167		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	8	25			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	76	56	65			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0			
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	130	145	197	146	167	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.12.23 (Yesterday)		07.12.23 (Today)		06.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		OT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		OT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25	26	Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	0	0	0	0	0	163	Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	8	8	8			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60	5	Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	330		
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	163	163	163	163			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	10	22	16	16	3	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	300	300			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	409	369	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	25	25	25	25	Gas Shortage	
Sylhet Zone Total					2472	2427	1480	1444	1478	1478	222	519
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	45			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	70	90			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	42	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	32	48			
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	8	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	377	377	370	370			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	443	916	935	935			
Khulna Zone Total					3241	3237	862	1393	1507	1504	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	24	110	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	18	21	25			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	600	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	35			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barisal Zone Total					2265	2265	1128	1167	1243	1282	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	19	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	60	40	86			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	40			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	267	236	330	330	178	Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11			
137	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	70			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
140	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
**	Adani Power ,Jharkhand Ltd	(Import)	2x748	1496	1496	754	760	748	748			
Rajshahi Zone Total					3653	3631	1092	1278	1349	1545	899	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	113			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	53	95	70	110			
150	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	1.7	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	166	0	130	0			
Rangpur Zone Total					1030	950	444	335	442	393	189	85
Sub-total: Plants in operation					25726	25211	9153.0	10827	11284	12515	3017	2243
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosilia 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	9153	10827	11284	12515	3017	2243
(C) Actual data of 06.12.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	10827	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10418	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	10827	MW, at =	18:00 hrs	Dhaka	4172	4172	0	Mymensingh	751	751
04.	Minimum Generation (Generation end)	:	7309	MW, at =	5:00 hrs	Chattogram	1198	1198	0	Sylhet	383	383
05.	Day-peak Generation (Generation end)	:	9153	MW, at =	12:00 hrs	Khulna	1127	1127	0	Barisal	286	286
06.	Evening-peak Generation (Generation end)	:	10827	MW, at =	18:00 hrs	Rajshahi	920	920	0	Rangpur	700	700
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	881	881	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6835	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	10418	10418
a)	Gas/LF limitation	:	2828	MW						(c) Coal =	439349024	Taka
d)	Coal supply Limitation	:	189	MW						(b) Oil =	280174044	Taka
b)	Low water level in Kaptai lake	:	0	MW						Total =	832121398	Taka
c)	Plants under shut down/ maintenance	:	2243	MW								
10.	Total Energy (Generation + India Import)	:	215.01	MKWh								
	By Gas =	109.969	MKWh	By Oil =	21.045	MKWh						
	By Coal =	64.394	MKWh	By Hydro =	1.984	MKWh						
	By Solar =	1.233	MKWh									
11.	Total Gas Supplied	:	818.43	MMCFD								
(D) Forecast of 07.12.23 (Today) Thursday :												
01.	Maximum Demand	:	10700	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12515	MW	(Generation end)	05.	Total Generation	:	212.49	MKWh		
03.	Reserve / Shortage	:	1815	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka	:	27°C			

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation