

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023					Day : Saturday				Date : 09.12.23				
Probable Maximum Demand : 10500 MW					Probable Maximum Generation : 12358 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 96.98 ft	Today = 96.86 ft			Rule Curve = 105.28 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.12.23 (Yesterday)		09.12.23 (Today)		08.12.23 (Yesterday)		09.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	71	74	74	108			Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360			Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450	0			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	321	412	410	410				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	210	126	0	0	84			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	18	18	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	25	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	16				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	52	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	0	48	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	17				
24	Kodda 300 MW PP Unit-3 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	45	0	35	70				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	55				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	70	70				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	35				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	35				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	80	90				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	36	36				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total					5655	5422	1291	1308	2193	2396	1507	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	192	193	192	192				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	100	100				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	0	10				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	17	17				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	50	65				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			23	27	15	30				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	1	0	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	0	0				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	12				
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	150	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	395	465	500	500				
	Metarbari 2*600 MW (CPGCL)	Coal				359	360	400	550				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run
Chattogram Zone Total					3829	3769	1077	1143	1639	1839	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	46	45	48				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	280	310	300	300		50		Under Maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	300	320	320				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	360	340	390				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	12	50				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	10	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	60	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	28	55				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	0	17	17				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	36	52	0	0				
**	Import (Tripura)	India		160	160	90	82	128	140				
Cumilla Zone Total					2959	2896	1123	1287	1459	1649	0	434	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	99	35	100	103			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	0	8	25				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	24	8	56	75				
84	Saishaboni 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	6	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	0	6	6				
Mymensingh Zone Total					622	614	71	107	157	206	103	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.12.23 (Yesterday)		09.12.23 (Today)		08.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		OT-1 Under maint.	
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	27	28	28	28		OT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	6	25	25	25	26	Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	0	0	0	0	0	163	Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	5			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	62	63	63	4	Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	330		
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	170	170	170	170			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	9	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	23	16	16	2	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	175	300	300			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	381	365	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	25	25	25	25	Gas Shortage	
Sylhet Zone Total					2472	2427	1403	1333	1485	1485	220	519
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	70	90			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	46	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	32			
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	360	501	450	550			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	769	722	882	930			
Khulna Zone Total					3241	3237	1175	1223	1534	1663	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	18	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	130	130			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	622	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	35			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	224	220	120	120			
Barishal Zone Total					2265	2265	860	1120	1142	1177	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38			
132	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	241	252	350	350	162	Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	50			
140	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
**	Adani Power ,Jharkhanda Ltd	(Import)	2x748	1496	1496	434	665	748	748			
Rajshahi Zone Total					3653	3631	684	928	1369	1550	883	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	34	113			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	0	70	110			
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	137	0	130	0			
Rangpur Zone Total					1030	950	335	170	442	393	189	85
Sub-total: Plants in operation					25726	25211	8019.0	8619	11420	12358	3082	2208
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosila 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bosila 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	8019	8619	11420	12358	3082	2208
(C) Actual data of 08.12.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	8619	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	8211	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	6519	MW, at =	20:00 hrs	Dhaka	2868	2868	0	Mymensingh	679	679
04.	Minimum Generation (Generation end)	:	6539	MW, at =	5:00 hrs	Chattogram	951	951	0	Sylhet	329	329
05.	Day-peak Generation (Generation end)	:	8019	MW, at =	12:00 hrs	Khulna	991	991	0	Barishal	272	272
06.	Evening-peak Generation (Generation end)	:	8619	MW, at =	20:00 hrs	Rajshahi	808	808	0	Rangpur	549	549
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	20:00 hrs	Cumilla	765	765	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6263	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	8211	8211
a)	Gas/LF limitation	:	2893	MW						(c) Coal =	346250925	Taka
d)	Coal supply Limitation	:	189	MW						(b) Oil =	23998569	Taka
b)	Low water level in Kaptai lake	:	0	MW						Total =	476052566	Taka
c)	Plants under shut down/ maintenance	:	2208	MW								
10.	Total Energy (Generation + India Import)	:	182.26	MKWh								
	By Gas =	102.742	MKWh	By Oil =	1.757	MKWh						
	By Coal =	56.834	MKWh	By Hydro =	2.012	MKWh						
	By Solar =	1.551	MKWh									
11.	Total Gas Supplied	:	774.34	MMCFD								
(D) Forecast of 09.12.23 (Today) Saturday :												
01.	Maximum Demand	:	10500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12358	MW	(Generation end)	05.	Total Generation	:	222.04	MKWh		
03.	Reserve / Shortage	:	1858	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka	:	23.5°C			

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation