

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Sunday				Date : 10.12.23					
Probable Maximum Demand :				11000 MW		Probable Maximum Generation :				12695 MW			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.86 ft		Today = 96.75 ft		Rule Curve = 105.19 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.12.23 (Yesterday)		10.12.23 (Today)		09.12.23 (Yesterday)		10.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	67	55	55	96			Gas Shortage
6	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360			Gas Shortage
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	420	450	0			Gas Shortage
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	350	400	330	400				
12	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	105	0	0	105			Gas Shortage
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	330	330	335			Gas Shortage
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	2	55	55				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	0	15	15				
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	12	34	38	38				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	34	105				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	48	48	48				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	35				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	7	130	130				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	62	35	80				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	34	70	70				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	166	17	17	17	35				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	14	90	90				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	2	90	90				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	2	85	85				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48				
37	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
38	Meghnaghat Unique Power	Gas				0	0	0	0				
39	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0				
Dhaka Zone Total				5655	5422	1267	1646	2303	2616	1516	740		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	86	46	46				
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	5	8	17				
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0				
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	0	19	6	18				
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17				
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	191	192	192	192				
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	16	65	245				
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	12	12	12				
52	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	9	17	17	17				
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	50	65				
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	13	12	12				
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	7	20				
56	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
57	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	5	17	17	17				
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	0	0				
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12				
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	5	17	17	17				
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	27	0	35	150				
63	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	360	490	500	500				
64	Matarbari 2*600 MW (CPGCL)	Coal				396	393	600	600				Test run
65	Cox's Bazar Wind PP	(Wind) (IPP)				5	5	10	10				Test run
Chattogram Zone Total				3829	3769	1066	1330	1665	1984	180	330		
66	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	47	45	48				
67	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
68	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	330	300	330		30		Under Maint.
69	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	300	280	300	300				
70	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	310	300	310				
71	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	0	0				
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	10	51	51	51				
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	15	150	150				
74	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20				
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	5	17	17	17				
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	18	18				
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
79	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	22	52	52				
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	10	10	10				
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	23	100	100				
83	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	46	26	46				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	9	17	17				
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	18	18				
86	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	48	32	12	48				
87	Import (Tripura)	India		160	160	90	96	128	141				
Cumilla Zone Total				2959	2896	1025	1392	1588	1720	0	414		
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	35	35	40	167			Gas Shortage
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
90	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	28	8	28				
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	75	57	78				
92	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
93	Sutlakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
94	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	0	6	6				
Mymensingh Zone Total				622	614	79</							

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.12.23 (Yesterday)		10.12.23 (Today)		09.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	25	25	25		26	Gas Shortage		
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Gas Shortage		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	63	63	3		Gas Shortage		
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	168	168	170	170					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	16	16	1		Gas Shortage		
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	300					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	396	367	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	390	380	390					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	25	25	25	25		Gas Shortage		
Sylhet Zone Total						2472	2427	1406	1457	1465	1475	218	519	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0	45				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	75	95					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	32	32					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	414	633	630	630					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDc)	India		1000	1000	863	628	933	933					
Khulna Zone Total						3241	3237	1345	1293	1770	1751	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	18	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	55	130	130					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	600	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	35					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	110	110					
Barishal Zone Total						2265	2265	834	1087	1149	1167	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86					
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40					
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	280	241	280	250	173		Gas Shortage		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	56	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	70	35	50					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	524	755	748	748					
Raishahi Zone Total						3653	3631	817	1141	1299	1450	894	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	102	34	100					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	93	70	110					
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	1.4	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	41	0	130	0					
Rangpur Zone Total						1030	950	228	365	442	380	189	85	
Sub-total: Plants in operation						25726	25211	8067.0	9849	11839	12695	3164	2188	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0	
Gross Total						25951	25211	8067	9849	11839	12695	3164	2188	
(C) Actual data of 09.12.23 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	9849	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9545	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	9849	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6263	MW, at =	5:00 hrs	Dhaka	3578	3578	0	Mymensingh	764	764	0	
05.	Day-peak Generation (Generation end)	:	8067	MW, at =	12:00 hrs	Chattogram	1061	1061	0	Sylhet	356	356	0	
06.	Evening-peak Generation (Generation end)	:	9849	MW, at =	19:00 hrs	Khulna	1102	1102	0	Barisal	279	279	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	913	913	0	Rangpur	655	655	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6672	MW, at =	5:00 hrs	Cumilla	838	838	0					
09.	Generation shortfall at evening peak due to :	:				Total						9545	9545	0
a)	Gas/LF limitation	:	2975	MW		(a) Gas = 104573123 Taka						(c) Coal = 371425223 Taka		
d)	Coal supply Limitation	:	189	MW		(b) Oil = 83252170 Taka						Total = 559250516 Taka		
b)	Low water level in Kaptai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2188	MW		Maximum Temperature in Dhaka was : 26.3°C								
10.	Total Energy (Generation + India Import)	:	194.03	MKWh		Export through East-West interconnections :								
	By Gas = 103.558 MKWh			By Oil = 6.580 MKWh		At evening peak-hour :						8067	MW, at 19:00 hrs	
	By Coal = 60.322 MKWh			By Hydro = 1.832 MKWh		Maximum :						150	MW, at 19:30 hrs	
	By Solar= 1.332 MKWh					Energy :						0.1155	MKWh	
11.	Total Gas Supplied	:	767.94	MMCFD										
(D) Forecast of 10.12.23 (Today) Sunday :														
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	12695	MW	(Generation end)	05.	Total Generation : 216.70 MKWh							
03.	Reserve / Shortage	:	1695	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 26.3°C							

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation