

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date :                |                                        | 11-Dec-23      |                     |                  |                      |                  |                        |  |  |  | Page - 2 |  |
|-----------------------|----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|------------------------|--|--|--|----------|--|
| Sl. No.               | Name of the Power Stations             | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Enerov Generated | Remarks                |  |  |  |          |  |
|                       |                                        |                | Unit No. X Capacity | MW               | MW                   | KWH              |                        |  |  |  |          |  |
| 1                     | Ghorasol Repowered CCPP-Unit-3 (GT     | PDB            | 1*260               | 260              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 2                     | Ghorasol Repowered CCPP Unit-4         | PDB            | 1*210               | 180              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 3                     | Ghorasol TPP Unit-5                    | PDB            | 1*210               | 190              | 180                  | 4347000          |                        |  |  |  |          |  |
| 4                     | Ghorasol 365 MW CCPP Unit-7            | PDB            | 1*243+1*122         | 365              | 0                    | 0                | Air Compressor problem |  |  |  |          |  |
| 5                     | Ghorasol 78.5 MW PP (MAX)              | QRPP           | 2*40                | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 4                     | Ghorashul 108 MW PP (Regent)           | IPP            | 34*3.35             | 108              | 72                   | 1062181          | Gas shortage           |  |  |  |          |  |
| 5                     | Haripur GTPP                           | SBU, PDB       | 2*32                | 20               | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 6                     | Haripur 412 MW CCPP                    | EGCB           | 1*273+1*139         | 412              | 282                  | 6948000          | Gas shortage           |  |  |  |          |  |
| 7                     | Haripur 360 MW CCPP(HPL)               | IPP            | 1*235+1*125         | 360              | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 8                     | Meghnaghat 450 MW CCPP(MPL)            | IPP            | 2*150+1*150         | 450              | 190                  | 4271300          | Gas shortage           |  |  |  |          |  |
| 9                     | Meghnaghat 100 MW(IEEL)                | NENP           | 12*8.9              | 100              | 30                   | 129600           | Fuel shortage          |  |  |  |          |  |
| 10                    | Meghnaghat CCPP(Summit)                | IPP            | 2*110+1*110         | 335              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 11                    | Madanganj 102 PP(Summit)               | NENP           | 6*17                | 102              | 82                   | 727700           | Engine problem         |  |  |  |          |  |
| 12                    | Madanganj-55 MW PP(Summit)             | NENP           | 3*17.08+1*11.3      | 55               | 55                   | 598054           |                        |  |  |  |          |  |
| 13                    | Keraniganj 100 MW PP (Powerpac)        | NENP           | 8*13.45             | 75               | 22                   | 49328            | Fuel shortage          |  |  |  |          |  |
| 14                    | Narshingdi 22 MW PP (Doreen)           | SIPP, REB      | 8*2.90              | 22               | 15                   | 251496           | Engine problem         |  |  |  |          |  |
| 15                    | 210 MW Siddhirgonj TPP                 | PDB            | 1*210               | 115              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 16                    | Siddhirgonj 2*120 MW GTTP              | EGCB           | 2*105               | 210              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 17                    | Siddhirgonj 100 PP(Dutch Bangla)       | NENP           | 12*8.9              | 100              | 70                   | 333101           | Fuel shortage          |  |  |  |          |  |
| 18                    | Siddhirganj 335 MW CCPP                | EGCB           | 1*217+1*118         | 335              | 145                  | 4040256          | Gas shortage           |  |  |  |          |  |
| 19                    | Gagnagar 102 MW PP (Digital Power)     | IPP            | 12*8.924            | 102              | 33                   | 74160            | Fuel shortage          |  |  |  |          |  |
| 20                    | Katpotti 52 MW PP (Siraha)             | IPP            | 7*7.9               | 0                | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 21                    | Kamalaghat 54 MW PP (Banco Energy)     | IPP            | 3*18                | 54               | 17                   | 129600           | Fuel shortage          |  |  |  |          |  |
| 22                    | Kodda 150 MW PP                        | BPDB-RPCL      | 9*17.06             | 149              | 98                   | 496320           | Fuel shortage          |  |  |  |          |  |
| 23                    | Manikganj 55 MW PP (Northern)          | IPP            | 3*19.3              | 55               | 35                   | 141796           | Fuel shortage          |  |  |  |          |  |
| 24                    | Nababganj 55 MW PP (Southern power)    | IPP            | 3*19.3              | 55               | 17                   | 134702           | Fuel shortage          |  |  |  |          |  |
| 25                    | Bosila 108 MW PP(CLC)                  | IPP            | 12*8.775+1*3.5      | 0                | 0                    | 0                |                        |  |  |  |          |  |
| 26                    | Summit Power, (Madhabadi+Ashulia)      | SIPP, REB      | 3*3.67+4*8.73       | 80               | 22                   | 747720           | Engine problem         |  |  |  |          |  |
| 27                    | Maona 33 MW PP(Summit)                 | SIPP, REB      | 4*8.73              | 33               | 25                   | 537000           | Engine problem         |  |  |  |          |  |
| 28                    | Rupganj 33 MW PP(Summit)               | SIPP, REB      | 4*8.73              | 33               | 23                   | 517300           | Engine problem         |  |  |  |          |  |
| 29                    | Gasipur 52 MW PP                       | RPCL           | 8*6.9               | 52               | 17                   | 148800           | Fuel shortage          |  |  |  |          |  |
| 30                    | Tongi 80 MW GTTP                       | PDB            | 1*105               | 105              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 31                    | Kodda 300 MW PP Unit-2 (Summit)        | IPP            | 18*17.076           | 300              | 97                   | 898255           | Fuel shortage          |  |  |  |          |  |
| 33                    | Bramhangaoan 100 MW PP (Aggreko)       | IPP            | 11*10.959           | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 34                    | Aurahat 100MW PP (Aggreko)             | IPP            | 0.85*23+0.95*91     | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 35                    | Kodda 149 MW PP Unit-1 (Summit)        | IPP            | 8*18.453+97         | 149              | 57                   | 692094           | Fuel shortage          |  |  |  |          |  |
| 36                    | Gasipur 100 MW PP                      | RPCL           | 6*17.5              | 105              | 70                   | 328224           | Fuel shortage          |  |  |  |          |  |
| 37                    | Meghnaghat 104 MW PP (OPCL)            | IPP            | 18.5*6              | 104              | 68                   | 458880           | Fuel shortage          |  |  |  |          |  |
| 38                    | Manikgonj 162MW PP(MPGL)               | IPP            | 9*18                | 162              | 17                   | 387360           | Fuel shortage          |  |  |  |          |  |
| 39                    | Spectra Solar Plant Ltd.               | IPP            | 35                  | 35               | 0                    | 149640           |                        |  |  |  |          |  |
| 40                    | Kanchan Purbasol Power Generation Ltd. | IPP            | 18*4.3              | 55               | 17                   | 145440           | Fuel shortage          |  |  |  |          |  |
|                       | Meghnaghat Unique power                | IPP            | 589                 | 0                | 0                    | 0                | On test.               |  |  |  |          |  |
|                       | Summit Meghnaghat-2 589 MW(Gas)        | IPP            | 589                 | 0                | 0                    | 0                | On test.               |  |  |  |          |  |
| Dhaka area Total      |                                        |                |                     | 5422             | 1756                 | 28808277         |                        |  |  |  |          |  |
| 41                    | Chattogram TPP-1                       | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 42                    | Chattogram TPP-2                       | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 43                    | Razzan 25 MW PP                        | RPCL           | 3*8.9               | 25               | 13                   | 77607            | Fuel shortage          |  |  |  |          |  |
| 44                    | Teknaf 20MW PP (Solartech)             | IPP            | .20                 | 20               | 0                    | 7020             |                        |  |  |  |          |  |
| 45                    | Patenga 50MW PP (Baraka)               | IPP            | 8*6.98              | 50               | 19                   | 148320           | Fuel shortage          |  |  |  |          |  |
| 46                    | Kapila Hydro: Unit-1,2,3,4, 5          | PDB            | 2*40+3*50           | 230              | 46                   | 1249740          | Unit-2 under maint.    |  |  |  |          |  |
| 47                    | Sikalbaha 225MW                        | PDB            | 1*150+1*75          | 225              | 192                  | 4560258          | Machine problem        |  |  |  |          |  |
| 48                    | Sikalbaha Peaking GT                   | PDB            | 1*150               | 0                | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 49                    | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP            | 6*17.5              | 105              | 17                   | 259272           | Fuel shortage          |  |  |  |          |  |
| 50                    | Hathazari 100 MW peaking PP            | PDB            | 11*8.9              | 98               | 75                   | 469696           | Engine problem         |  |  |  |          |  |
| 51                    | Dohazari -Kalaish 100 MW Peaking       | PDB            | 6*17                | 102              | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 52                    | Julidah 100 MW Unit-1 (Acom)           | NENP           | 8*13.45             | 100              | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 53                    | Julidah 100 MW PP Unit-3 (Acom)        | IPP            | 8*13.5              | 25               | 100                  | 477120           | Fuel shortage          |  |  |  |          |  |
| 54                    | Barabkunda 22 MW PP (Regent)           | SIPP, PDB      | 8*2.90              | 22               | 10                   | 246480           | Engine problem         |  |  |  |          |  |
|                       | Malancha, Ctg. EPZ (United)            |                | 5*8.73+3*9.34       | 0                | 2                    | 145440           |                        |  |  |  |          |  |
| 55                    | Chattogram 108 MW PP (ECPV)            | IPP            | 16*7                | 108              | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 56                    | Kapila 7 MW Solar PP                   | PDB            | 7.4 MW              | 7                | 0                    | 7559             |                        |  |  |  |          |  |
| 57                    | Anwara 300 MW PP (United)              | IPP            | 17*17+24            | 300              | 130                  | 1021200          | Fuel shortage          |  |  |  |          |  |
| 58                    | Jodisc Power                           | IPP            | 3*18.55+1*3.6       | 54               | 17                   | 182277           | Fuel shortage          |  |  |  |          |  |
| 59                    | Karnaphuli Power Ltd.                  | IPP            | 18.415*6+8.5        | 110              | 17                   | 296909           | Fuel shortage          |  |  |  |          |  |
| 60                    | Julidah unit-2 (Acom)                  | IPP            | 8*13.6              | 100              | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 61                    | Anlima Energy Ltd.                     | IPP            | 6*21.2              | 116              | 17                   | 289800           | Fuel shortage          |  |  |  |          |  |
|                       | Minshara 150 MW                        | BPDB-RPCL      | 18.5*9              | 163              | 0                    | 260945           |                        |  |  |  |          |  |
|                       | SS Power 1                             | SS Power       | 2*612               | 1224             | 480                  | 10118180         |                        |  |  |  |          |  |
|                       | Cox's Bazar Wind                       | IPP            | 85                  | 0                | 8                    | 254400           | On test.               |  |  |  |          |  |
|                       | Matarbari 2*600 MW (CPGCL)             | CPGCL          | 0                   | 0                | 575                  | 13701090         | On test.               |  |  |  |          |  |
|                       | Minshara 150 MW (Gas)                  | BPDB-RPCL      | 18.5*9              | 0                | 0                    | 0                |                        |  |  |  |          |  |
| Chattogram area Total |                                        |                |                     | 3769             | 1653                 | 33773313         |                        |  |  |  |          |  |
| 61                    | Ashuganj TPP Unit- 3                   | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
|                       | Ashuganj TPP Unit-4                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
|                       | Ashuganj TPP Unit-5                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 62                    | Ashuganj 225 MW CCPP                   | APSCL          | 1*142+1*75          | 221              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 63                    | Ashuganj 450 MW CCPP(North)            | APSCL          | 1*360               | 360              | 310                  | 7386500          | Under maint.           |  |  |  |          |  |
| 64                    | Ashuganj 450 MW CCPP(South)            | APSCL          | 1*360               | 360              | 290                  | 6449000          | Gas shortage           |  |  |  |          |  |
|                       | Ashuganj 420 MW CCPP(East)             | APSCL          | 284*1+116*1         | 400              | 300                  | 6717500          | Gas shortage           |  |  |  |          |  |
| 65                    | Ashuganj 50 MW PP                      | APSCL          | 14*3.968            | 45               | 10                   | 630000           | Gas shortage           |  |  |  |          |  |
| 66                    | Ashuganj 55 MW PP (Precision)          | QRPP           | 0                   | 0                | 1                    | 244320           | Gas shortage           |  |  |  |          |  |
| 67                    | Ashuganj 195 MW PP (APSCL-United)      | IPP            | 20*9.73+1*16        | 195              | 8                    | 217455           | Gas shortage           |  |  |  |          |  |
| 68                    | Ashuganj 51 MW PP (Midland)            | IPP            | 9*9.34              | 51               | 51                   | 871124           |                        |  |  |  |          |  |
| 69                    | Ashuganj 150 MW PP (Midland)           | IPP            | 29*7.015            | 150              | 85                   | 839709           |                        |  |  |  |          |  |
| 70                    | Titas 50 MW Peaking PP                 | PDB            | 6*8.92              | 52               | 8                    | 53872            | Fuel shortage          |  |  |  |          |  |
| 71                    | Chandpur 150 MW CCPP                   | PDB            | 1*106+1*57          | 163              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 72                    | Chandpur 200 MW (Desh energy)          | IPP            | 12*18.4             | 200              | 17                   | 324000           | Fuel shortage          |  |  |  |          |  |
| 73                    | Feni 22 MW PP (Doreen)                 | SIPP, PDB      | 8*2.90              | 22               | 18                   | 324288           | Engine problem         |  |  |  |          |  |
| 74                    | Feni 11 MW PP (Doreen)                 | SIPP, REB      | 4*2.90              | 11               | 8                    | 166880           |                        |  |  |  |          |  |
|                       | Import (Tripura)                       | Imported power | 0                   | 160              | 90                   | 1989120          |                        |  |  |  |          |  |
| 75                    | Jangalia 33 MW PP (Summit)             | SIPP, PDB      | 4*8.73              | 33               | 25                   | 533300           | Engine problem         |  |  |  |          |  |
| 76                    | Jangalia 52 MW PP (Lakdanavi)          | IPP            | 6*8.92              | 52               | 38                   | 119501           | Engine problem         |  |  |  |          |  |
| 77                    | Cumilla 25 MW PP (Summit)              | SIPP, REB      | 3*3.67+2*6.97       | 25               | 8                    | 226870           | Engine problem         |  |  |  |          |  |
| 78                    | Daukheri 200 MW PP (B.Trac)            | IPP            | 0                   | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 79                    | Feni Lanka Power                       | IPP            | 7*18.415+1*9.78     | 114              | 81                   | 163020           | Engine problem         |  |  |  |          |  |
| 80                    | Chowmuhani 113 MW                      | IPP            | 12*9.78+2*3.1       | 113              | 57                   | 606480           | Fuel shortage          |  |  |  |          |  |
| 81                    | Bhairab 54.5 MW                        | IPP            | 3*18.2              | 54               | 17                   | 445320           |                        |  |  |  |          |  |
| 82                    | Chandpur 115(Doreen)                   | IPP            | 4*18.5+2*22.5       | 115              | 18                   | 272640           | Fuel shortage          |  |  |  |          |  |
| Cumilla Area Total    |                                        |                |                     | 2896             | 1440                 | 28580699         |                        |  |  |  |          |  |
| 83                    | RPCL 210MW CCPP                        | IPP            | 4*35+1*70           | 202              | 30                   | 1076040          | Gas shortage           |  |  |  |          |  |
| 84                    | Tangail 22 MW PP (Doreen)              | SIPP, PDB      | 8*2.90              | 22               | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 85                    | Jamalpur 95 MW PP(Powerpac)            | IPP            | 0                   | 0                | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 86                    | Sarishabari 3 MW Solar Plant           | IPP            | 1*3                 | 3                | 0                    | 6500             |                        |  |  |  |          |  |
| 87                    | Mymensingh 200 MW PP (United)          | IPP            | 9*78*21             | 200              | 77                   | 1058400          | Fuel shortage          |  |  |  |          |  |
| 88                    | Jamalpur 115 MW PP (United)            | IPP            | 9*78*12             | 115              | 28                   | 223200           | Fuel shortage          |  |  |  |          |  |
| 89                    | Sutakhal 50 MW Solar PP                | IPP            | 50                  | 50               | 0                    | 142810           |                        |  |  |  |          |  |
| 90                    | Tangail Pali Power Gen 22 MW           | IPP            | 4*6.7               | 22               | 6                    | 88560            | Engine problem         |  |  |  |          |  |
| Mymensingh Area Total |                                        |                |                     | 614              | 141                  | 2598510          |                        |  |  |  |          |  |
| 91                    | Fenchugonj CCPP Phase-1                | PDB            | 2*32+1*33           | 70               | 43                   | 1018000          | Engine problem         |  |  |  |          |  |
| 92                    | Fenchugonj CCPP Phase-2                | PDB            | 2*35+1*35           | 90               | 28                   | 703800           | Engine problem         |  |  |  |          |  |
| 93                    | Kushiana 163 MW CCPP (KP)              | IPP            | 1*109+1*54          | 163              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 94                    | Shahjibazar 330 MW CCPP                | PDB            | 3*110               | 330              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 95                    | Fenchugonj 51 MW PP (Barakattulah)     | RPP            | 19*2.90             | 51               | 25                   | 495600           | Gas shortage           |  |  |  |          |  |
| 96                    | Fenchugonj 44 MW (Energyprima)         | NENP           | 12*3.3+5*2          | 50               | 25                   | 415368           | Gas shortage           |  |  |  |          |  |
| 97                    | Hobiganj 1.1 MW PP (Desh-E)            | SIPP, REB      | 4*2.90              | 11               | 5                    | 120380           | Engine problem         |  |  |  |          |  |
| 98                    | Shahjibazar GTTP Unit- 8 & 9           | PDB            | 2*35                | 66               | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 99                    | Shahjibazar 86 MW PP (Shahjibazar)     | RPP            | 32*2.90             | 86               | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 100                   | Shahjibazar 100 MW GTTP                | PDB            | 1*100               | 100              | 0                    | 0                | Under maint.           |  |  |  |          |  |
| 101                   | Sylhet 225 MW CCPP                     | PDB            | 1*142+1*89          | 231              | 152                  | 4384300          | Machine problem        |  |  |  |          |  |
| 102                   | Sylhet 20 MW GTTP                      | PDB            | 1*20                | 20               | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 103                   | Sylhet 50 MW PP (EPL)                  | NENP           | 27*2                | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 104                   | Shahjahanulla 25 MW PP                 | SIPP, REB      | 3*9.34              | 25               | 16                   | 236064           |                        |  |  |  |          |  |
| 105                   | Bibiana-II 341 MW CCPP (Summit)        | IPP            | 1*222+1*119         | 341              | 290                  | 7024000          | Gas shortage           |  |  |  |          |  |
| 106                   | Bibiyana-III 400 MW CCPP               | PDB            | 285*1+134*1         | 400              | 400                  | 8516000          |                        |  |  |  |          |  |
| 107                   | Sylhet 10MW PP (Desh)                  | RPP            | 8*1.95              | 10               | 9                    | 161820           |                        |  |  |  |          |  |
| 108                   | Bibiyana South 400 MW                  | PDB            | 400 MW              | 383              | 400                  | 8987200          |                        |  |  |  |          |  |
| Sylhet Area Total     |                                        |                |                     | 2427             | 1393                 | 32062512         |                        |  |  |  |          |  |
| 107                   | Bheramara GTTP Unit-3                  | PDB            | 1*20                | 0                | 0                    | 0                |                        |  |  |  |          |  |
| **                    | Bheramara (HVDC )                      | Imported power | 2*500               | 1000             | 841                  | 14276363         |                        |  |  |  |          |  |
| 108                   | Khulina 115 PP MW (KPCL-2)             | NENP           | 7*17                | 115              | 0                    | 124              | Fuel shortage          |  |  |  |          |  |
| 109                   | Fairfoud 60 MW Peaking PP              | PDB            | 8*6.99              | 54               | 6                    | 30720            | Fuel shortage          |  |  |  |          |  |
| 110                   | Khulina 225 MW CCPP                    | NWPGCL         | 1*150+1*75          | 230              | 0                    | 0                | Fuel shortage          |  |  |  |          |  |
| 111                   | Gopalganj 100 MW Peaking PP            | PDB            | 16*6.98             | 109              | 0                    | 0                | Machine problem        |  |  |  |          |  |
| 112                   | Bheramara 410 MW CCPP                  | NWPGCL         | 1*278+1*132         | 410              | 0                    | 0                | Gas shortage           |  |  |  |          |  |
| 113                   | Noapara 40 MW PP (Kharajahan Ali)      | NENP           | 5*8.5               | 40               | 8                    | 13125            | Fuel shortage          |  |  |  |          |  |
| 114                   | Noapara 100 MW PP (Bangla Trac)        | IPP            | 70*1.4              | 0                | 0                    | 0                | Contract Expired       |  |  |  |          |  |
| 115                   | Rupsha 105 MW PP (Orion rupsha)        | IPP            | 6*18.445            | 105              | 53                   |                  |                        |  |  |  |          |  |