

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023					Day : Tuesday					Date : 12.12.23				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 11256 MW									
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 96.72 ft		Today = 96.69 ft		Rule Curve = 105.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.12.23 (Yesterday)		12.12.23 (Today)		11.12.23 (Yesterday)		12.12.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	72	55	71	39			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	190	225	225	260			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	318	282	280	280					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	145	180	180	190			Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	33	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	12	15	15	15					
17	Summit Power,Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.7+7x8.73	80	80	34	22	34	34					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	23	23	23					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	34	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	48	98					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17					
24	Kodda 300 MW PP Unit-3 (Summit)	HFO (IPP)	18x17.076	300	300	12	97	130	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	57	35	80					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	68	70	70					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	30	17	17	17					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	70	90	90					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	30	90	90					
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	18	82	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	22	48	48					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total				5655	5422	1283	1756	1878	2094	1679	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	13	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	193	192	192	192					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	45	130	65	245					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	100	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	17	17					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	75	50	75					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	0	7					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	0	0					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	26	0	35	150					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	455	490	350	350					
	Matlabari 2*600 MW (CPGCL)	Coal				565	575	575	575				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				10	8	10	10				Test run	
Chattogram Zone Total				3829	3769	1433	1653	1609	1859	180	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	10	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	260	290	290	290		70		Under Maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	310	310	310					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	250	300	250	300					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	0	0					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	85	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	8	0	20					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	20	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	21	25	25	25					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	38	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	8	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	81	100	100					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	19	57	26	65					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	18	18	35					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	10	1	30	30					
**	Import (Tirupura)	India		160	160	80	90	128	141					
Cumilla Zone Total				2959	2896	1144	1440	1547	1686	0	454			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	27	30	30	40	172			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	8	28					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780											

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.12.23 (Yesterday)		12.12.23 (Today)		11.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening								
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25	26		Gas Shortage				
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5							
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	63	63	66		Gas Shortage				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	80	80							
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	168	152	140	155							
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0							
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9							
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	0	0							
100	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	400	400	400							
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400							
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work				
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	25	25	25	25	25		Gas Shortage				
Sylhet Zone Total					2472	2427	1373	1393	1234	1249	289	519				
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	6	0	45							
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0							
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	75	95							
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0							
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0							
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	26	0	32	32							
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16							
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0							
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDF)	1x220+1x116	336	336	0	0	0	0							
**	Bheramara (HVDCL)	India		1000	1000	911	841	927	927							
Khulna Zone Total					3241	3237	1011	908	1134	1115	0	0				
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	23	110	110							
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	11	19	20	20							
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	120	120	120							
119	Payra 1320 MW TPP	Coal (BOPCL)	2x622	1244	1244	560	622	622	622							
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	35							
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140							
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	170	220	220							
Barishal Zone Total					2265	2265	918	1129	1249	1267	0	0				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.				
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	19	0	30							
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20							
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	50	40	86							
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	30	45							
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	42							
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38							
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage				
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	213	184	250	230	230		Gas Shortage				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11							
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52							
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	55							
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	3	35	35	50							
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28							
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	759	757	748	748							
Rajshahi Zone Total					3653	3631	1072	1205	1269	1455	951	100				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	31	77	34	100							
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0							
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	94	70	110							
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0							
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	36	0	130	0							
Rangpur Zone Total					1030	950	284	341	442	380	189	85				
Sub-total: Plants in operation					25726	25211	8635.0	9966	10514	11256	3460	2228				
(B) Plants under long term maintenance/ contract expired																
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0				
Gross Total					25951	25211	8635	9966	10514	11256	3460	2228				
(C) Actual data of 11.12.23 (Yesterday) Monday :																
01.	Max. Demand at eve. peak (Generation end)	:	9966	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	9684	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	9966	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW			
04.	Minimum Generation (Generation end)	:	6576	MW, at =	5:00 hrs	Dhaka	3704	3704	0	Mymensingh	750	750				
05.	Day-peak Generation (Generation end)	:	8635	MW, at =	12:00 hrs	Chattogram	1043	1043	0	Sylhet	364	364	0			
06.	Evening-peak Generation (Generation end)	:	9966	MW, at =	18:00 hrs	Khulna	1135	1135	0	Barisal	274	274	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	901	901	0	Rangpur	693	693	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6609	MW, at =	5:00 hrs	Cumilla	820	820	0							
09.	Generation shortfall at evening peak due to :	:				Total						9684	9684	0		
a)	Gas/LF limitation	:	3271	MW		a) Gas = 93094989 Taka						c) Coal = 343291563 Taka				
d)	Coal supply Limitation	:	189	MW		b) Oil = 230947851 Taka						Total = 667334403 Taka				
b)	Low water level in Kaptai lake	:	0	MW												
c)	Plants under shut down/ maintenance	:	2228	MW		14. Maximum Temperature in Dhaka was : 23.9°C										
10.	Total Energy (Generation + India Import)	:	193.50	MKWh		15. Export through East-West interconnections :										
	By Gas =	94.144	MKWh	By Oil =	17.575	At evening peak-hour :								8635	MW, at	18:00 hrs
	By Coal =	62.747	MKWh	By Hydro =	1.250	Maximum :								124	MW, at	7:00 hrs
	By Solar=	1.262	MKWh			Energy :								0.0495	MKWh	
11.	Total Gas Supplied	:	723.03	MMCFD												
(D) Forecast of 12.12.23 (Today) Tuesday :																
01.	Maximum Demand	:	10000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	:	11256	MW	(Generation end)	05.	Total Generation	:	194.16	MKWh						
03.	Reserve / Shortage	:	1256	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	23.9°C							

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation