

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Wednesday				Date : 13.12.23					
Probable Maximum Demand : 10300 MW				Probable Maximum Generation : 11385 MW									
Water Level of Kapital Lake at 06:00 AM				Yesterday = 96.69 ft	Today = 96.57 ft			Rule Curve = 105.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.12.23 (Yesterday)		13.12.23 (Today)		12.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	72	55	71	39		Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	270	324	280	280				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	146	0	0	0	335		Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	91	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	34	35	34	34				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	17	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	22	23	23				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	90	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	48	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	81	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	23	105	35	72				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	36	71	70	70				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	15	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	76	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	85	90	90				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	78	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	24	47	48	48				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total				5655	5422	1399	2015	1632	1961	1789	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	167	92	92				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	194	192	192	192				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	45	100	45	100				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	25	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	17				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	75	42	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	2	7				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	0	0				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	25	24	24				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	144	150	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	395	350	350	350				
	Matarbari 2*600 MW (CPGCL)	Coal				574	560	575	575			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run	
Chattogram Zone Total				3829	3769	1513	1788	1624	1727	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	5	25	25				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	260	290	290		100	Under Maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	285	280	310	310				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	250	250	250	300				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	26	43	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	53	150	12	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	17	24	0	20				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	6	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	19	32	25	25				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	10	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	81	100	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	33	58	28	57				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	36	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	6	3	3	3				
**	Import (Tripura)	India		160	160	94	88	128	141				
Cumilla Zone Total				2959	2896	1152	1418	1347	1597	0	484		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	33	30	40	169		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	9	28				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	77	56	77				
84	Saishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	17	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	123	144	153	151	169	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.12.23 (Yesterday)		13.12.23 (Today)		12.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25		26	Gas Shortage			
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Gas Shortage			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	63	63	63	3		Gas Shortage			
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	80	80						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	153	127	130	150						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	16	16	1		Gas Shortage			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	361	320	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	345	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5*5*2	50	50	25	25	25	25	25		Gas Shortage			
Sylhet Zone Total						2472	2427	1174	1099	1225	1245	218	519		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	45						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	70	75	95						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	32						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	0	16	16						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	95	600	600						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVCDC) India			1000	1000	911	628	923	923						
Khulna Zone Total						3241	3237	1021	843	1730	1711	0	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	19	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	100	100	120	120						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	480	622	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	35						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	180	220	220						
Barishal Zone Total						2265	2265	931	1128	1249	1267	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	18	0	30						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	82	40	86						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	30	45						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	38	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	200	193	250	250	221		Gas Shortage			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	5	35	35	35						
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	761	760	748	748						
Raishahi Zone Total						3653	3631	1062	1272	1190	1376	942	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	220	170	170	54		Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	53	6	70						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	94	70	110						
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	167	0	130	0						
Rangpur Zone Total						1030	950	435	367	414	350	139	85		
Sub-total: Plants in operation						25726	25211	8810.0	10074	10564	11385	3437	2258		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	8810	10074	10564	11385	3437	2258		
(C) Actual data of 12.12.23 (Yesterday) Tuesday :															
01.	Max. Demand at eve. peak (Generation end)	:	10074	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9549	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	10074	MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	6609	MW, at =	5:00 hrs	Dhaka	3692	3692	0	Mymensingh	746	746	0		
05.	Day-peak Generation (Generation end)	:	8810	MW, at =	12:00 hrs	Chattogram	949	949	0	Sylhet	348	348	0		
06.	Evening-peak Generation (Generation end)	:	10074	MW, at =	19:30 hrs	Khulna	1105	1105	0	Barisal	291	291	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Rajshahi	938	938	0	Rangpur	644	644	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6602	MW, at =	5:00 hrs	Cumilla	836	836	0						
09.	Generation shortfall at evening peak due to :	:				Total						9549	9549	0	
	a) Gas/LF limitation	:	3298	MW		13. Fuel cost : (a) Gas = 91745108 Taka						(c) Coal = 349849092 Taka			
	d) Coal supply Limitation	:	139	MW		(b) Oil = 285063031 Taka						Total = 726657231 Taka			
	b) Low water level in Kaptai lake	:	0	MW											
	c) Plants under shut down/ maintenance	:	2258	MW		14. Maximum Temperature in Dhaka was :						24.1°C			
10.	Total Energy (Generation + India Import)	:	200.14	MKWh		15. Export through East-West interconnections :									
	By Gas =	89.959	MKWH	By Oil =	21.872	At evening peak-hour						8827	MW, at 19:30 hrs		
	By Coal =	62.845	MKWH	By Hydro =	2.196	Maximum						100	MW, at 7:00 hrs		
	By Solar =	2.079	MKWH			Energy						0	MKWh		
11.	Total Gas Supplied	:	683.11	MMCFD											
(D) Forecast of 13.12.23 (Today) Wednesday :															
01.	Maximum Demand	:	10300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11385	MW	(Generation end)	05.	Total Generation	:	204.63	MKWh					
03.	Reserve / Shortage	:	1085	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	24.1°C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation