

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Friday				Date : 15.12.23					
Probable Maximum Demand : 9800 MW				Probable Maximum Generation : 11071 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.40 ft				Today = 96.28 ft					
								Rule Curve = 104.80 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.23 (Yesterday)		15.12.23 (Today)		14.12.23 (Yesterday)		15.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	74	71	71	39			Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	420	420	420	30			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	323	349	300	330				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	24	22	35	35				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	16	26	26				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	73	48	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	58	82	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	25	17	35				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	51	100	100				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54				
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	54	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	36	90	100				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	51	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	48	48				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total				5655	5422	1282	1698	1840	2206	1234	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	132	92	86	86				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	78	78	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	18	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	194	193	194	194				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	116	45	170				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	42	70	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	4	2	7				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	150	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	350	348	300	300				
	Metarbari 2*600 MW (CPGCL)	Coal				569	559	584	584				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				10	15	10	10				Test run
Chattogram Zone Total				3829	3769	1394	1521	1687	1849	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	48	45	45				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	334	390	330	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360		Under Maint.
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	325	320	330	330				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	31	70	12	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	30	0	20				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	9	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	27	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	19	34	34				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	28	28	57				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	25	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	3	39	42	42				
**	Import (Tirupura)	India		160	160	94	90	128	141				
Cumilla Zone Total				2959	2896	962	1248	1174	1374	0	744		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	34	30	40	168			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	9	28				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	64	77	56	77				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	155	145	153	151	168	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.12.23 (Yesterday)		15.12.23 (Today)		14.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	52	52	52	-1		Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	163	163	163		Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	5	5				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	63	63	3		Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	85	86	80	80				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	130	130	0	0				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	16	16	1		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	367	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	25	46	46	46	4		Gas Shortage	
Sylhet Zone Total					2472	2427	1225	1252	1306	1306	170	519	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	60	75	95				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0				
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	20	32	32				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	16				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	526	510	510	520				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDCL)	India		1000	1000	905	622	736	832				
Khulna Zone Total					3241	3237	1520	1228	1453	1540	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	20	20				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120				
119	Payra 1320 MW TPP	Coal (BOPCL)	2x622	1244	1244	480	510	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	63	17	35				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2265	975	1071	1249	1267	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	0	30				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	33	72	40	86				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	18	42	30	45				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	191	169	250	250	245	Gas Shortage		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11				
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	16	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	1	35	35	35				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	717	1002	400	400				
Raishahi Zone Total					3653	3631	991	1443	842	1028	966	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	170	170	114	Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	70	6	70				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	75	70	110				
149	Lalmourihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	23	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	137	0	130	0				
Rangpur Zone Total					1030	950	366	305	414	350	199	85	
Sub-total: Plants in operation					25726	25211	8870.0	9911	10118	11071	2917	2518	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0	
Gross Total					25951	25211	8870	9911	10118	11071	2917	2518	
(C) Actual data of 14.12.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	9911 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9555 MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	9911 MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6526 MW, at =	5:00 hrs	Dhaka	3650	3650	0	Mymensingh	767	767	0	
05.	Day-peak Generation (Generation end)	:	8870 MW, at =	12:00 hrs	Chattogram	954	954	0	Sylhet	345	345	0	
06.	Evening-peak Generation (Generation end)	:	9911 MW, at =	18:00 hrs	Khulna	1136	1136	0	Barisal	268	268	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Rajshahi	934	934	0	Rangpur	676	676	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6439 MW, at =	5:00 hrs	Cumilla	825	825	0					
09.	Generation shortfall at evening peak due to :	:							Total	9555	9555	0	
a)	Gas/LF limitation	:	2718 MW						(a) Gas =	92155863 Taka	(c) Coal =	282161899 Taka	
d)	Coal supply Limitation	:	199 MW						(b) Oil =	203714919 Taka	Total =	578032680 Taka	
b)	Low water level in Kaptai lake	:	0 MW										
c)	Plants under shut down/ maintenance	:	2518 MW										
10.	Total Energy (Generation + India Import)	:	181.97 MKWh										
	By Gas =	89.596 MKWh	By Oil =	15.365 MKWh									
	By Coal =	52.244 MKWh	By Hydro =	2.143 MKWh									
	By Solar=	1.928 MKWh											
11.	Total Gas Supplied	:	699.35 MMCFD										
(D) Forecast of 15.12.23 (Today) Friday :													
01.	Maximum Demand	:	9800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11071 MW (Generation end)		05.	Total Generation	:	179.93 MKWh					
03.	Reserve / Shortage	:	1271 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	25.6°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation