

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Saturday				Date : 16.12.23				
Probable Maximum Demand : 8800 MW				Probable Maximum Generation : 11323 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.28 ft	Today = 96.16 ft			Rule Curve = 104.60 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.12.23 (Yesterday)		16.12.23 (Today)		15.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for H/GPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	74	73	71	71	34	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	0		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	297	294	0	200			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	140	140	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	8	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	90	90			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	12	15	15			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	26	19	34	34			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	27	28	26	26			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	55	48	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	49	82	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	23	17	35			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	32	72	72			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	17	54			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	90	100			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1112	1414	1681	2250	1199	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	92	92	92			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	80	80	80	100	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	12	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	6	6	20			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	227	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	136	45	170			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	4	12	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	65	70	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	33	10	30			
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	30	150	150			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	300	301	350	350			
	Matlabari 2*600 MW (CPGCL)	Coal				586	578	0	0		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				3	11	10	10		Test run	
Chattogram Zone Total				3829	3769	1389	1688	1200	1377	100	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	48	49	45	45			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	315	275	330	330			
62	Ashuganj 450 MW CCPP(East)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under Maint.	
63	Ashuganj 420 MW CCPP(North)	Gas (APSCCL)	1x284+1x116	400	400	380	393	350	350			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	45	8	8			
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	51	37	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	105	12	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	1	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	10	10			
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	10	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	39	34	34			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	48	28	57			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	17	18	18			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	8	48	42	42			
**	Import (Tripura)	India		160	160	80	84	128	141			
Cumilla Zone Total				2959	2896	963	1252	1194	1394	0	744	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	85	100	100	117	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	28	9	28			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	24	71	56	77			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0			
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	4	6	6			
Mymensingh Zone Total				622	614	104	188	223	211	117	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.12.23 (Yesterday)		16.12.23 (Today)		15.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	25	52	52	26		Gas Shortage		
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0		Gas Shortage		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	5					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	63	63	3		Gas Shortage		
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	80	80					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	130	130					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16	9		Gas Shortage		
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	390	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	46	25	46	46	25		Gas Shortage		
Sylhet Zone Total						2472	2427	882	857	1436	1436	63	519	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	13	75	95					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	32					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	0	0	16					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	433	504	510	520					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDc)	India		1000	1000	722	532	835	931					
Khulna Zone Total						3241	3237	1227	1049	1552	1639	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	15	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120					
119	Payra 1320 MW TPP	Coal (BOPCL)	2x622	1244	1244	440	340	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140					
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total						2265	2265	935	852	1249	1267	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86					
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	45					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	34	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	218	237	414	414	177		Gas Shortage		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	17	8	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	35	35	35					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	433	593	550	550					
Raishahi Zone Total						3653	3631	661	996	1156	1362	898	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	6	107					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	0	70	110					
148	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	153	0	130	0					
Rangpur Zone Total						1030	950	352	170	414	387	189	85	
Sub-total: Plants in operation						25726	25211	7625.0	8466	10105	11323	2566	2518	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0	
Gross Total						25951	25211	7625	8466	10105	11323	2566	2518	
(C) Actual data of 15.12.23 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	8466	MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8165	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	8466	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6439	MW, at =	5:00 hrs	Dhaka	2805	2805	0	Mymensingh	721	721	0	
05.	Day-peak Generation (Generation end)	:	7625	MW, at =	12:00 hrs	Chattogram	760	760	0	Sylhet	340	340	0	
06.	Evening-peak Generation (Generation end)	:	8466	MW, at =	18:00 hrs	Khulna	1030	1030	0	Barisal	253	253	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	863	863	0	Rangpur	631	631	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5848	MW, at =	5:00 hrs	Cumilla	763	763	0					
09.	Generation shortfall at evening peak due to :	:				Total								0
a)	Gas/LF limitation	:	2377	MW		Fuel cost :				(c) Coal =				Taka
d)	Coal supply Limitation	:	189	MW		(a) Gas = 92725815 Taka				(b) Oil = 96598853 Taka				Taka
b)	Low water level in Kaptai lake	:	0	MW		Total =								
c)	Plants under shut down/ maintenance	:	2518	MW		Maximum Temperature in Dhaka was :								
10.	Total Energy (Generation + India Import)	:	178.26	MKWh		Export through East-West interconnections :								
	By Gas =	88.538	MKWh	By Oil =	7.662	At evening peak-hour				7625	MW, at	18:00 hrs		
	By Coal =	61.328	MKWh	By Hydro =	2.142	Maximum				-40	MW, at	8:00 hrs		
	By Solar =	2.072	MKWh			Energy				0.1815	MKWh			
11.	Total Gas Supplied	:	675.35	MMCFD										
(D) Forecast of 16.12.23 (Today) Saturday :														
01.	Maximum Demand	:	8800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11323	MW	(Generation end)	05.	Total Generation	:	185.29	MKWh				
03.	Reserve / Shortage	:	2523	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.1°C					