

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Sunday				Date : 17.12.23					
Probable Maximum Demand : 9800 MW				Probable Maximum Generation : 11371 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.16 ft				Today = 95.92 ft					
								Rule Curve = 104.50 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.12.23 (Yesterday)		17.12.23 (Today)		16.12.23 (Yesterday)		17.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	160	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for H/GPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	69	71	71	96			Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	420	450	450	30			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	33	370	370				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	81	153	0	0	57			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+3x8.73	80	80	34	34	34	34				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	17	17	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	26	26				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	48	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	82	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	17	35				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	72	72				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	54				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	90	100				
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas				0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0				
Dhaka Zone Total				5655	5422	778	1138	1911	2280	1138	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	60	92	92				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	77	80	80	103			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	218	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	45	45	170				
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	12	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	70	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			30	30	10	25				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	17	17				
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	12	12	12				
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	12	12				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	150	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	300	350	350	350				
	Metarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				5	7	10	10				Test run
Chattogram Zone Total				3829	3769	761	898	1200	1372	103	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	45	45	45				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	345	330	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360		Under Maint.
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	380	350	350				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	16	16				
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	10	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	50	12	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	0	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	0	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	9	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	34	34				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	37	28	57				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	23	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	44	10	10	10				
**	Import (Tripura)	India		160	160	78	88	128	141				
Cumilla Zone Total				2959	2896	914	1096	1170	1370	0	744		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	157	166	210	160	36			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	8	9	28				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	75	56	77				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	0	6	6				
Mymensingh Zone Total				622	614	204	249	333	271	36	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.12.23 (Yesterday)		17.12.23 (Today)		16.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		OT-1 Under maint.	
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28	62	OT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	53	52	52	-2	Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0	Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	5			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	65	63	63	1	Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	80	80			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	129	128	130	130			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	377	403	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	33	46	46	17	Gas Shortage	
Sylhet Zone Total					2472	2427	1246	1350	1436	1436	25	519
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	75	95			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	66	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	32			
113	Nosapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	455	545	510	510			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDc)	India		1000	1000	818	628	880	928			
Khulna Zone Total					3241	3237	1339	1173	1597	1626	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	119	120	120	120			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	530	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barisal Zone Total					2265	2265	814	1045	1249	1267	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	45			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	414	414	0	Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35			
140	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
**	Adani Power ,Jharkhanda Ltd	(Import)	2x748	1496	1496	425	500	550	550			
Rajshahi Zone Total					3653	3631	790	1003	1156	1362	721	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	35	6	107			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	110			
150	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	149	0	130	0			
Rangpur Zone Total					1030	950	353	240	414	387	189	85
Sub-total: Plants in operation					25726	25211	7199.0	8192	10466	11371	2212	2518
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosilia 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	7199	8192	10466	11371	2212	2518
(C) Actual data of 16.12.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	8192 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	7847 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	8192 MW, at =	18:00 hrs	Dhaka	2541	2541	0	Mymensingh	715	715	0
04.	Minimum Generation (Generation end)	:	5848 MW, at =	5:00 hrs	Chattogram	680	680	0	Sylhet	325	325	0
05.	Day-peak Generation (Generation end)	:	7199 MW, at =	12:00 hrs	Khulna	1051	1051	0	Barisal	257	257	0
06.	Evening-peak Generation (Generation end)	:	8192 MW, at =	18:00 hrs	Rajshahi	877	877	0	Rangpur	641	641	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	760	760	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5635 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	7847	7847	0
a)	Gas/LF limitation	:	2023 MW		13.	Fuel cost :	(a) Gas = 95788907 Taka	(c) Coal = 353475046 Taka				
d)	Coal supply Limitation	:	189 MW			(b) Oil = 31404726 Taka	Total = 480668679 Taka					
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :	26.0°C					
c)	Plants under shut down/ maintenance	:	2518 MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)	:	168.90 MKWh			At evening peak-hour	: 7199 MW, at	18:00 hrs				
	By Gas = 92.187 MKWh		By Oil = 2.483 MKWh			Maximum	: -40 MW, at	8:00 hrs				
	By Coal = 51.688 MKWh		By Hydro = 2.101 MKWh			Energy	: 0.1815 MKWh					
11.	Total Gas Supplied	:	768.01 MMCFD									
(D) Forecast of 17.12.23 (Today) Sunday :												
01.	Maximum Demand	:	9800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	11371 MW (Generation end)		05.	Total Generation	:	202.05 MKWh				
03.	Reserve / Shortage	:	1571 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation