

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023					Day : Monday				Date : 18.12.23					
Probable Maximum Demand :					9800 MW		Probable Maximum Generation :				11734 MW			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.92 ft		Today = 95.81 ft		Rule Curve = 104.40 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.12.23 (Yesterday)		18.12.23 (Today)		17.12.23 (Yesterday)		18.12.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW		Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	72	71	71	36			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	420	450	450	30			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	386	402	412	412					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	97	0	0	113			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	44	31	34	34					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	27	27	26	26					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	8	48	48	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	10	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	12	45	82	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	12	44	36	50					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	17	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	51	72	72					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	17	54					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	90	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total				5655	5422	1287	1718	1972	2380	1134	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	92	92	92					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	100	100	100	80			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	218	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	100	65	100					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	70	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			13	24	10	25					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	4	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	5	0	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	36	36	36					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	350	400	400	620					
	Matlabari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	5	10	10				Test run	
Chattogram Zone Total				3829	3769	878	1116	1163	1465	80	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	49	48	48	48					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	345	295	360	360					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360		Under Maint.	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	375	393	393	393					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	73	73	73	73					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	142	12	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	11	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	100	100					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	2	47	9	47					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	34	18	18					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	25	25	30	25					
**	Import (Tripura)	India		160	160	94	92	128	140					
Cumilla Zone Total				2959	2896	1088	1306	1327	1592	0	744			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	190	112	70	100	90			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	9	28					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	75	56	75					
84	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0					
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	4	6	6					
Mymensingh Zone Total				622	614	300	219	193	209	90	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.12.23 (Yesterday)		18.12.23 (Today)		17.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	OT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	52	52	-2		Gas Shortage			
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163	0		Gas Shortage			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	63	63	3		Gas Shortage			
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	80	80						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	130	128	130	130						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	394	332	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	39	46	46	11		Gas Shortage			
Sylhet Zone Total						2472	2427	1301	1282	1408	1408	21	547		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	75	95						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	32						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	510	628	510	510						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDc)	India		1000	1000	863	816	881	930						
Khulna Zone Total						3241	3237	1441	1444	1598	1628	0	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	622	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	75	17	75						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220						
Barishal Zone Total						2265	2265	1045	1197	1249	1307	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82						
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	45						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	341	414	414	73		Gas Shortage			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	17	8	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	35	35	35						
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	416	581	550	550						
Raishahi Zone Total						3653	3631	848	1072	1166	1358	794	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	89	6	107						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	110						
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	174	0	130	0						
Rangpur Zone Total						1030	950	379	294	414	387	189	85		
Sub-total: Plants in operation						25726	25211	8567.0	9648	10490	11734	2308	2546		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	8567	9648	10490	11734	2308	2546		
(C) Actual data of 17.12.23 (Yesterday) Sunday :															
01.	Max. Demand at eve. peak (Generation end)	:	9648	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9163	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	9648	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	5635	MW, at =	5:00 hrs	Dhaka	3429	3429	0	Mymensingh	753	753	0		
05.	Day-peak Generation (Generation end)	:	8567	MW, at =	12:00 hrs	Chattogram	863	863	0	Sylhet	353	353	0		
06.	Evening-peak Generation (Generation end)	:	9648	MW, at =	19:00 hrs	Khulna	1081	1081	0	Barishal	276	276	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	930	930	0	Rangpur	642	642	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6274	MW, at =	5:00 hrs	Cumilla	837	837	0						
09.	Generation shortfall at evening peak due to :	:				Total								0	
a)	Gas/LF limitation	:	2119	MW		Fuel cost :				(c) Coal =				Taka	
d)	Coal supply Limitation	:	189	MW		(a) Gas =	107149335	Taka		(c) Coal =	378998989	Taka			
b)	Low water level in Kaptai lake	:	0	MW		(b) Oil =	133406951	Taka		Total =	619555275	Taka			
c)	Plants under shut down/ maintenance	:	2546	MW		14. Maximum Temperature in Dhaka was :								26.7°C	
10.	Total Energy (Generation + India Import)	:	189.31	MKWh		15. Export through East-West interconnections :									
	By Gas =	103.322	MKWh	By Oil =	10.160	At evening peak-hour :									
	By Coal =	51.052	MKWh	By Hydro =	1.607	Maximum :									
	By Solar =	2.291	MKWh			Energy :									
11.	Total Gas Supplied	:	812.65	MMCFD											
(D) Forecast of 18.12.23 (Today) Monday :															
01.	Maximum Demand	:	9800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11734	MW	(Generation end)	05.	Total Generation	:	192.29	MKWh					
03.	Reserve / Shortage	:	1934	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	22.6°C						