

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Tuesday				Date : 19.12.23				
Probable Maximum Demand :				Probable Maximum Generation :								
10500 MW				12132 MW								
Water Level of Kaptai Lake at 06:00 AM				Rule Curve =				104.30 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.12.23 (Yesterday)		19.12.23 (Today)		18.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180		Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Awaiting for HGPI	
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	75	71	71	38	Gas Shortage	
6	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired	
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	0		
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115 Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	400	412	412			
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
15	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	5	40	15	55			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	24	90	90			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15			
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	32	29	34	34			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	32	32			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	2	0	8	17			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	45	17	105			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	48	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	72	45	82	130			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	36	50			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	35			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	17	35			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	13	26	72	72			
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54			
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	35	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17			
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	17	90	90			
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	22	90	100			
35	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	62	85	85			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	33	48	48			
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
38	Meghnaghat Unique Power	Gas				0	0	0	0			
39	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0			
Dhaka Zone Total				5655	5422	1491	1743	2012	2386	1203	740	
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	92	92	92			
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	93	100	100	100	80	Gas Shortage	
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180 Under maint.	
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17			
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20			
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150 Under maint.	
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	221	225	225			
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	98	65	100	170			
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
52	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34			
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	72	74	70	70			
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12			
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	24	5	25			
56	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17			
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	5	12	12	12			
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	36	36	36			
63	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	367	317	350	350			
64	Metarbari 2*600 MW (CPGCL)	Coal				126	583	580	580		Test run	
65	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total				3829	3769	1237	1663	1723	1845	80	330	
66	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	45	48	48			
67	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221 Under Maint.	
68	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	330	290	320	340			
69	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360 Under Maint.	
70	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	375	375	393	393			
71	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	11	8	8	8			
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	38	105	12	150			
74	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	0	30			
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163 Under maint.	
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	18	17	17	17			
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10			
79	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	4	46	0	52			
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	10	10			
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	51	100	100			
83	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	47	9	48			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	24	18	18			
86	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	54	52	30	55			
87	** Import (Tirupura)	India		160	160	102	92	128	140			
Cumilla Zone Total				2959	2896	1141	1314	1222	1538	0	744	
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	34	34	70	168	Gas Shortage	
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
90	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	9	28			
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	76	56	75			
92	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
93	Sutlakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
94	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	4	24	6	6			
Mymensingh Zone Total				622	614	151	162	157	179	168	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.12.23 (Yesterday)		19.12.23 (Today)		18.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Machines shut down (MW)		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	OT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	OT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51	-2	Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0	Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
92	Shahjibazar GTPP Unit: 8 & 9	Gas (PDB)	2x35	70	66	60	63	63	63	3	Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	40	80	80			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	65	122	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	122	343	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	42	46	46	46	4	Gas Shortage	
Sylhet Zone Total					2472	2427	1009	1304	1487	14	547	
104	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	30	75	95			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	32			
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	622	617	510	510			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	865	776	883	931			
Khulna Zone Total					3241	3237	1558	1447	1600	1629	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	19	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	610	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	75			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	150	150	150			
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	225	220	220	220			
Barishal Zone Total					2265	2265	1154	1259	1317	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	30	45			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	385	414	414	29	Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
137	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	35	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	1	35	35	35			
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
**	Adani Power, Jharkhanda Ltd	(Import)	2x748	1496	1496	426	562	550	550			
Rajshahi Zone Total					3653	3631	877	1129	1166	1358	750	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	25	6	113			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	0	70	110			
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	29	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	160	0	130	0			
Rangpur Zone Total					1030	950	364	195	414	393	189	85
Sub-total: Plants in operation					25726	25211	8756.0	10111	11040	12132	2404	2546
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
151	Bosila 108MW PP (C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	8756	10111	11040	12132	2404	2546
(C) Actual data of 18.12.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	10111 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9620 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10111 MW, at =	18:00 hrs	Dhaka	3686	3686	0	Mymensingh	765	765	0
04.	Minimum Generation (Generation end)	:	6274 MW, at =	5:00 hrs	Chattogram	912	912	0	Sylhet	364	364	0
05.	Day-peak Generation (Generation end)	:	8756 MW, at =	12:00 hrs	Khulna	1132	1132	0	Barishal	275	275	0
06.	Evening-peak Generation (Generation end)	:	10111 MW, at =	18:00 hrs	Rajshahi	949	949	0	Rangpur	717	717	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	821	821	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6353 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	9620	9620	0
a)	Gas/LF limitation	:	2215 MW		13.	Fuel cost :	(a) Gas = 105033798 Taka	(c) Coal = 415500974 Taka				
d)	Coal supply Limitation	:	189 MW			(b) Oil = 168214611 Taka		Total = 688749383 Taka				
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :	26.9°C					
c)	Plants under shut down maintenance	:	2546 MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)	:	202.41 MKWh			At evening peak-hour	:	8756 MW, at	18:00 hrs			
	By Gas = 101.549 MKWh					Maximum	:	128 MW, at	7:00 hrs			
	By Coal = 63.435 MKWh					Energy	:	0.0165 MKWh				
	By Solar = 2.129 MKWh											
11.	Total Gas Supplied	:	771.54 MMCFD									
(D) Forecast of 19.12.23 (Today) Tuesday :												
01.	Maximum Demand	:	10500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12132 MW (Generation end)		05.	Total Generation	:	210.20 MKWh				
03.	Reserve / Shortage	:	1632 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	26.9°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation