

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Wednesday				Date : 20.12.23			
Probable Maximum Demand : 10300 MW				Probable Maximum Generation : 11927 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.70 ft	Today = 95.58 ft			Rule Curve = 104.20 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.12.23 (Yesterday)		20.12.23 (Today)		19.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for H/GPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	71	71	71	38	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	450	400	450	0	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	372	397	350	390		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	40	15	40		
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	92	92	92		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	15	15		
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+3x8.73	80	80	33	25	34	34		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	26	32	32		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	17	8	16		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	51	17	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	149	48	149		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	118	130	130		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17		
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	35		
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	17	35		
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	52	17	17		
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	17	54		
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0		
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	17		
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	90	90		
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	100	100		
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	80	80		
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	48	48		
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		
	Meghnaghat Unique Power	Gas			0	0	0	0	0		
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0		
Dhaka Zone Total				5655	5422	1238	1918	1881	2257	1203	740
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	92	92	92		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	70	54	0	0	126	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	12	8	17		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20		
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	6	17	17	17		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	227	226	225	225		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	130	100	100		
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	7	12	12	12		
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	34		
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	75	40	70		
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12		
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	5	10		
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17		
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17		
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12		
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	90	163		
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	309	350	350	350		
	Metarbari 2*600 MW (CPGCL)	Coal				586	584	580	580		Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				2	3	10	10		Test run
Chattogram Zone Total				3829	3769	1387	1666	1647	1787	126	330
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	45	48	48		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	300	300	330	340		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under Maint.
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	392	393	393		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8		
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	47	31	43	43		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	47	69	50	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	40	0	30		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	10	17	17		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10		
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	41	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	11	10	10		
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	99	100	100		
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	3	47	9	47		
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17		
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	18	18	18		
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	51	31	30	30		
**	Import (Tripura)	India		160	160	102	106	128	140		
Cumilla Zone Total				2959	2896	1101	1325	1314	1504	0	744
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	33	35	35	169	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	9	28		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	76	56	75		
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0		
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	24	6	22		
Mymensingh Zone Total				622	614	153	161	158	160	169	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.12.23 (Yesterday)		20.12.23 (Today)		19.12.23 (Yesterday)		20.12.23 (Today)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening									
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27		OT-1 Under maint.				
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			90		OT-4 Under maint.				
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	48	51	51	3				Gas Shortage				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163	0				Gas Shortage				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	5									
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	63	63	3				Gas Shortage				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330		Under maint.				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	30	30									
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	209	207	210	210									
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0									
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10									
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16	9				Gas Shortage				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0									
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	349	344	400	400									
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400									
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100		Under project work				
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	40	20	20	10				Gas Shortage				
Sylhet Zone Total						2472	2427	1320	1372	1411	1411	25	547					
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0									
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0					Gas Shortage				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45									
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0									
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0									
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	35	70									
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0									
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	62	0	100	0									
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	32									
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16									
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	470	614	510	510									
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0									
**	Bheramara (HVDCL)	India		1000	1000	866	655	869	917									
Khulna Zone Total						3241	3237	1398	1328	1546	1590	0	0					
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110									
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	22	20	20									
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120									
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	510	622	622									
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	75									
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	160	160	150	150									
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	220	220	220									
Barishal Zone Total						2265	2265	981	1049	1259	1317	0	0					
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71				Gas Shortage				
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100		Under maint.				
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30									
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0									
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20									
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82									
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	30	45									
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	42									
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38									
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210				Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220				Gas Shortage				
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220				Gas Shortage				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	405	369	414	414	45				Gas Shortage				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11									
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8									
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	50									
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	35	35	35									
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28									
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0									
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	412	518	600	748									
Rajshahi Zone Total						3653	3631	830	1082	1216	1551	766	100					
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85				Coal Shortage				
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85		Under Overhauling				
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104				Coal Shortage				
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	10	74	40	70									
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
147	Majpara, Taluka 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0									
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	110									
149	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0									
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	168	0	130	0									
Rangpur Zone Total						1030	950	382	279	448	350	189	85					
Sub-total: Plants in operation						25726	25211	8790.0	10180	10880	11927	2478	2546					
(B) Plants under long term maintenance/ contract expired																		
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0									
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0									
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0									
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0					
Gross Total						25951	25211	8790	10180	10880	11927	2478	2546					
(C) Actual data of 19.12.23 (Yesterday) Tuesday :																		
01.	Max. Demand at eve. peak (Generation end)	:	10180	MW,	at =	18:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	9745	MW,	at =	18:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	10180	MW,	at =	18:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW			
04.	Minimum Generation (Generation end)	:	6353	MW,	at =	5:00	hrs	Dhaka	3735	3735	0	Mymensingh	765	765	0			
05.	Day-peak Generation (Generation end)	:	8790	MW,	at =	12:00	hrs	Chattogram	977	977	0	Sylhet	356	356	0			
06.	Evening-peak Generation (Generation end)	:	10180	MW,	at =	18:00	hrs	Khulna	1148	1148	0	Barishal	273	273	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	18:00	hrs	Rajshahi	964	964	0	Rangpur	700	700	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6533	MW,	at =	5:00	hrs	Cumilla	828	828	0							
09.	Generation shortfall at evening peak due to :	:						Total										
	a) Gas/LF limitation	:	2289	MW				(a) Gas = 103781889 Taka				(c) Coal = 376954002 Taka						
	d) Coal supply Limitation	:	189	MW				(b) Oil = 148239119 Taka				Total = 628975010 Taka						
	b) Low water level in Kaptai lake	:	0	MW			Maximum Temperature in Dhaka was : 26.5°C											
	c) Plants under shut down/ maintenance	:	2546	MW			Export through East-West interconnections :											
10.	Total Energy (Generation + India Import)	:	200.95	MKWh			At evening peak-hour											
	By Gas =	101.291	MKWh	By Oil =	11.242	MKWh	: 8790 MW, at 18:00 hrs											
	By Coal =	63.993	MKWh	By Hydro =	2.155	MKWh	Maximum											
	By Solar=	2.169	MKWh	Energy								: 0.099 MKWh						
11. Total Gas Supplied : 762.93 MMCFD																		
(D) Forecast of 20.12.23 (Today) Wednesday :																		
01.	Maximum Demand	:	10300	MW	(Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)												
02.	Maximum Generation	:	11927	MW	(Generation end)	05. Total Generation : 203.32 MKWh												
03.	Reserve / Shortage	:	1627	MW	(Generation end)	06. Probable Max. Temperature in Dhaka : 26.5°C												