

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Thursday				Date : 21.12.23					
Probable Maximum Demand : 10000 MW				Probable Maximum Generation : 11956 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.58 ft	Today = 95.36 ft			Rule Curve = 104.10 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.12.23 (Yesterday)		21.12.23 (Today)		20.12.23 (Yesterday)		21.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	74	71	71	36			Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	400	450	450	70			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	404	350	390				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	25	15	40				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	32	92	92				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	11	11	34	34				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	25	17	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	30	32	32				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	10	8	16				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	115	48	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	75	130	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	17	17				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	30	17	35				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	17	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	17	17				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	54				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	40	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	25	100	100				
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	80	80				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total				5655	5422	1234	1680	1881	2257	1271	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	92	92	92				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	15	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	228	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	82	100	100				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	12	12	12				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	40	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	14	12	12				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	5	10				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	24	0	0				
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	10	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	12	12	12				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	20	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	81	163	90	163				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	350	325	350	350				
	Metarbari 2*600 MW (CPGCL)	Coal				587	586	580	580				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run
Chattogram Zone Total				3829	3769	1373	1707	1647	1787	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	48	48	48				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	350	350	330	340				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360		Under Maint.
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	375	340	393	393				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	55	8	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	43	43	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	57	150	60				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	6	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	11	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	100	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	58	9	58				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	17	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	54	32	32	50				
**	Import (Tripura)	India		160	160	98	94	128	140				
Cumilla Zone Total				2959	2896	1105	1166	1416	1445	0	744		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	33	35	35	169			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	47	47				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	76	56	75				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	23	6	6	22				
Mymensingh Zone Total				622	614	174	143	196	17				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.12.23 (Yesterday)		21.12.23 (Today)		20.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51						
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163	0					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	63	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	30	30						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	210	210	210						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0						
100	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	407	399	400	400						
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	400	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	42	39	39						
Sylhet Zone Total				2472	2427	1368	1432	1430	1430	0	547				
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0						
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	35	70						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	32						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	504	620	510	510						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDCL)	India		1000	1000	854	609	869	917						
Khulna Zone Total				3241	3237	1429	1262	1546	1590	0	0				
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	20	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	120	120	120						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	540	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	75						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200						
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220						
Barishal Zone Total				2265	2265	945	1117	1309	1367	0	0				
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82						
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	15	30	45						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	354	426	414	414						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11						
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	50						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35						
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	673	758	709	748						
Raishahi Zone Total				3653	3631	1032	1313	1325	1551	721	100				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	49	40	70						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	54	70	110						
148	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	179	0	130	0						
Rangpur Zone Total				1030	950	388	273	448	350	189	85				
Sub-total: Plants in operation				25726	25211	9048.0	10093	11198	11956	2530	2546				
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired				225	0	0	0	0	0	0	0				
Gross Total				25951	25211	9048	10093	11198	11956	2530	2546				
(C) Actual data of 20.12.23 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	10093	MW,	at =	18:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9764	MW,	at =	18:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand		
03.	Highest Generation (Generation end)	:	10093	MW,	at =	18:00	hrs	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	6533	MW,	at =	5:00	hrs	Dhaka	3774	3774	0	Mymensingh	769		
05.	Day-peak Generation (Generation end)	:	9048	MW,	at =	12:00	hrs	Chattogram	998	998	0	Sylhet	359		
06.	Evening-peak Generation (Generation end)	:	10093	MW,	at =	18:00	hrs	Khulna	1125	1125	0	Barisal	272		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	18:00	hrs	Rajshahi	966	966	0	Rangpur	718		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6620	MW,	at =	5:00	hrs	Cumilla	784	784	0		718		
09.	Generation shortfall at evening peak due to :	:						Total		9764	9764	0			
a)	Gas/LF limitation	:	2341	MW				(a) Gas = 99863637 Taka		(c) Coal = 422744646 Taka					
d)	Coal supply Limitation	:	189	MW				(b) Oil = 114477316 Taka		Total = 637085599 Taka					
b)	Low water level in Kaptai lake	:	0	MW				14. Maximum Temperature in Dhaka was : 27.5°C							
c)	Plants under shut down/ maintenance	:	2546	MW				15. Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	202.62	MKWh				At evening peak-hour		9048	MW,	at	18:00	hrs	
	By Gas = 99.154 MKWh				By Oil = 10.121 MKWh			Maximum		166	MW,	at	20:00	hrs	
	By Coal = 69.491 MKWh				By Hydro = 2.199 MKWh			Energy		0.066	MKWh				
	By Solar= 2.372 MKWh														
11.	Total Gas Supplied	:	741.63	MMCFD											
(D) Forecast of 21.12.23 (Today) Thursday :															
01.	Maximum Demand	:	10000	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11956	MW	(Generation end)			05.	Total Generation	:	200.75	MKWh			
03.	Reserve / Shortage	:	1956	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	22.6°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation