

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Friday				Date : 22.12.23				
Probable Maximum Demand : 9600 MW				Probable Maximum Generation : 12311 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.36 ft. Today = 95.12 ft.				Rule Curve = 104.00 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.12.23 (Yesterday)		22.12.23 (Today)		21.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	72	71	71	36	Gas Shortage	
6	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired	
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	50	Gas Shortage	
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	361	348	390	390			
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	45	15	55			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	92	92			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	15	15			
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+3x8.73	80	80	30	21	34	34			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	17	25			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	29	32	32			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	16	8	16			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	77	17	105			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	115	48	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	22	130	130			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	17	17			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	35			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	17	35			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	54			
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	17	17			
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	100	100			
35	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	32	80	80			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	48	48			
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
38	Meghnaghat Unique Power	Gas			0	0	0	0	0			
39	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1241	1599	1971	2272	1251	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	100	100	250			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	34			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	50	40	70			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	12	12			
52	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	30	30			
53	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	12	0	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	17			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	6	17	17	17			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	19	12	12			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	20	17	17	17			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	124	90	163			
60	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	420	420	350	400			
61	Metarbari 2*600 MW (CPGCL)	Coal				587	587	580	580		Test run	
62	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total				3829	3769	1389	1770	1666	2001	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	48	48	48			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	340	265	330	340			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under Maint.	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	375	320	380	380			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	36	8	8	8			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	150	12	6	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	9	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	22	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	30	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	70	100	100			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	38	9	58			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	23	18	18			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	49	51	50	50			
80	Import (Tripura)	India		160	160	88	92	128	140			
Cumilla Zone Total				2959	2896	1202	1103	1277	1522	0	744	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	34	35	40	168	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	45	78	57	79			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	28	9	28			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	6	6	22			
Mymensingh Zone Total				622	614	124	146	159	169	168	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.12.23 (Yesterday)		22.12.23 (Today)		21.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	43	43	43	27	GT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51			
90	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	61	63	63			
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	30	30			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	207	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	22	22			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	366	400	400			
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	394	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	38	42	42	42			
Sylhet Zone Total					2472	2427	1404	1396	1439	1439	0	547
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	35	70			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	69	0	100	0			
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	32	32			
113	Nosapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	509	585	510	600			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDc)	India		1000	1000	840	609	721	818			
Khulna Zone Total					3241	3237	1418	1227	1398	1581	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	21	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	125	125			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	440	530	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	75			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	200	200	200			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	938	1145	1314	1372	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	45	30	45			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	421	414	414	414			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	30	35	35			
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0			
**	Adani Power ,Jharkhanda Ltd	(Import)	2x748	1496	1496	680	760	720	760			
Rajshahi Zone Total					3653	3631	1110	1383	1336	1568	721	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	106	50	107			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	100	70	110			
150	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	166	0	130	0			
Rangpur Zone Total					1030	950	409	376	458	387	189	85
Sub-total: Plants in operation					25726	25211	9235.0	10145	11018	12311	2509	2546
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosilia 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	9235	10145	11018	12311	2509	2546
(C) Actual data of 21.12.23 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	10145 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9882 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10145 MW, at =	18:00 hrs	Dhaka	3874	3874	0	Mymensingh	760	760	0
04.	Minimum Generation (Generation end)	:	6620 MW, at =	5:00 hrs	Chattogram	966	966	0	Sylhet	364	364	0
05.	Day-peak Generation (Generation end)	:	9235 MW, at =	12:00 hrs	Khulna	1150	1150	0	Barishal	269	269	0
06.	Evening-peak Generation (Generation end)	:	10145 MW, at =	18:00 hrs	Rajshahi	946	946	0	Rangpur	708	708	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	846	846	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6628 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	9882	9882	0
a)	Gas/LF limitation	:	2320 MW		13.	Fuel cost :	(a) Gas = 100004041 Taka	(c) Coal = 431608005 Taka				
d)	Coal supply Limitation	:	189 MW			(b) Oil = 148320539 Taka	Total = 679932586 Taka					
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :	28.1°C					
c)	Plants under shut down/ maintenance	:	2546 MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)	:	205.34 MKWh			At evening peak-hour	:	9235 MW, at	18:00 hrs			
	By Gas = 99.122 MKWh					Maximum	:	166 MW, at	20:00 hrs			
	By Coal = 71.468 MKWh					Energy	:	0.066 MKWh				
	By Solar= 2.374 MKWh											
11.	Total Gas Supplied	:	752.76 MMCFD									
(D) Forecast of 22.12.23 (Today) Friday :												
01.	Maximum Demand	:	9600 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12311 MW (Generation end)		05.	Total Generation	:	194.31 MKWh				
03.	Reserve / Shortage	:	2711 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.1°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation