

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023					Day : Saturday					Date : 23.12.23				
Probable Maximum Demand :					Probable Maximum Generation :									
9500 MW					11779 MW									
Water Level of Kaptai Lake at 06:00 AM					Rule Curve =					104.00 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.12.23 (Yesterday)		23.12.23 (Today)		22.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date	
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	67	72	71	72	41	Gas Shortage			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	420	450	450	30	Gas Shortage			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	322	281	0	200					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	80	0	210	Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage			
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	17	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	15	15					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	11	0	34	34					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	32	32					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	48	149					
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	130	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	11	17	17					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	17	17					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	0	0					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	100	100					
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	45	45					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total			5655	5422	1022	1147	1639	1999	1236	740				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	6	6	18					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	229	225	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	30	100	200					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	15	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	17					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	60					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			17	16	10	20					
51	Chattogram 108 MW PP (ECVP)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	11	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	90	163					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	320	330	300	350					
	Matarbari 2*600 MW (CPGCL)	Coal				587	585	580	585		Test run			
	Cox's Bazar Wind PP	(Wind) (IPP)				1	0	10	10		Test run			
Chattogram Zone Total			3829	3769	1309	1365	1599	1870	180	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	48	48	48	48					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	345	290	330	360					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Under Maint.			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	305	310	380	380					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	38	8	8					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	30	38	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	8	6	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	100	100					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	28	48					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	18	18	18					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	51	36	50	50					
**	Import (Tripura)	India		160	160	108	88	128	140					
Cumilla Zone Total			2959	2896	972	992	1296	1532	0	744				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	61	75	80	80	127	Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	75	57	79					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	28	9	28					
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total			622	614	179	184	204	193	127	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.12.23 (Yesterday)		23.12.23 (Today)		22.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Machines shut down (MW)		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	GT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51			
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163	0		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	63	63			
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	60	60			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	210	210	210			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	22	24			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			
100	Bibiyaan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	388	365	400	400			
101	Bibiyaan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	36	38	40	40			
Sylhet Zone Total					2472	1323	1360	1424	1426	0	590	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	70			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	16			
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	452	567	510	600			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	707	718	721	818			
Khulna Zone Total					3241	3237	1224	1285	1366	1552	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	20	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	118	120	120			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	390	430	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	75			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	236	200	200			
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220			
Barisal Zone Total					2265	2265	809	1024	1309	1367	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	82			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	40			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	400	300	300			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	35			
140	Aminara 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0			
**	Adani Power ,Jharkhand Ltd	(Import)	2x748	1496	1496	573	762	720	760			
Rajshahi Zone Total					3653	3631	924	1167	1222	1447	721	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	50	113			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	0	70	110			
150	Lalmohorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	168	0	130	0			
Rangpur Zone Total					1030	950	411	170	458	393	189	85
Sub-total: Plants in operation					25726	25211	8173.0	8694	10517	11779	2453	2589
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosila 108MW PP(CCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	8173	8694	10517	11779	2453	2589
(C) Actual data of 22.12.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	8694 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8402 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	8737 MW, at =	13:00 hrs	Dhaka	2915	2915	0	Mymensingh	718	718	0
04.	Minimum Generation (Generation end)	:	6628 MW, at =	5:00 hrs	Chattogram	876	876	0	Sylhet	330	330	0
05.	Day-peak Generation (Generation end)	:	8173 MW, at =	12:00 hrs	Khulna	1044	1044	0	Barisal	258	258	0
06.	Evening-peak Generation (Generation end)	:	8694 MW, at =	18:00 hrs	Rajshahi	863	863	0	Rangpur	639	639	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	758	758	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6197 MW, at =	5:00 hrs					Total	8402	8402	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 98060098 Taka	(c) Coal = 393661625 Taka				
a) Gas/LF limitation	:	2264 MW				(b) Oil = 29243934 Taka		Total = 520965658 Taka				
d) Coal supply Limitation	:	189 MW			14.	Maximum Temperature in Dhaka was :	27.5°C					
b) Low water level in Kaptai lake	:	0 MW			15.	Export through East-West interconnections :						
c) Plants under shut down/ maintenance	:	2589 MW				At evening peak-hour	:	8173 MW, at	18:00 hrs			
10.	Total Energy (Generation + India Import)	:	185.19 MKWh			Maximum	:	110 MW, at	7:00 hrs			
	By Gas = 96.035 MKWh	By Oil = 2.235 MKWh				Energy	:	0.099 MKWh				
	By Coal = 65.948 MKWh	By Hydro = 2.081 MKWh										
	By Solar= 2.313 MKWh											
11.	Total Gas Supplied	:	704.72 MMCFD									
(D) Forecast of 23.12.23 (Today) Saturday :												
01.	Maximum Demand	:	9500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	11779 MW (Generation end)		05.	Total Generation	:	201.36 MKWh				
03.	Reserve / Shortage	:	2279 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation