

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2023				Day : Sunday				Date : 24.12.23					
Probable Maximum Demand : 10200 MW				Probable Maximum Generation : 11895 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 94.90 ft	Today = 94.78 ft			Rule Curve = 103.80 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.12.23 (Yesterday)		24.12.23 (Today)		23.12.23 (Yesterday)		24.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW				
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for H/GPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	71	71	71	38			Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	370	450	450	450	0			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	250				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	80	77	80	80	133			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	8	55	15	55				
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	26	33	34	34				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	17	17	17				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	32	32				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	35	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	140	48	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	130	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	35				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	15	17	17	17				
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	0	0				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	100	100				
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	21	80	80				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	45	45				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total				5655	5422	935	1263	1657	2128	1126	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	5	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	226	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	30	100	200				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	19	12	12	12				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	64	86	40	86				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	13	15	15				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	4	5	15				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	106	0	0				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	1	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	10	12	12				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	12	12				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	20	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	163	163				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	320	350	300	350				
	Matlabari 2*600 MW (CPGCL)	Coal				566	584	580	585				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run
Chattogram Zone Total				3829	3769	1425	1793	1667	1910	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	5	48	48				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	280	300	320				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	10	300	300		350		Under Maint.
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	265	0	0				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	45	0	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	132	6	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	32	0	32				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	48	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	80	100	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	47	28	48				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	18	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	50	0	50	50				
**	Import (Tripura)	India		160	160	104	102	128	140				
Cumilla Zone Total				2959	2896	1074	1167	1186	1414	0	734		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	70	71	80	80	131			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	60	79	57	79				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	37	19	35				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0				
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	2	6	6				
Mymensingh Zone Total				622	614	171	189	214					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.12.23 (Yesterday)		24.12.23 (Today)		23.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	30	30	30		40	GT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51						
90	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	53	163	163	110					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	5	5						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	63	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	60	30	30	30						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	210	210	210						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	15	22	24						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	318	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	45	45	45						
Sylhet Zone Total						2472	2427	1363	1212	1429	1431	110	560		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0						
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	70						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	10	0	16						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	503	625	510	600						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDc)	India		1000	1000	750	809	870	919						
Khulna Zone Total						3241	3237	1318	1452	1515	1653	0	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	16	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	115	76	120	120						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	510	600	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	17	72						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	307	160	160						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	220	220						
Barishal Zone Total						2265	2265	989	1251	1269	1324	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	27	0	30						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	5	50	50	82						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	35	50						
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	40						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	263	238	280	280						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11						
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	15	35	35						
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	659	754	720	760						
Raishahi Zone Total						3653	3631	944	1228	1207	1437	721	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	70	50	113						
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
147	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0						
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	70	115						
149	Lalmorihatal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	23	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	57	0	130	0						
Rangpur Zone Total						1030	950	256	355	458	398	189	85		
Sub-total: Plants in operation						25726	25211	8475.0	9910	10602	11895	2457	2549		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	8475	9910	10602	11895	2457	2549		
(C) Actual data of 23.12.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	9910	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9526	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	9910	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	6197	MW, at =	4:00 hrs	Dhaka	3630	3630	0	Mymensingh	781	781	0		
05.	Day-peak Generation (Generation end)	:	8475	MW, at =	12:00 hrs	Chattogram	968	968	0	Sylhet	361	361	0		
06.	Evening-peak Generation (Generation end)	:	9910	MW, at =	19:00 hrs	Khulna	1087	1087	0	Barisal	281	281	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	935	935	0	Rangpur	657	657	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6565	MW, at =	5:00 hrs	Cumilla	826	826	0						
09.	Generation shortfall at evening peak due to :	:				Total							9526	9526	0
a)	Gas/LF limitation	:	2268	MW		(a) Gas = 92045921 Taka							422166367	Taka	
d)	Coal supply Limitation	:	189	MW		(b) Oil = 177613498 Taka							691825786	Taka	
b)	Low water level in Kaptai lake	:	0	MW		Total =									
c)	Plants under shut down/ maintenance	:	2549	MW		Maximum Temperature in Dhaka was :							26.9°C		
10.	Total Energy (Generation + India Import)	:	194.69	MKWh		Export through East-West interconnections :									
	By Gas = 89.462 MKWh			By Oil = 13.769 MKWh		At evening peak-hour :							8475	MW, at 19:00 hrs	
	By Coal = 69.034 MKWh			By Hydro = 2.077 MKWh		Maximum :							190	MW, at 7:00 hrs	
	By Solar = 1.199 MKWh					Energy :							0	MKWh	
11.	Total Gas Supplied	:	731.25	MMCFD											
(D) Forecast of 24.12.23 (Today) Sunday :															
01.	Maximum Demand	:	10200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11895	MW	(Generation end)	05.	Total Generation	:	200.38	MKWh					
03.	Reserve / Shortage	:	1695	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation