

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Monday				Date : 25.12.23				
Probable Maximum Demand : 10000 MW				Probable Maximum Generation : 11580 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 94.78 ft Today = 94.66 ft				Rule Curve = 103.70 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.12.23 (Yesterday)		25.12.23 (Today)		24.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180		Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Awaiting for H/GPI	
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	71	71	40		Gas Shortage	
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	105		Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired	
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	380	450	450	70	Gas Shortage	
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	306	400	400			
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	102	0	0	210		Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	335		Gas Shortage	
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	335		Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	40	90	90			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
18	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.7+7x8.73	80	80	33	33	33	33			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	16	17	17			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	26	32	32			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	17			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	105			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	48	149			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	25	45	95	130			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	35			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	35			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	9	17	17			
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	0	17			
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	35	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	21	55	17	17			
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	28	90	90			
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	10	100	100			
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	85	78	85	85			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	45	45			
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
38	Meghnaghat Unique Power	Gas			0	0	0	0	0			
39	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1062	1603	1914	2164	1275	740	
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	180		Gas Shortage	
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17			
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20			
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	199	199	200	200			
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	170	150	200			
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
52	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	34			
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	58	74	40	86			
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	10	15	15			
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	5	15			
56	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	3	17	17	17			
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	20	17	17	17			
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	108	163	163			
63	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	345	350	350	350			
64	Matlabari 2*600 MW (CPGCL)	Coal				586	599	600	450		Test run	
65	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total				3829	3769	1498	1768	1762	1750	180	330	
66	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	47	48	48			
67	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.	
68	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	310	310	310			
69	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	310	310	310	50	Under Maint.	
70	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0			
71	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	8	8			
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	50	12	150			
74	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	0	32			
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	14	18	18			
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	0	10	10			
79	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	28	52	52	52			
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	10	10	10			
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	98	100	100			
83	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	38	28	48			
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	28	18	18			
86	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	51	53	50	50			
87	** Import (Tripura)	India		160	160	120	118	128	140			
Cumilla Zone Total				2959	2896	1046	1252	1212	1414	0	434	
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	34	40	40	168	Gas Shortage	
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
90	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	57	79	57	79			
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	37	19	35			
92	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
93	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0			
94	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	155	156	174	160	168	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.12.23 (Yesterday)		25.12.23 (Today)		24.12.23 (Yesterday)		24.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40		GT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90		GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51					
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	163	163	43				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	5					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	61	63	63					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330		Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	30	30	30					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	210	210	210					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	22	24					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0					
100	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	340	400	400					
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100		Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	49	49	45	45					
Sylhet Zone Total					2472	2427	1386	1335	1429	1431	43	560		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0					
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	35	70					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	57	0	100	0					
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16					
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	471	477	510	600					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDCL)	India		1000	1000	853	898	829	878					
Khulna Zone Total					3241	3237	1381	1399	1474	1612	0	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	12	110	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	11	19	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	550	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	72					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	250	160	160					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barisal Zone Total					2265	2265	1190	1206	1269	1324	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	8	50	50	82					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	35	50					
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	40					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210			Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220			Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220			Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	203	192	280	280					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11					
137	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	10	35	35	35					
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	21	28	28					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
**	Adani Power, Jharkhand Ltd	(Import)	2x748	1496	1496	707	760	748	748					
Rajshahi Zone Total					3653	3631	952	1227	1235	1405	721	100		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104			Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	17	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	35	35	35					
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	84	35	70	115					
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0					
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	148	0	130	0					
Rangpur Zone Total					1030	950	471	257	443	320	189	85		
Sub-total: Plants in operation					25726	25211	9141.0	10203	10912	11580	2576	2249		
(B) Plants under long term maintenance/ contract expired														
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
153	Bosila 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
154	Bogra 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0		
Gross Total					25951	25211	9141	10203	10912	11580	2576	2249		
(C) Actual data of 24.12.23 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	10203 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9881 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	10203 MW, at =	18:00 hrs	Dhaka	3813	3813	0	Mymensingh	774	774	0		
04.	Minimum Generation (Generation end)	:	6565 MW, at =	5:00 hrs	Chattogram	1039	1039	0	Sylhet	366	366	0		
05.	Day-peak Generation (Generation end)	:	9141 MW, at =	12:00 hrs	Khulna	1143	1143	0	Barisal	269	269	0		
06.	Evening-peak Generation (Generation end)	:	10203 MW, at =	18:00 hrs	Rajshahi	942	942	0	Rangpur	692	692	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	843	843	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6658 MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:							Total	9881	9881	0		
a)	Gas/LF limitation	:	2387 MW		13.	Fuel cost :	(a) Gas = 102400498 Taka	(c) Coal = 436538176 Taka						
d)	Coal supply Limitation	:	189 MW			(b) Oil = 211567742 Taka		Total = 750506415 Taka						
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :	26.8°C							
c)	Plants under shut down/ maintenance	:	2249 MW		15.	Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	205.32 MKWh			At evening peak-hour	:	9141 MW, at	18:00 hrs					
	By Gas = 92.697 MKWh					Maximum	:	180 MW, at	7:00 hrs					
	By Coal = 71.142 MKWh					Energy	:	0 MKWh						
	By Solar = 1.829 MKWh													
11.	Total Gas Supplied	:	730.03 MMCFD											
(D) Forecast of 25.12.23 (Today) Monday :														