

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2023				Day : Thursday				Date : 28.12.23			
Probable Maximum Demand : 10600 MW				Probable Maximum Generation : 11610 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 94.27 ft	Today = 94.03 ft	Rule Curve = 103.40 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.12.23 (Yesterday)		28.12.23 (Today)		27.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI
5	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	73	70	70	35	Gas Shortage
6	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	30	Gas Shortage
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	414	400	400		
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	41	90	90		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	33	21	33	33		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	17	17		
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	26	28	28		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105		
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	149	48	48		
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	50	80	130		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17		
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17		
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35		
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	14	0	17		
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	0	35		
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	35	0		
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	21	17	17		
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	24	90	90		
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	100	100		
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	8	65	80	80		
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	18	24	40	40		
37	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		
38	Meghnaghat Unique Power	Gas			0	0	0	0	0		
39	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0		
Dhaka Zone Total				5655	5422	1448	1803	1833	2065	1230	740
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86		
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17		
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0		
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20		
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17		
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	160	160	165	165		
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	115	200	260	260		
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12		
52	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	14	51	34	51		
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	43	74	40	74		
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	15	15		
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	3	5	10		
56	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
57	Sikalbaha 54 MW PP(Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	1	14	17	17		
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17		
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12		
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	17	163		
63	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	320	292	420	420		
64	Matlabari 2*600 MW (CPGCL)	Coal				567	566	600	600		Test run
65	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run
Chattogram Zone Total				3829	3769	1453	1741	1795	1995	180	330
66	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	30	40	42	42		
67	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	96	0	0	125	Under Maint.
68	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		
69	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	285	300	310	75	Gas Shortage
70	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	415	290	350	400	110	Gas Shortage
71	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	8	8		
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	8	6	50		
74	Titas 50 MW Peaking PP	HFO (PDB)	6x6.92	52	52	33	32	0	38		
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18		
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10		
79	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	42	52	52		
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	11	12	12		
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.45+1*9.78	114	114	70	52	100	100		
83	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	38	9	48		
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17		
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	3	18	18	18		
86	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	10	10	10	10		
87	** Import (Tripura)	India		160	160	108	110	128	140		
Cumilla Zone Total				2959	2896	1151	1170	1173	1366	185	288
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	27	31	30	35	171	Gas Shortage
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
90	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	56	57	79		
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	38	56	19	35		
92	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
93	Sutlakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	43	0	50	0		
94	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	153	149	164	155	171	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.12.23 (Yesterday)		28.12.23 (Today)		27.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	43	43	43	27	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	41	50	50	50				
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163	0			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	5	5				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	63	63				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	50	50	50				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	202	210	210				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	22	24				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	341	300	341	341				
100	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	350	400				
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	25	25	25				
Sylhet Zone Total						2472	2427	1331	1332	1384	0	547	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0				
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	40				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	72	72				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	58	0	100	0				
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	16				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	16	0	8				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	466	476	470	470				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC) India			1000	1000	862	901	876	924				
Khulna Zone Total						3241	3237	1386	1429	1518	1530	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	20	30	110	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	20	20				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	100	120	120				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	622	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	72				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	220	250	250	250				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1162	1276	1359	1414	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	23	0	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	34	92	50	92				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	34	40				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	38				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	171	132	250	250				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	25	35	0	35				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	10	17	0	35				
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	720	763	748	748				
Rajshahi Zone Total						3653	3631	1002	1187	1142	1382	721	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	27	0	34				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	114	70	115				
148	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	158	0	130	0				
Rangpur Zone Total						1030	950	454	311	408	319	189	85
Sub-total: Plants in operation						25726	25211	9540.0	10396	10724	11610	2676	2090
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bosila 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0
Gross Total						25951	25211	9540	10396	10724	11610	2676	2090
(C) Actual data of 27.12.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10396	MW, at =	18:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10052	MW, at =	18:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	10396	MW, at =	18:00	hrs	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	6680	MW, at =	5:00	hrs	Dhaka	3929	3929	0	Mymensingh	783	783
05.	Day-peak Generation (Generation end)	:	9540	MW, at =	12:00	hrs	Chattogram	1054	1054	0	Sylhet	362	362
06.	Evening-peak Generation (Generation end)	:	10396	MW, at =	18:00	hrs	Khulna	1136	1136	0	Barishal	277	277
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00	hrs	Rajshahi	959	959	0	Rangpur	707	707
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6840	MW, at =	5:00	hrs	Cumilla	845	845	0			
09.	Generation shortfall at evening peak due to :	:					Total						
a) Gas/LF limitation	:	2487	MW				Total = 10052						
d) Coal supply Limitation	:	189	MW				Total = 10052						
b) Low water level in Kaptai lake	:	0	MW				Total = 10052						
c) Plants under shut down/ maintenance	:	2090	MW				Total = 10052						
10.	Total Energy (Generation + India Import)	:	208.63	MKWh			Total = 10052						
	By Gas =	95.289	MKWh	By Oil =	17.379	MKWh	Total = 10052						
	By Coal =	70.740	MKWh	By Hydro =	2.087	MKWh	Total = 10052						
	By Solar =	2.052	MKWh				Total = 10052						
11.	Total Gas Supplied	:	727.68	MMCFD			Total = 10052						
(D) Forecast of 28.12.23 (Today) Thursday :													
01.	Maximum Demand	:	10600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	11610	MW	(Generation end)		05.	Total Generation	:	212.73	MKWh		
03.	Reserve / Shortage	:	1010	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka	:	25.8°C			
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00													
(M. Helalur Rahman) Deputy Secretary, Generation													