

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Sunday				Date : 31.12.23						
Probable Maximum Demand : 10500 MW				Probable Maximum Generation : 11775 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 93.74 ft Today = 93.50 ft				Rule Curve = 103.10 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.12.23 (Yesterday)		31.12.23 (Today)		30.12.23 (Yesterday)		31.12.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for H/GPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	64	65	70	70	44		Gas Shortage		
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0			Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	0		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	376	402	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	2	25	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.7+7x8.73	80	80	22	33	37	37					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	24	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	2	17	8	16					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	35	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	1	17	17	17					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	0	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	92	92					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	14	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	39	39					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	60	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total				5655	5422	1183	1644	1793	2173	1209	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	20	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	182	192	182	192					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	10	150	200	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	48	17	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	72	0	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	13	15	15					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	4	25	25					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	22	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	54	17	54					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	301	292	290	290					
	Metarbari 2*600 MW (CPGCL)	Coal				610	647	700	700			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run		
Chattogram Zone Total				3829	3769	1349	1661	1719	1934	180	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	45	48	48					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0					
62	Ashuganj 450 MW CCPP(East)	Gas (APSCCL)	1x361	360	360	310	310	310	310	50		Gas Shortage		
63	Ashuganj 420 MW CCPP(North)	Gas (APSCCL)	1x284+1x116	400	400	270	393	380	400	7		Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	45	8	45					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	55	6	50					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	38					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	50	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	6	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.45+1*9.78	114	114	45	80	100	100					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	48	9	48					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	2	18	18	18					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	27	25	25	25					
**	Import (Tripura)	India		160	160	102	92	128	140					
Cumilla Zone Total				2959	2896	947	1306	1234	1424	57	384			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	71	30	35	131		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	80	57	79					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	37	19	35					
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	3	6	6					
Mymensingh Zone Total				622	614	200	191	164	155	131	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.12.23 (Yesterday)		31.12.23 (Today)		30.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
												Day	Evening	Day
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	29	8	42	42		62	GT-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	50	50					
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163	0				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	8	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	64	63	63					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	207	210	210					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	22	24					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	330	330					
100	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	353	402	400	400					
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	25	25	25					
Sylhet Zone Total						2472	2427	1234	1317	1373	1378	0	582	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0					
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	72	72					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	16					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	626	625	550	600					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDCL)	India		1000	1000	816	788	833	930					
Khulna Zone Total						3241	3237	1515	1430	1555	1666	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	55	55	120	120					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	530	610	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	5	35	17	72					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	240	250	250	250					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total						2265	2265	1065	1189	1359	1414	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	92					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40					
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	40					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	249	204	235	235					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11					
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	0					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	0					
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	767	762	748	748					
Raishahi Zone Total						3653	3631	1040	1194	1127	1297	721	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage			
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage			
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	2	49	6	49					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	18	111	70	115					
149	Lalmohorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	164	0	130	0					
Rangpur Zone Total						1030	950	390	330	414	334	189	85	
Sub-total: Plants in operation						25726	25211	8923.0	10262	10738	11775	2487	2221	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosilia 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0	
Gross Total						25951	25211	8923	10262	10738	11775	2487	2221	
(C) Actual data of 30.12.23 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	10262	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9784	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10262	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6281	MW, at =	5:00 hrs	Dhaka	3781	3781	0	Mymensingh	770	770	0	
05.	Day-peak Generation (Generation end)	:	8923	MW, at =	12:00 hrs	Chattogram	1015	1015	0	Sylhet	378	378	0	
06.	Evening-peak Generation (Generation end)	:	10262	MW, at =	19:00 hrs	Khulna	1129	1129	0	Barisal	283	283	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	933	933	0	Rangpur	659	659	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6752	MW, at =	5:00 hrs	Cumilla	837	837	0					
09.	Generation shortfall at evening peak due to :	:				Total						9784	9784	0
a)	Gas/LF limitation	:	2298	MW		(a) Gas = 97276303 Taka						(c) Coal = 457312115 Taka		
d)	Coal supply Limitation	:	189	MW		(b) Oil = 166439372 Taka						Total = 721027789 Taka		
b)	Low water level in Kaptai lake	:	0	MW		Maximum Temperature in Dhaka was :						28.1°C		
c)	Plants under shut down/ maintenance	:	2221	MW		Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	201.70	MKWh		At evening peak-hour : 8923 MW, at 19:00 hrs								
	By Gas = 94.789 MKWh			By Oil = 12.350 MKWh		Maximum : 204 MW, at 7:00 hrs								
	By Coal = 71.529 MKWh			By Hydro = 2.071 MKWh		Energy : 0.099 MKWh								
	By Solar= 2.325 MKWh													
11.	Total Gas Supplied	:	714.54	MMCFD										
(D) Forecast of 31.12.23 (Today) Sunday :														
01.	Maximum Demand	:	10500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11775	MW	(Generation end)	05.	Total Generation	:	206.38	MKWh				
03.	Reserve / Shortage	:	1275	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation