

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date :                          |                                         | 1-Jan-24       |                     | Page - 2         |                      |                  |                        |
|---------------------------------|-----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|------------------------|
| Sl. No.                         | Name of the Power Stations              | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Enerov Generated | Remarks                |
|                                 |                                         |                | Unit No. X Capacity | MW               | MW                   | KWH              |                        |
| 1                               | Ghorasal Repowered CCPP-Unit-3 (GT      | PDB            | 1*260               | 260              | 0                    | 0                | Under maint.           |
| 2                               | Ghorasal Repowered CCPP Unit-4          | PDB            | 1*210               | 180              | 0                    | 0                | Under maint.           |
| 3                               | Ghorasal TPP Unit-5                     | PDB            | 1*210               | 190              | 180                  | 4221000          |                        |
| 4                               | Ghorasal 365 MW CCPP Unit-7             | PDB            | 1*243+1*122         | 365              | 0                    | 0                | Air Compressor problem |
| 5                               | Ghorasal 78.5 MW PP (PMAx)              | QRPP           | 2*40                | 0                | 0                    | 0                | Contract Expired       |
| 4                               | Ghorashal 108 MW MP (Regent)            | IPP            | 3*43.35             | 108              | 65                   | 1205409          | Gas shortage           |
| 5                               | Haripur GTPP                            | SBU, PDB       | 2*32                | 20               | 0                    | 0                | Under maint.           |
| 6                               | Haripur 412 MW CCPP                     | EGCB           | 1*273+1*139         | 412              | 380                  | 8956800          | Gas shortage           |
| 7                               | Haripur 360 MW CCPP(HPL)                | IPP            | 1*235+1*125         | 360              | 0                    | 0                | Contract Expired       |
| 8                               | Meghnaghat 450 MW CCPP(MPL)             | IPP            | 2*150+1*150         | 450              | 450                  | 8959800          | Gas shortage           |
| 9                               | Meghnaghat 100 MW(EEL)                  | NENP           | 12*8.9              | 100              | 19                   | 35424            | Low demand             |
| 10                              | Meghnaghat CCPP(Summit)                 | IPP            | 2*110+1*110         | 335              | 0                    | 0                | Gas shortage           |
| 11                              | Madanganj 102 PP(Summit)                | NENP           | 6*17                | 102              | 64                   | 197150           | Low demand             |
| 12                              | Madanganj-55 MW PP(Summit)              | IPP            | 3*17.08+1*11.3      | 55               | 30                   | 196943           | Engine problem         |
| 13                              | Keraniganj 100 MW PP (Powerpac)         | NENP           | 8*13.45             | 75               | 37                   | 101083           | Fuel shortage          |
| 14                              | Narshingdi 22 MW PP (Doreen)            | SIPP, REB      | 8*2.90              | 22               | 0                    | 0                | Contract Expired       |
| 15                              | 210 MW Siddhirgonj TPP                  | PDB            | 1*210               | 115              | 0                    | 0                | Under maint.           |
| 16                              | Siddhirgonj 2*120 MW GTTP               | EGCB           | 2*105               | 210              | 0                    | 0                | Gas shortage           |
| 17                              | Siddhirgonj 100 PP(Dutch Bangla)        | NENP           | 12*8.9              | 100              | 73                   | 196800           | Low demand             |
| 18                              | Siddhirgonj 335 MW CCPP                 | EGCB           | 1*217+118           | 335              | 0                    | 0                | Gas shortage           |
| 19                              | Gagnagar 102 MW PP (Digital Power)      | IPP            | 12*8.924            | 102              | 66                   | 193968           | Low demand             |
| 20                              | Kalpottti 52 MW PP (Siraha)             | IPP            | 7*7.9               | 0                | 0                    | 0                | Fuel shortage          |
| 21                              | Kamalaghat 54 MW PP(Banco Energy)       | IPP            | 3*18                | 54               | 0                    | 45900            | Fuel shortage          |
| 22                              | Kodda 150 MW PP                         | BPDB-RPCL      | 9*17.06             | 149              | 98                   | 603840           | Fuel shortage          |
| 23                              | Manikganj 55 MW PP (Northern)           | IPP            | 3*19.3              | 55               | 35                   | 70067            | Fuel shortage          |
| 24                              | Nababganj 55 MW PP (Southern power)     | IPP            | 3*19.3              | 55               | 17                   | 67401            | Fuel shortage          |
| 25                              | Bosila 108 MW PP(CLC)                   | IPP            | 12*8.775+1*3.5      | 0                | 0                    | 0                |                        |
| 26                              | Summit Power, (Machhabdi+Ashulia)       | SIPP, REB      | 3*3.67+4*8.73       | 80               | 40                   | 949680           | Engine problem         |
| 27                              | Maona 33 MW PP(Summit)                  | SIPP, REB      | 4*8.73              | 33               | 25                   | 515200           |                        |
| 28                              | Rugganj 33 MW PP(Summit)                | SIPP, REB      | 4*8.73              | 33               | 20                   | 502700           | Engine problem         |
| 29                              | Gaspur 52 MW PP                         | RPCL           | 8*6.9               | 52               | 17                   | 185419           | Fuel shortage          |
| 30                              | Tongi 80 MW GTTP                        | PDB            | 1*105               | 105              | 0                    | 0                | Gas shortage           |
| 31                              | Kodda 300 MW PP Unit-2 (Summit)         | IPP            | 18*17.076           | 300              | 60                   | 291055           | Low demand             |
| 33                              | Bramhangaoan 100 MW PP (Aggreko)        | IPP            | 11*10.959           | 0                | 0                    | 0                | Contract Expired       |
| 34                              | Aurahat 100MW PP (Aggreko)              | IPP            | 0.85*23+0.95*91     | 0                | 0                    | 0                | Contract Expired       |
| 35                              | Kodda 149 MW PP Unit-1 (Summit)         | IPP            | 8*18.45+5*97        | 149              | 0                    | 0                | Fuel shortage          |
| 36                              | Gazipur 100 MW PP                       | RPCL           | 6*17.5              | 105              | 105                  | 645878           |                        |
| 37                              | Meghnaghat 104 MW PP (OPCL)             | IPP            | 18.5*6              | 104              | 17                   | 33600            | Fuel shortage          |
| 38                              | Manikgonj 162MW PP(MPGL)                | IPP            | 9*18                | 162              | 0                    | 61920            | Fuel shortage          |
| 39                              | Spectra Solar Plant Ltd.                | IPP            | 35                  | 35               | 0                    | 119630           |                        |
| 40                              | Kanchan Purbastha Power Generation Ltd. | IPP            | 18*4.3              | 55               | 17                   | 137520           | Fuel shortage          |
| Meghnaghat Unique power         |                                         |                | 589                 | 0                | 81                   | 1313636          | On test.               |
| Summit Meghanghat-2 589 MW(Gas) |                                         |                | 589                 | 0                | 0                    | 0                | On test.               |
| Dhaka area Total                |                                         |                |                     | 5422             | 1886                 | 29807823         |                        |
| 41                              | Chattogram TPP-1                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage           |
| 42                              | Chattogram TPP-2                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage           |
| 43                              | Razcar 25 MW PP                         | RPCL           | 3*8.9               | 25               | 17                   | 169759           | Fuel shortage          |
| 44                              | Teknaf 20MW PP (Solartech)              | IPP            | .20                 | 0                | 0                    | 133785           |                        |
| 45                              | Patenga 50MW PP (Baraka)                | IPP            | 8*6.98              | 50               | 20                   | 174240           | Fuel shortage          |
| 46                              | Kapla Hydro: Unit-1,2,3,4, 5            | PDB            | 2*40+3*50           | 230              | 86                   | 2055520          | Unit-3 under maint.    |
| 47                              | Sikalbaha 225MW                         | PDB            | 1*150+1*75          | 225              | 193                  | 4143462          | Gas shortage           |
| 48                              | Sikalbaha Peaking GT                    | PDB            | 1*150               | 0                | 0                    | 0                | Fuel shortage          |
| 49                              | Sikalbaha 105 MW PP (Baraka Sikalbaha)  | IPP            | 6*17.5              | 105              | 17                   | 225818           | Fuel shortage          |
| 49                              | Hathazari 100 MW peaking PP             | PDB            | 11*8.9              | 98               | 66                   | 702624           | Engine problem         |
| 50                              | Dohazari -Kalaish 100 MW Peaking        | PDB            | 6*17                | 102              | 34                   | 377080           | Low demand             |
| 51                              | Juldah 100 MW Unit-1 (Acom)             | NENP           | 8*13.45             | 100              | 25                   | 67440            | Fuel shortage          |
| 52                              | Julidah 100 MW PP Unit-3 (Acom)         | IPP            | 8*13.5              | 100              | 12                   | 159380           | Fuel shortage          |
| 53                              | Barabkunda 22 MW PP (Regent)            | SIPP, PDB      | 8*2.90              | 22               | 14                   | 316416           | Engine problem         |
| *                               | Malancha, Ctg. EPZ (United)             |                | 5*8.73+3*9.34       | 0                | 2                    | 234720           |                        |
| 54                              | Chattogram 108 MW PP (ECPV)             | IPP            | 16*7                | 108              | 0                    | 0                | Fuel shortage          |
| 55                              | Kapla 7 MW Solar PP                     | PDB            | 7.4 MW              | 7                | 0                    | 24359            |                        |
| 56                              | Anwara 300 MW PP (United)               | IPP            | 17*17+24            | 300              | 170                  | 963240           | Low demand             |
| 57                              | Jodisc Power                            | IPP            | 3*18.55+1*3.6       | 54               | 0                    | 0                | Fuel shortage          |
| 58                              | Karnaphuli Power Ltd.                   | IPP            | 18.415*6+8.5        | 110              | 17                   | 297744           | Fuel shortage          |
| 59                              | Juldah unit-2 (Acom)                    | IPP            | 8*13.6              | 100              | 12                   | 161280           | Fuel shortage          |
| 60                              | Anlima Energy Ltd.                      | IPP            | 6*21.2              | 116              | 17                   | 288545           | Fuel shortage          |
| Minshara 150 MW                 |                                         |                | BPDB-RPCL           | 18.5*9           | 163                  | 54               | 286036                 |
| SS Power                        |                                         |                | SS Power            | 2*612            | 1224                 | 270              | 6779999                |
| Cox's Bazar Wind                |                                         |                | CPCL                | 68               | 0                    | 0                | 30720                  |
| Matarbari 2*600 MW (CPGCL)      |                                         |                | CPGCL               | 0                | 0                    | 697              | 15309090               |
| Minshara 150 MW (Gas)           |                                         |                | BPDB-RPCL           | 18.5*9           | 0                    | 0                | On test.               |
| Chattogram area Total           |                                         |                |                     | 3769             | 1723                 | 32901237         |                        |
| 61                              | Ashuganj TPP Unit-3                     | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 62                              | Ashuganj TPP Unit-4                     | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 63                              | Ashuganj TPP Unit-5                     | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 64                              | Ashuganj 225 MW CCPP                    | APSCL          | 1*142+1*75          | 221              | 98                   | 1759000          | GT was sync. at 16:04  |
| 65                              | Ashuganj 450 MW CCPP(North)             | APSCL          | 1*360               | 360              | 0                    | 5306300          | FGMO                   |
| 66                              | Ashuganj 450 MW CCPP(South)             | APSCL          | 1*360               | 360              | 0                    | 0                | Gas shortage           |
| 67                              | Ashuganj 450 MW CCPP(East)              | APSCL          | 284*116+1           | 400              | 0                    | 4430000          | tripped at             |
| 68                              | Ashuganj 50 MW PP                       | APSCL          | 14*3.968            | 45               | 15                   | 691560           | Gas shortage           |
| 69                              | Ashuganj 55 MW PP (Precision)           | QRPP           | 0                   | 0                | 0                    | 441600           | Gas shortage           |
| 67                              | Ashuganj 195 MW PP (APSCL-United)       | IPP            | 20*9.73+1*16        | 195              | 16                   | 501818           | Gas shortage           |
| 68                              | Ashuganj 51 MW PP (Midland)             | IPP            | 6*9.34              | 51               | 51                   | 750052           | Engine problem         |
| 69                              | Ashuganj 150 MW PP (Midland)            | IPP            | 27*0.015            | 150              | 110                  | 682473           | Fuel shortage          |
| 70                              | Titas 50 MW Peaking PP                  | PDB            | 6*8.92              | 52               | 31                   | 276224           |                        |
| 71                              | Chandpur 150 MW CCPP                    | PDB            | 1*106+1*57          | 163              | 0                    | 0                | Under maint.           |
| 72                              | Chandpur 200 MW (Desh energy)           | IPP            | 12*18.4             | 200              | 17                   | 284160           | Fuel shortage          |
| 73                              | Feni 22 MW PP (Doreen)                  | SIPP, PDB      | 8*2.90              | 22               | 18                   | 440115           | Engine problem         |
| 74                              | Feni 11 MW PP (Doreen)                  | SIPP, REB      | 4*2.90              | 11               | 11                   | 148320           |                        |
| **                              | Jangalia 33 MW PP (Summit)              | Imported power | 0                   | 160              | 102                  | 2283840          |                        |
| 77                              | Jangalia 52 MW PP (Lakdanavi)           | SIPP, PDB      | 4*8.73              | 33               | 33                   | 623200           |                        |
| 77                              | Jangalia 52 MW PP (Lakdanavi)           | IPP            | 6*8.92              | 52               | 50                   | 372014           |                        |
| 76                              | Cumilla 25 MW PP (Summit)               | SIPP, REB      | 3*3.67+2*6.97       | 25               | 17                   | 271740           | Engine problem         |
| 77                              | Daukheri 200 MW PP (B.Trac)             | IPP            | 15*14.4             | 0                | 0                    | 0                | Contract Expired       |
| 79                              | Feni Lanka Power                        | IPP            | 7*18.415+1*9.78     | 114              | 114                  | 737580           |                        |
| 80                              | Chowmuhani 113 MW                       | IPP            | 12*9.78+2*3.1       | 113              | 48                   | 380520           | Fuel shortage          |
| 81                              | Bhairab 54.5 MW                         | IPP            | 3*18.2              | 54               | 17                   | 220680           | Engine problem         |
| 82                              | Chandpur 115(Doreen)                    | IPP            | 4*18.5+2*22.5       | 115              | 20                   | 192000           | Fuel shortage          |
| Cumilla Area Total              |                                         |                | 2896                | 768              | 20753196             |                  |                        |
| 83                              | RPCL 210MW CCPP                         | IPP            | 4*35+1*70           | 202              | 35                   | 1341120          | Gas shortage           |
| 84                              | Tangail 22 MW PP (Doreen)               | SIPP, PDB      | 8*2.90              | 22               | 0                    | 0                | Contract Expired       |
| 85                              | Jamalpur 95 MW PP(Powerpac)             | IPP            | 0                   | 0                | 0                    | 0                | Under maint.           |
| 86                              | Sarishabari 3 MW Solar Plant            | IPP            | 1*3                 | 3                | 0                    | 3800             |                        |
| 87                              | Mymensingh 200 MW PP (United)           | IPP            | 9*78.21             | 200              | 28                   | 225600           | Fuel shortage          |
| 88                              | Jamalpur 115 MW PP (United)             | IPP            | 9*78.12             | 115              | 79                   | 1035600          | Fuel shortage          |
| 89                              | Sutakhalai 50 MW Solar PP               | IPP            | 50                  | 50               | 0                    | 147970           |                        |
| 90                              | Tangail Pali Power Gen 22 MW            | IPP            | 4*6.7               | 22               | 6                    | 90480            | Fuel shortage          |
| Mymensingh Area Total           |                                         |                | 614                 | 148              | 2844570              |                  |                        |
| 91                              | Fenchugonj CCPP Phase-1                 | PDB            | 2*32+1*33           | 70               | 43                   | 1013000          | Machine problem        |
| 92                              | Fenchugonj CCPP Phase-2                 | PDB            | 2*35+1*35           | 90               | 0                    | 0                | Machine problem        |
| 93                              | Kushiana 163 MW CCPP (KP)               | IPP            | 1*109+1*54          | 163              | 163                  | 3633790          |                        |
| 94                              | Shajibazar 330 MW CCPP                  | PDB            | 3*110               | 330              | 0                    | 0                | Under maint.           |
| 95                              | Fenchugonj 51 MW PP (Barakatullah)      | RPP            | 19*2.90             | 51               | 53                   | 985800           |                        |
| 96                              | Fenchuganj 44 MW (Energyprima)          | NENP           | 12*3.3+5*2          | 50               | 25                   | 516816           | Gas shortage           |
| 97                              | Hobiganj 1.1 MW PP (Confidence-E        | SIPP, REB      | 4*2.90              | 11               | 11                   | 190944           | Engine problem         |
| 97                              | Shajibazar GTTP Unit- 8 & 9             | PDB            | 2*35                | 66               | 62                   | 1256544          |                        |
| 98                              | Shajibazar 86 MW PP (Shajibazar)        | RPP            | 32*2.90             | 86               | 50                   | 997440           | Gas shortage           |
| 99                              | Shajibazar 100 MW GTTP                  | PDB            | 1*100               | 100              | 0                    | 0                | Under maint.           |
| 100                             | Sylhet 225 MW CCPP                      | PDB            | 1*142+1*89          | 231              | 203                  | 517760           |                        |
| 101                             | Sylhet 20 MW GTTP-1                     | PDB            | 1*20                | 0                | 0                    | 0                | Gas shortage           |
| 102                             | Sylhet 50 MW PP (EPL)                   | NENP           | 27*2                | 0                | 0                    | 0                | Contract Expired       |
| 103                             | Shahjahanulla 25 MW PP                  | SIPP, REB      | 3*9.34              | 25               | 0                    | 349440           |                        |
| 104                             | Bibiana-II 341 MW CCPP (Summit)         | IPP            | 1*222+1*119         | 341              | 300                  | 7338000          | FGMO                   |
| 105                             | Bibiyana-III 400 MW CCPP                | PDB            | 285*11+134*1        | 400              | 413                  | 8936000          |                        |
| 106                             | Sylhet 10MW PP (Desh)                   | RPP            | 8*1.95              | 10               | 10                   | 198900           |                        |
| 106                             | Bibiyana South 400 MW                   | PDB            | 400 MW              | 383              | 0                    | 0                | Under maint.           |
| Sylhet Area Total               |                                         |                | 2427                | 1333             | 25934434             |                  |                        |
| 107                             | Bheramara GTTP Unit-3                   | PDB            | 1*20                | 16               | 0                    | 0                | Reserve                |
| **                              | Bheramara (HVDC )                       | Imported power | 2*500               | 1000             | 543                  | 14968727         |                        |
| 108                             | Khulina 115 PP MW (KPCL-2)              | NENP           | 7*17                | 115              | 32                   | 88320            | Fuel shortage          |
| 109                             | Fairipur 50 MW Peaking PP               | PDB            | 8*6.98              | 50               | 18                   | 72000            | Low demand             |
| 110                             | Khulina 225 MW CCPP                     | NWPGCL         | 1*150+1*75          | 230              | 0                    | 0                | Fuel shortage          |
| 111                             | Gopalganj 100 MW Peaking PP             | PDB            | 16*6.98             | 109              | 0                    | 0                | Machine problem        |
| 112                             | Bheramara 410 MW CCPP                   | NWPGCL         | 1*278+1*132         | 410              | 0                    | 0                | Gas shortage           |
| 113                             | Noapara 40 MW PP (Kharajahan Ali)       | NENP           | 5*8.5               | 40               | 16                   | 78750            | Fuel shortage          |
| 114                             | Noapara 100 MW PP (Bangla Trac)         | IPP            | 70*1.4              | 0                | 0                    | 0                | Contract Expired       |
| 114                             | Rupsha 105 MW PP (Orion rupsha)         | IPP            | 6*18.445            | 105              | 28                   | 230352           | Low demand             |
| 115                             | Madhum                                  |                |                     |                  |                      |                  |                        |