

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month January, 2024					Day : Thursday				Date : 04.01.24				
Probable Maximum Demand : 10200 MW					Probable Maximum Generation : 11819 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 93.02 ft	Today = 92.77 ft			Rule Curve = 102.43 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.01.24 (Yesterday)		04.01.24 (Today)		03.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	70	70	70	38	Gas Shortage		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	357	378	380	400				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	68	74	90	90				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	40	40	40				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	18	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	92	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	82	16	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	35	80	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	17	17				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	0	17				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	0	17	35				
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	7	100	100				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	35	68	68				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	20	35	40				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			400	257	620	620					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0					
Dhaka Zone Total				5655	5422	1592	1889	2313	2636	1203	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	6	19	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Gas Shortage		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	45	130	150	200				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	60	32	60				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	17	17				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	5				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	25	12	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	17	17	54				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	270	270	270	270	954	Coal Shortage		
	Matarbari 2*600 MW (CPGCL)	Coal				647	648	700	700		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run		
Chattogram Zone Total				3829	3769	1255	1431	1476	1607	1359	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	45	45	45				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	96	96	96	96	125	Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	220	260	260	140	Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	330	330	360	Gas Shortage		
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400	Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	185	110	0	0				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	36	43	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	52	13	60				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	32	0	30				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	11				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	21	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	17	11	11				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	88	100	100				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	54	9	58				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	4	18	17	17				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	25	15	0	0				
**	Import (Tripura)	India		160	160	102	103	128	140				
Cumilla Zone Total				2959	2896	883	1019	1199	1338	900	288		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	32	40	40	170	Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	57	79				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	28	19	37				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	10	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	117	145	174	162	170	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.01.24 (Yesterday)		04.01.24 (Today)		03.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)	Machines shut down (MW)		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		GT-1 Under maint.	
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	53	50	50			
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	11			
92	Shahjibazar GTTP Unit: 8 & 9	Gas (PDB)	2x35	70	66	40	61	63	63			
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	203	210	210			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	22	17	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	310	300	300			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	413	398	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0	383	Under maint.	
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	0	25	25	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1251	1307	1338	1347	67	930
104	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	80	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	24	0	16			
113	Nosapara 40 MW PP (Khejhanj Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	778	727	700	700			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDF)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDc)	India		1000	1000	863	910	873	921			
Khulna Zone Total					3241	3237	1721	1681	1778	1790	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	20	20			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	55	55	55	55			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	520	622	622			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	72			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	294	250	250			
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barisal Zone Total					2265	2265	1040	1177	1200	1255	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	21	0	33			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	92	50	91			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	50			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	254	191	200	200	223	Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	52			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	30	0	35			
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
**	Adani Power, Jharkhand Ltd	(Import)	2x748	1496	1496	761	727	748	748			
Rajshahi Zone Total					3653	3631	1079	1221	1100	1390	944	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	42	6	49			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	49	70	75			
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	30	0	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	138	0	130	0			
Rangpur Zone Total					1030	950	349	261	414	294	189	85
Sub-total: Plants in operation					25726	25211	9287.0	10131	10992	11819	5242	2473
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0	85	Coal Shortage	
153	Bosila 108MW PP(C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bosila 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	9287	10131	10992	11819	5242	2473
(C) Actual data of 03.01.24 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	10131 MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9816 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10131 MW, at =	18:00 hrs	Dhaka	3739	3739	0	Mymensingh	800	800	0
04.	Minimum Generation (Generation end)	:	6464 MW, at =	5:00 hrs	Chattogram	1066	1066	0	Sylhet	369	369	0
05.	Day-peak Generation (Generation end)	:	9287 MW, at =	12:00 hrs	Khulna	1141	1141	0	Barisal	272	272	0
06.	Evening-peak Generation (Generation end)	:	10131 MW, at =	18:00 hrs	Rajshahi	945	945	0	Rangpur	671	671	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	813	813	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6481 MW, at =	5:00 hrs					Total	9816	9816	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 91137222 Taka	(c) Coal = 492187206 Taka				
a) Gas/LF limitation	:	5053 MW				(b) Oil = 184247137 Taka		Total = 767571565 Taka				
d) Coal supply Limitation	:	189 MW			14.	Maximum Temperature in Dhaka was :	22.2°C					
b) Low water level in Kaptai lake	:	0 MW			15.	Export through East-West interconnections :						
c) Plants under shut down/ maintenance	:	2473 MW				At evening peak-hour	9287 MW, at	18:00 hrs				
10.	Total Energy (Generation + India Import)	:	205.71 MKWh			Maximum	292 MW, at	18:30 hrs				
	By Gas = 90.371 MKWh	By Oil = 13.615 MKWh				Energy	0.0165 MKWh					
	By Coal = 76.855 MKWh	By Hydro = 2.072 MKWh										
	By Solar = 1.601 MKWh											
11.	Total Gas Supplied	:	719.82 MMCFD									
(D) Forecast of 04.01.24 (Today) Thursday :												
01.	Maximum Demand	:	10200 MW (Generation end)	04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	11819 MW (Generation end)	05.	Total Generation	:	207.11 MKWh					
03.	Reserve / Shortage	:	1619 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	23.5°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation