

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month January, 2024				Day : Saturday				Date : 06.01.24						
Probable Maximum Demand : 9700 MW				Probable Maximum Generation : 11656 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.59 ft Today = 92.37 ft				Rule Curve = 102.24 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.01.24 (Yesterday)		06.01.24 (Today)		05.01.24 (Yesterday)		06.01.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for H/GPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	73	70	70	35			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	402	380	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	91	0	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	18	40	40	40					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	17	17					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	21	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	17	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	149	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	0					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	2	0	17	17					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	10	0	0	17					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	0	0					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	57	0	100	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	40	0	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	35	40					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			304	300	300	300	300					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total				5655	5422	1742	1590	2126	2350	1200	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	6	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	126	25	200	99			Gas Shortage	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	87	0	150	200					
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	58	32	74					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	18	18	18					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	17	20	30					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	33	0	33					
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	12	0	12	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	17	17	17					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	270	280	280	280	944			Coal Shortage	
	Metarbari 2*600 MW (CPGCL)	Coal				314	313	312	312				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				2	14	10	10				Test run	
Chattogram Zone Total				3829	3769	930	1094	1144	1465	1223	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	38	38					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	50	96	96	100		125		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	200	180	280	280	180			Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	360	360	360	0			Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400			Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0					
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	43	43	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	72	13	60					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	33	0	33					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	14	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	10	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	10	24	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	10	11	11					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	17	100	100					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	48	9	58					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	17	17					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
**	Import (Tripura)	India		160	160	112	90	128	140					
Cumilla Zone Total				2959	2896	968	1070	1242	1387	580	288			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	59	50	60	143			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	50	75	57	75					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	28	19	30					
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0					
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total				6										

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.01.24 (Yesterday)		06.01.24 (Today)		05.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	50						
90	Kushlira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	8	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	63	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	209	210	210						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	305	300	300						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	323	400	300	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	0	0	0	0	50		Gas Shortage			
Sylhet Zone Total						2472	2427	1228	1213	1316	59	930			
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	105	105						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	32						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	637	332	700	750						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDc)	India		1000	1000	717	704	824	920						
Khulna Zone Total						3241	3237	1428	1053	1729	1855	410	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	16						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	18	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	120	120	120						
119	Payra 1320 MW TPP	Coal (BOPCL)	2x622	1244	1244	260	622	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	72						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	281	250	250						
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220						
Barishal Zone Total						2265	2265	761	1315	1265	1320	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	38	50	50	90						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	0	50						
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	0	42	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	331	298	350	350	116		Gas Shortage			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	35						
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	35	35						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	764	754	748	750						
Raishahi Zone Total						3653	3631	1158	1278	1250	1498	837	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	34	6	49						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	70	75						
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	151	0	130	0						
Rangpur Zone Total						1030	950	362	278	414	294	189	85		
Sub-total: Plants in operation						25726	25211	8731.0	9168	10567	11656	4641	2473		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	8731	9168	10567	11656	4641	2473		
(C) Actual data of 05.01.24 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	9168	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8721	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	9230	MW,	at =	13:00	hrs	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	6576	MW,	at =	5:00	hrs	Dhaka	3015	3015	0	Mymensingh	779		
05.	Day-peak Generation (Generation end)	:	8731	MW,	at =	12:00	hrs	Chattogram	938	938	0	Sylhet	344		
06.	Evening-peak Generation (Generation end)	:	9168	MW,	at =	19:30	hrs	Khulna	1073	1073	0	Barishal	274		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Rajshahi	898	898	0	Rangpur	616		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6149	MW,	at =	5:00	hrs	Cumilla	785	785	0		0		
09.	Generation shortfall at evening peak due to :	:						Total		8721	8721		0		
a)	Gas/LF limitation	:	4452	MW				(a) Gas = 100553138 Taka		(c) Coal = 411574103 Taka					
d)	Coal supply Limitation	:	189	MW				(b) Oil = 152749904 Taka		Total = 664877145 Taka					
b)	Low water level in Kaptai lake	:	0	MW				14. Maximum Temperature in Dhaka was : 22.6°C							
c)	Plants under shut down/ maintenance	:	2473	MW				15. Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	191.26	MKWh				At evening peak-hour		8731	MW,	at 19:30	hrs		
	By Gas = 97.294 MKWh			By Oil = 11.719 MKWh				Maximum		134	MW,	at 7:00	hrs		
	By Coal = 61.808 MKWh			By Hydro = 2.067 MKWh				Energy		0	MKWh				
	By Solar = 2.130 MKWh														
11.	Total Gas Supplied	:	758.74	MMCFD											
(D) Forecast of 06.01.24 (Today) Saturday :															
01.	Maximum Demand	:	9700	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11656	MW	(Generation end)			05.	Total Generation	:	201.00	MKWh			
03.	Reserve / Shortage	:	1956	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	22.6°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation