

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		7-Jan-24						Page - 2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks		
			Unit No. X Capacity	MW	MW	KWH			
1	Ghorasol Repowered CCPP-Unit-3 (GT	PDB	1*260	260	0	0	Under maint.		
2	Ghorasol Repowered CCPP Unit-4	PDB	1*210	180	0	0	Under maint.		
3	Ghorasol TPP Unit-5	PDB	1*210	190	180	4205250			
3	Ghorasol 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Air Compressor problem		
4	Ghorasol 78.5 MW PP(MAAX)	QRPP	2*40	0	0	0	Contract Expired		
4	Ghorasol 108 MW PP (Regent)	IPP	3*43.35	108	73	366954	Engine problem		
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.		
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	303	7696800	Frequency Control		
7	Haripur 360 MW CCPP(HPL)	IPP	1*235+1*125	360	0	0	Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	330	8049000	Frequency Control		
9	Meghnaghat 100 MW(EI/EL)	NENP	12*8.9	100	0	0	Reserve		
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0			
11	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Reserve		
12	Madanganj-55 MW PPI(Summit)	IPP	3*17.08+1*11.3	55	0	0	Reserve		
13	Keraniganj 100 MW PP (Powerpac)	NENP	8*13.45	75	0	0	Reserve		
14	Narasingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	0	Contract Expired		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.		
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0			
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	0	0	132 kV line under maint.		
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	0	0			
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Reserve		
20	Kalpottti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage		
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	0	0	Reserve		
22	Kodda 150 MW PP	BPDB-RPCL	9*17.06	149	0	0	Reserve		
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	0	Reserve		
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	0	0	Reserve		
25	Bosila 108 MW PPI(CLC)	IPP	12*8.775+1*3.5	0	0	0			
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	40	893160	Engine problem		
27	Maona 33 MW PPI(Summit)	SIPP, REB	4*8.73	33	8	341300			
28	Rupganj 33 MW PPI(Summit)	SIPP, REB	4*8.73	33	16	451600			
29	Gasipur 52 MW PP	RPCL	8*6.9	52	0	0	Reserve		
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage		
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	0	0	Reserve		
33	Bramhangon 100 MW PP (Aggreko)	IPP	11*10.959	0	0	0	Contract Expired		
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	0	0	0	Contract Expired		
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.453+97	149	0	0	Reserve		
36	Gasipur 100 MW PP	RPCL	6*17.5	105	0	0	Reserve		
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	0	0	Reserve		
38	Manikgonj 162MW PPI(MPGL)	IPP	9*18	162	0	0	Reserve		
39	Spectra Solar Plant Ltd.	IPP	35	35	0	154666			
40	Kanchan Purbasol Power Generation Ltd.	IPP	18.4*3	55	0	0	Fuel shortage		
	Meghnaghat Unique power	IPP	589	0	239	5639090	On test.		
	Summit Meghanghat-2 589 MW(Gas)	IPP	589	0	0	0	On test.		
Dhaka area Total				5422	1189	27797820			
41	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage		
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage		
42	Razzan 25 MW PP	RPCL	3*9.9	25	0	0	Fuel shortage		
43	Teknaf 20MW PP (Solartech)	IPP	.20	20	0	123795			
44	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	0	Reserve		
45	Kapila Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	76	1532020	Unit-3 under maint.		
46	Sikalbaha 225MW	PDB	1*150+1*75	225	126	2386530	ST Under maint.		
47	Sikalbaha Peaking GT	PDB	1*150	0	0	0	Under maint.		
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	0	0	Reserve		
49	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Reserve		
50	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	0	0	Reserve		
51	Juidah 100 MW Unit-1 (Acom)	NENP	8*13.45	100	0	0	Reserve		
52	Juidah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	0	0	Reserve		
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	18	296088	Engine problem		
*	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	42	756960			
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Reserve		
55	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	24359			
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	0	0	Reserve		
57	Jodis Power	IPP	3*18.55+1*3.6	54	0	0	Reserve		
58	Karnaphuli Power Ltd.	IPP	18.415*6+8.5	110	0	0	Reserve		
59	Juidah unit-2 (Acom)	IPP	8*13.6	100	0	0	Reserve		
60	Anlima Energy Ltd.	IPP	6*21.2	116	0	0	Reserve		
	Mirshara 150 MW	BPDB-RPCL	18.5*9	163	0	0	Reserve		
	SS Power 1	SS Power	2*612	1224	272	6599999	Coal shortage		
	Cox's Bazar Wind	IPP	85	0	14	424800	On test.		
	Matarbari 2*600 MW (CPGCL)	0	CPGCL	0	333	7752727	On test.		
	Mirsharai 150 MW (Gas)	BPDB-RPCL	18.5*9	0	0	0	On test.		
Chattogram area Total				3769	881	19900278			
61	Ashuganj TPP Unit- 3	APSCL	1*150	0	0	0	Contract Expired		
	Ashuganj TPP Unit- 4	APSCL	1*150	0	0	0	Contract Expired		
	Ashuganj TPP Unit- 5	APSCL	1*150	0	0	0	Contract Expired		
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	96	2056000	ST Under maint.		
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	310	7236000	FGMO		
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	240	2440000	FGMO		
	Ashuganj 420 MW CCPP(East)	APSCL	28*1+16*1	400	0	0	Under maint.		
65	Ashuganj 50 MW PP	APSCL	14*3.968	45	48	823032			
66	Ashuganj 55 MW PP (Precision)	QRPP	0	0	42	432480	Gas shortage		
67	Ashuganj 195 MW PP (APSCL-United)	IPP	20*9.73+1*16	195	102	485091	Gas shortage		
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	325245			
69	Ashuganj 150 MW PP (Midland)	IPP	27*0.015	150	0	0	Reserve		
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve		
71	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.		
72	Chandpur 200 MW (Desh energy)	IPP	12*18.4	200	0	0	Reserve		
73	Feni 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	143280	Engine problem		
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	57060			
**	Impogrt (Tirupura)	Imported power	0	160	82	1696320			
75	Jangalia 33 MW PP (Summit)	SIPP, PDB	4*8.73	33	33	280500			
76	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	0	Reserve		
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	11	279440	Engine problem		
78	Daudkandi 200 MW PP (B.Trac)	IPP	0	0	0	0	Contract Expired		
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	Reserve		
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Reserve		
81	Bhairab 54.5 MW	IPP	3*18.2	54	0	41400	Reserve		
82	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	0	0	Reserve		
Cumilla Area Total				2896	1041	16295848			
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	152	2654000	Gas shortage		
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	0	Contract Expired		
85	Jamulpur 95 MW PPI(Powerpac)	IPP	0	0	0	0	Under maint.		
86	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	11300			
87	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	16	21600	Low voltage		
88	Jamulpur 115 MW PP (United)	IPP	9*78*12	115	16	75600	Low voltage		
89	Sutakhalai 50 MW Solar PP	IPP	50	50	0	266180			
90	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	0	0			
Mymensingh Area Total				614	184	3038660			
91	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1005000	Machine problem		
92	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	80	9	90	Machine problem		
93	Kushiana 163 MW CCPP (KP)	IPP	1*109+1*54	163	120	3251781			
94	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.		
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	342600			
	Fenchugonj 44 MW (Energyprima)	NENP	12*3.3+5*2	50	0	0			
96	Hobiganj 1.1 MW PP (Confidence-E	SIPP, REB	4*2.90	11	8	159936	Engine problem		
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	40	927828			
98	Shahjibazar 86 MW PP (Shahjibazar)	RPP	32*2.90	86	50	329280	Gas shortage		
99	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.		
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	206	5219090	Gas shortage		
101	Sylhet 20 MW GTPP-1	PDB	1*20	20	0	0	Gas shortage		
	Sylhet 50 MW PP (EPL)	NENP	27*2	0	0	0	Contract Expired		
102	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	107184	Gas shortage		
103	Bibiana-I 341 MW CCPP (Summit)	IPP	1*222+1*119	341	325	6804000	FGMO		
104	Bibiyana-III 400 MW CCPP	PDB	285*1+13*1	400	353	7446000			
105	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	8	61200			
106	Bibiyana South 400 MW	PDB	0	400 MW	383	0	Under maint.		
Sylhet Area Total				2427	1223	25653899			
107	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve		
**	Bheramara (HVDC)	Imported power	2*500	1000	803	14885818			
108	Khulina 115 PP MW (KPCL-2)	NENP	7*17	115	0	0	Reserve		
109	Fairfurd 50 MW Peaking PP	PDB	8*6.89	50	0	0	Reserve		
110	Khulina 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve		
111	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Machine problem		
112	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage		
	Noapara 40 MW PP (Kharajahan Ali)	NENP	5*8.5	40	0	0	Reserve		
113	Noapara 100 MW PP (Bangla Trac)	IPP	7*01.4	100	0	0	Contract Expired		
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	0	Reserve		
115	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Reserve		
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	413280			
	Khulina 330 MW CCPP (OL)	BPDB	1*220+1*110	336	0	0			