

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month January, 2024				Day : Sunday				Date : 31.12.24			
Probable Maximum Demand :				10100 MW		Probable Maximum Generation :				11883 MW	
Water Level of Kapital Lake at 06:00 AM				Yesterday =		#REF! ft		Today = 91.58 ft		Rule Curve = 101.29 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.24 (Yesterday)		31.12.24 (Today)		10.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGIPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	14	72	70	70	36	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	400	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	348	377	350	380		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30		
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	8	90	90		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0		
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	27	40	40	40		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	25	25		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	18	26	26		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	48	98		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	15	80	130		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	50	80	80		
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17		
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35		
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	17	53	53		
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	35	35		
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	35	0		
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17		
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	100	100		
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	100	100		
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	7	85	85		
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	35	40		
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		
	Meghnaghat Unique Power	Gas			628	549	584	584			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0			
Dhaka Zone Total				5655	5422	1943	2102	2523	2804	1201	740
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	20	6	20		
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	192	194	194	194	31	Gas Shortage
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	65	30	260	260		
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	12	12	12		
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51		
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	66	74	50	74		
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	18	18		
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	20	20		
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	27	0	46		
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	17		
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17		
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	25	25		
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	72	17	150		
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	281	276	280	280	948	Coal Shortage
	Metarbari 2*600 MW (CPGCL)	Coal				269	359	550	550		Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				1	13	10	10		Test run
Chattogram Zone Total				3829	3769	1159	1304	1682	1883	1159	330
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	48	45	45		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	180	260	200	0	100	Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	290	310	300	310	50	Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	350	400	Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	36	8	55		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	40	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	51	20	75		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	20	24	0	30		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10		
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	25	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	5	17	11	15		
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.45+1*9.78	114	114	52	34	100	100		
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	18	115	9	113		
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17		
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	17	18	18		
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	53	54	55	55		
**	Import (Tirupura)	India		160	160	118	100	128	140		
Cumilla Zone Total				2959	2896	956	1235	1092	1504	550	384
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	36	35	74	74	167	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	80	57	80		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	28	19	30		
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	7	0	50	0		
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	127	149	208	190	167	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.01.24 (Yesterday)		31.12.24 (Today)		10.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51						
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	63	63						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	211	212	210	210						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	15	15	15						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	300	300						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	413	406	250	350						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	0	0	0	0		50	Gas Shortage			
Sylhet Zone Total						2472	2427	1318	1323	1171	1271	50	930		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	14	0	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	17	90	90						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	66	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	16	32						
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0		8				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDc)	India		1000	1000	854	787	870	918						
Khulna Zone Total						3241	3237	955	848	1076	1088	410	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	22	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	122	120	120	120		74	Gas Shortage			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	622	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	35						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	307	250	250						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220						
Barishal Zone Total						2265	2265	1251	1342	1265	1283	74	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	34						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	20						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	91	50	90						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	48	0	50						
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	42	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	200	350						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	43	43	43	43						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	35	35						
139	Ammurua 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	766	759	750	750						
Raishahi Zone Total						3653	3631	1336	1496	1165	1526	721	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	42	6	49						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	75	70	115						
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	30	0						
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	18	0	130	0						
Rangpur Zone Total						1030	950	235	287	414	334	189	85		
Sub-total: Plants in operation						25726	25211	9280.0	10086	10596	11883	4521	2569		
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	9280	10086	10596	11883	4521	2569		
(C) Actual data of 10.01.24 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	10086	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9693	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	10086	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	6495	MW, at =	5:00 hrs	Dhaka	3625	3625	0	Mymensingh	848	848	0		
05.	Day-peak Generation (Generation end)	:	9280	MW, at =	12:00 hrs	Chattogram	972	972	0	Sylhet	353	353	0		
06.	Evening-peak Generation (Generation end)	:	10086	MW, at =	19:00 hrs	Khulna	1136	1136	0	Barisal	285	285	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	973	973	0	Rangpur	680	680	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6716	MW, at =	5:00 hrs	Cumilla	822	822	0						
09.	Generation shortfall at evening peak due to :	:				Total						9693	9693	0	
a)	Gas/LF limitation	:	4332	MW		(a) Gas = 106614495 Taka						(c) Coal = 351971729 Taka			
d)	Coal supply Limitation	:	189	MW		(b) Oil = 239212323 Taka						Total = 697798547 Taka			
b)	Low water level in Kaptai lake	:	0	MW		Maximum Temperature in Dhaka was : 23.0°C									
c)	Plants under shut down/ maintenance	:	2569	MW		Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	:	192.25	MKWh		At evening peak-hour						9280	MW, at 19:00 hrs		
	By Gas = 96.848 MKWh			By Oil = 17.794 MKWh		Maximum						140	MW, at 18:00 hrs		
	By Coal = 53.974 MKWh			By Hydro = 1.790 MKWh		Energy						0.0825	MKWh		
	By Solar= 1.080 MKWh														
11.	Total Gas Supplied	:	837.51	MMCFD											
(D) Forecast of 31.12.24 (Today) Sunday :															
01.	Maximum Demand	:	10100	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	11883	MW (Generation end)		05.	Total Generation	:	192.51	MKWh					
03.	Reserve / Shortage	:	1783	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	23.0°C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation