

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month January, 2024					Day : Saturday				Date : 13.01.24				
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 11963 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.40 ft		Today = 91.16 ft		Rule Curve = 100.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.01.24 (Yesterday)		13.01.24 (Today)		12.01.24 (Yesterday)		13.01.24 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	67	70	70	41		Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0			Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	397	400	400	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	0	91	91				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
17	Summit Power,Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.57+3x8.73	80	80	25	39	40	40				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	20	26	26				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	22	0	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	42	0	80	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	65	17	35	100				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	0	53	53				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	0	17	35				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	5	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	18	0	100	100				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	1	0	100	100				
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	42	0	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	12	0	35	40				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			574	605	605	605				Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0				Test run	
Dhaka Zone Total					5655	5422	2091	1918	2516	2851	1206	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	6	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	193	193	194	194	32		Gas Shortage	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	136	15	300	300				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	17	34	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	58	0	70	83				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	18	18				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			26	35	10	25				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	0	25	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	0	17	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	270	422	280	280	802		Coal Shortage	
	Metarbari 2*600 MW (CPGCL)	Coal				362	274	362	362			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				3	14	10	10			Test run	
Chattogram Zone Total					3829	3769	1334	1146	1527	1686	1014	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	48	45	45				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	310	330	330	50		Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	185	393	390	390	7		Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	73	8	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	10	20	80				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	0	0	30				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	10				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	17	11	15				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	0	98	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	29	116	113	113				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	18	18				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	55	54	55	55				
**	Import (Tripura)	India		160	160	96	92	128	140				
Cumilla Zone Total					2959	2896	1020	1196	1414	1536	417	384	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	54	35	45	148		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	60	79	57	80				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	28	19	30				
84	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	14	0	50	0				
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	2	6				
Mymensingh Zone Total					622	614	131	167	165	161	148	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.01.24 (Yesterday)		13.01.24 (Today)		12.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening						
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	51	51	51						
90	Kushlira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163						
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	214	211	210	210						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	15	15						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16						
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	330	330						
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	375	412	400	400						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	100	260	260	260		123	Under maint.			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5+5*2	50	50	0	0	0	0		50	Gas Shortage			
Sylhet Zone Total						2472	2427	1037	1294	1608	50	670			
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	0	90	90						
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0						
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	49	0	16	32						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0						
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVDc) India			1000	1000	719	708	826	922						
Khulna Zone Total						3241	3237	874	708	1032	410	0			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	0	16	16						
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	20	20	20						
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	117	120	120		77	Gas Shortage			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	580	622	622						
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	17	35						
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150						
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220						
Barishal Zone Total						2265	2265	1029	1122	1165	1183	77	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	34						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	26	50	90						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	50						
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	42	42						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38						
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage			
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage			
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	298	414	350	350		0	Gas Shortage			
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	43	43						
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	7	0	35	35						
140	Ammurra 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	723	764	750	750						
Raishahi Zone Total						3653	3631	1125	1250	1315	1526	721	100		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage			
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	41	6	35						
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
148	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0						
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	70	115						
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	4	0	30	0						
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	30	0	130	0						
Rangpur Zone Total						1030	950	211	283	414	320	189	85		
Sub-total: Plants in operation						25726	25211	8852.0	9084	11156	11963	4232	2309		
(B) Plants under long term maintenance/ contract expired															
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
153	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
154	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0		
Gross Total						25951	25211	8852	9084	11156	11963	4232	2309		
(C) Actual data of 12.01.24 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	9084	MW,	at =	20:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8667	MW,	at =	20:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9589	MW,	at =	13:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	6656	MW,	at =	5:00	hrs	Dhaka	2990	2990	0	Mymensingh	811	811	0
05.	Day-peak Generation (Generation end)	:	8852	MW,	at =	12:00	hrs	Chattogram	881	881	0	Sylhet	333	333	0
06.	Evening-peak Generation (Generation end)	:	9084	MW,	at =	20:00	hrs	Khulna	1077	1077	0	Barisal	277	277	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	20:00	hrs	Rajshahi	898	898	0	Rangpur	616	616	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6118	MW,	at =	5:00	hrs	Cumilla	785	785	0				
09.	Generation shortfall at evening peak due to :	:						Total					8667	8667	0
a)	Gas/LF limitation	:	4043	MW				Total = 8667					327605409	Taka	
d)	Coal supply Limitation	:	189	MW				Total = 8667					599452187	Taka	
b)	Low water level in Kaptai lake	:	0	MW				Total = 8667							
c)	Plants under shut down/ maintenance	:	2309	MW				Total = 8667							
10.	Total Energy (Generation + India Import)	:	193.50	MKWh				Total = 8667							
	By Gas =	109.134	MKWh	By Oil =	12.929	MKWh		Total = 8667							
	By Coal =	51.916	MKWh	By Hydro =	1.845	MKWh		Total = 8667							
	By Solar=	0.898	MKWh					Total = 8667							
11.	Total Gas Supplied	:	808.73	MMCFD				Total = 8667							
(D) Forecast of 13.01.24 (Today) Saturday :															
01.	Maximum Demand	:	10300	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11963	MW	(Generation end)			05.	Total Generation	:	207.85	MKWh			
03.	Reserve / Shortage	:	1663	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	18.5°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation