

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2024				Day : Sunday				Date : 14.01.24					
Probable Maximum Demand : 10600 MW				Probable Maximum Generation : 11400 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.16 ft.		Today = 90.99 ft.		Rule Curve = 100.72 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.01.24 (Yesterday)		14.01.24 (Today)		13.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180		Gas Shortage		
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0		365	Awaiting for HGPI		
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	69	70	70	39	Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired		
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	366	403	400	400				
12	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage		
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	40	91	91				
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x4.73	80	80	15	24	40	40				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	25	30	25	30				
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	18	12	26	26				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	52	17	105				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	32	98				
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	0	0	17				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	45	80	130				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	48	54	55	55				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	25	46	52	72				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	35	35				
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	25	92	92				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	100	100				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	51	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	20	35	40				
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
38	Meghnaghat Unique Power	Gas			554	580	605	605			Test run		
39	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0			Test run		
Dhaka Zone Total				5655	5062	1814	2267	2540	2817	1204	740		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76				
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
44	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0				
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	20				
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under Maint.		
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	194	194	194	194	31	Gas Shortage		
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	203	100	175				
51	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	12	12	12				
52	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	51	51				
53	Hatibazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	81	60	83				
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	18	18	18				
55	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			4	10	10	25				
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
57	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17				
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
59	Juldah unit-2 (Acorn)	HFO (RPP)	8x13.6	100	100	0	12	12	12				
60	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	25	25	25				
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	88	17	150				
63	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	270	285	280	280	939	Coal Shortage		
64	Matarbari 2*600 MW (CPGCL)	Coal		575	575	304	358	362	362		Test run		
65	Cox's Bazar Wind PP	(Wind) (IPP)				0	6	10	10		Test run		
Chattogram Zone Total				4404	4344	1027	1506	1334	1578	1150	330		
66	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	45	45	45	45				
67	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.		
68	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage		
69	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	280	280	330	80	Gas Shortage		
70	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	360	355	390	390	45	Gas Shortage		
71	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8				
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	108	12	80				
74	Titas 50 MW Peaking PP	HFO (PDB)	6x6.92	52	52	0	16	0	30				
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17				
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	18	18				
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	10	10	10				
79	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	33	33	33				
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	11	15				
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114				
83	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	120	39	9	38				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17				
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	18	18				
86	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	20	55	55				
87	Import (Tirupura)	India		160	160	106	102	128	140				
Cumilla Zone Total				2959	2951	1150	1268	1216	1409	485	384		
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	31	35	45	171	Gas Shortage		
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
90	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	60	77	57	80				
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	28	19	30				
92	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
93	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0				
94	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	2	6				
Mymensingh Zone Total				622	614	122	142	165	161	171	0		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.01.24 (Yesterday)		14.01.24 (Today)		13.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
							Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	53	51	51					
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	130	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	50	50	50					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	216	210	210	210					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	15	16	20	20					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	290	300					
100	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	373	412	400	400					
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	120	0	0	0		383	Under maint.		
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50		Gas Shortage		
Sylhet Zone Total				2472	2427	1340	1301	1313	1323	50	930			
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	6	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)	7x17	100	100	74	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	66	49	49					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	8	0	8					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDP)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVCDC)	India		1000	1000	809	792	826	922					
Khulna Zone Total				3241	3237	883	872	1065	1109	410	0			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	26	0	16					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	19	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	115	115	120	120	79		Gas Shortage		
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	622	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	63	17	35					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total				2265	2265	1119	1215	1149	1183	79	0			
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	34					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	20					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	92	50	92					
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	50					
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	360	350	350	54		Gas Shortage		
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	0	55	0	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	7	33	35	35					
140	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	759	760	750	750					
Raishahi Zone Total				3653	3631	1246	1432	1280	1493	775	100			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	41	6	42					
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	72	70	115					
150	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	5	0	30	0					
151	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	31	0	130	0					
Rangpur Zone Total				1030	950	213	283	414	327	189	85			
Sub-total: Plants in operation				26301	25481	8914.0	10286	10476	11400	4513	2569			
(B) Plants under long term maintenance/ contract expired														
152	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
153	Bostla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
154	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	0	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0			
Gross Total				26504	25481	8914	10286	10476	11400	4513	2569			
(C) Actual data of 13.01.24 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	10286	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9851	MW, at =	19:00 hrs	Zone Demand Supply Load Shed Zone Demand Supply Load Shed								
03.	Highest Generation (Generation end)	:	10286	MW, at =	19:00 hrs	Dhaka 3621 3621 0 Myrmensingh 895 895 0								
04.	Minimum Generation (Generation end)	:	6118	MW, at =	5:00 hrs	Chattogram 968 968 0 Sylhet 354 354 0								
05.	Day-peak Generation (Generation end)	:	8914	MW, at =	12:00 hrs	Khulna 1195 1195 0 Barishal 289 289 0								
06.	Evening-peak Generation (Generation end)	:	10286	MW, at =	19:00 hrs	Rajshahi 1015 1015 0 Rangpur 680 680 0								
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla 833 833 0								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6652	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:				Total 9851 9851 0								
a)	Gas/LF limitation	:	4324	MW		13. Fuel cost : (a) Gas = 101921065 Taka (c) Coal = 324119765 Taka								
d)	Coal supply Limitation	:	189	MW		(b) Oil = 215447010 Taka Total = 641487841 Taka								
b)	Low water level in Kaptai lake	:	0	MW										
c)	Plants under shut down/ maintenance	:	2569	MW		14. Maximum Temperature in Dhaka was : 17.6°C								
10.	Total Energy (Generation + India Import)	:	200.44	MKWh		15. Export through East-West interconnections : At evening peak-hour : 8914 MW, at 19:00 hrs								
	By Gas = 112.011 MKWh			By Oil = 16.559 MKWh		Maximum : 106 MW, at 2:00 hrs								
	By Coal = 50.271 MKWh			By Hydro = 1.861 MKWh		Energy : 0 MKWh								
	By Solar = 0.984 MKWh													
11.	Total Gas Supplied	:	845.83	MMCFD										
(D) Forecast of 14.01.24 (Today) Sunday :														
01.	Maximum Demand	:	10600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11400	MW	(Generation end)	05.	Total Generation	:	206.56	MKWh				
03.	Reserve / Shortage	:	800	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		18.5°C					