

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2024					Day : Monday					Date : 15.01.24					
Probable Maximum Demand : 10600 MW					Probable Maximum Generation : 10864 MW										
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 90.99 ft		Today = 90.81 ft		15.01.24		Rule Curve = 100.34 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.24 (Yesterday)		15.01.24 (Today)		14.01.24 (Yesterday)		15.01.24 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :						
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks				
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	74	70	74	34		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0	0		Contract Expired			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	370	400	450	450						
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	406	400	412						
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	8	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	91	74	90	90						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0						
17	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.87+7x4.73	80	80	40	38	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	12	26	26						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	17	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	32	98						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	0						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	113	80	130						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	35	35	35						
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17						
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35						
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	52	53						
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	0	0	0						
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	4	0	35	0						
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17						
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	84	92	92	92						
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	71	92	90	92						
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	78	82	80	80						
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	26	30	30						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
	Meghnaghat Unique Power	Gas			617	623	605	620				Test run			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			Test run			
Dhaka Zone Total				5655	5062	2315	2602	2469	2724	1199	740				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	106	76	76						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	27	17	17						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	194	194	194	194	31		Gas Shortage			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	107	100	100	120						
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	12	12	12	12						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	57	81	60	81						
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	18	21						
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			0	0	10	15						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
52	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	0						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	22	17	17	17						
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	12	12	12						
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	25	25	25	25						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	106	17	150						
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	276	300	280	300	924		Coal Shortage			
	Matarbari 2*600 MW (CPGCL)	Coal		575	575	324	479	480	480			Test run			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run			
Chattogram Zone Total				4404	4344	1232	1585	1435	1635	1135	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	41	45	45						
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	370	280	300	300	80		Gas Shortage			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	285	350	390	390	50		Gas Shortage			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	0	0	0						
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	75	12	100						
67	Titas 50 MW Peaking PP	HFO (PDB)	6x6.92	52	52	24	24	0	30						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	36	17	17						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10						
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	52						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	8	11	17						
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	114	114	114						
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	36	9	9						
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	7	17	17	17						
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	18	18						
	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	35	55	55						
**	Import (Tripura)	India		160	160	108	98	128	140						
Cumilla Zone Total				2959	2951	1152	1244	1228	1416	490	384				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	35	35	50	167		Gas Shortage			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0						
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	57	80						
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	38	19	28						
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0						
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	27	0	50	0						
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	2	6						
Mymensingh Zone Total				622	614	143	158	165	164	167	0				

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.01.24 (Yesterday)		15.01.24 (Today)		14.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW			
							Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	0	0	0					
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	60	60					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	50	50					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	14	13	20	20					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	330	305	290	310					
100	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	241	413	400	400					
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.		
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage		
Sylhet Zone Total				2472	2427	1119	1213	1192	1212	50	930			
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	35					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	17	17	17					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	72	93	90	93					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)	7x17	100	100	74	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	49	32	32	32					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	16	8	0	8					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVCDC)	India		1000	1000	905	838	826	905					
Khulna Zone Total				3241	3237	1116	1022	1065	1090	410	0			
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	32					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	20	20	20					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	115	120	120		79	Gas Shortage		
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	622	622	622					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total				2265	2265	1124	1213	1149	1218	79	0			
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	27	0	30					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	52	93	50	93					
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	0	40					
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	23	38	0	38					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	188	0	0	0		414	Gas Shortage		
135	Ullapara 11 MW PP. (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	0	35	0	35					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	9	0	0	35					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	768	759	750	750					
Raishahi Zone Total				3653	3631	1129	1080	895	1130	1135	100			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	200	170	170		74	Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	34	6	35					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	12	0	0					
146	Majpara. Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6x20	115	115	0	74	70	70					
148	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0					
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	39	0	130	0					
Rangpur Zone Total				1030	950	227	320	414	275	159	85			
Sub-total: Plants in operation				26301	25481	9557.0	10437	10012	10864	4824	2569			
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	0	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0			
Gross Total				26504	25481	9557	10437	10012	10864	4824	2569			
(C) Actual data of 14.01.24 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	10437	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	9954	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10437	MW, at =	19:30 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6652	MW, at =	5:00 hrs	Dhaka	3687	3687	0	Myrmensingh	879	879	0	
05.	Day-peak Generation (Generation end)	:	9557	MW, at =	12:00 hrs	Chattogram	1008	1008	0	Sylhet	355	355	0	
06.	Evening-peak Generation (Generation end)	:	10437	MW, at =	19:30 hrs	Khulna	1205	1205	0	Barishal	295	295	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Rajshahi	998	998	0	Rangpur	697	697	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6722	MW, at =	5:00 hrs	Cumilla	830	830	0					
09.	Generation shortfall at evening peak due to :	:				Total						9954	9954	0
	a) Gas/LF limitation	:	4665	MW		13. Fuel cost : (a) Gas = 96473345 Taka (c) Coal = 334182662 Taka								
	d) Coal supply Limitation	:	159	MW		(b) Oil = 375609922 Taka Total = 806265928 Taka								
	b) Low water level in Kaptai lake	:	0	MW		14. Maximum Temperature in Dhaka was : 18.1°C								
	c) Plants under shut down/ maintenance	:	2569	MW		15. Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	212.79	MKWh		At evening peak-hour : 9557 MW, at 19:30 hrs								
	By Gas = 108.026 MKWh			By Oil = 28.149 MKWh		Maximum : 106 MW, at 2:00 hrs								
	By Coal = 52.291 MKWh			By Hydro = 1.765 MKWh		Energy : 0 MKWh								
	By Solar= 1.145 MKWh													
11.	Total Gas Supplied	:	792.16	MMCFD										
(D) Forecast of 15.01.24 (Today) Monday :														
01.	Maximum Demand	:	10600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	10864	MW	(Generation end)	05.	Total Generation	:	216.12	MKWh				
03.	Reserve / Shortage	:	264	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	22.6°C					

*Gross Power Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation