

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month January, 2024					Day : Tuesday				Date : 16.01.24					
Probable Maximum Demand : 10600 MW					Probable Maximum Generation : 11269 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 90.81 ft		Today = 90.60 ft		16.01.24 (Today)		Rule Curve = 100.34 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.01.24 (Yesterday)		16.01.24 (Today)		15.01.24 (Yesterday)		16.01.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening					Description/ Remarks	Probable start-up date
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	75	70	75	33			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	330	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	418	340	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	83	50	90	90					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	38	39	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	30	30					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	14	14	14					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	17	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	32	98					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	0					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	45	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	36	35	35					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	53	52	53					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	0	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	92	50	92	92					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	94	48	90	92					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	68	58	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	20	30	30					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			617	623	0	300					Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0					Test run	
Dhaka Zone Total			5655	5062	2371	2316	1856	2424	1198	740				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	20	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	193	193	194	194	32			Gas Shortage	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	80	100	120					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	80	60	81					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	18	22					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	3	10	15					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	0					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	25	25	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	150					
58	Chattogram 2*612MW Coal Based PP (SS Powe)	Coal (IPP)	2x612	1224	1224	296	295	280	280	929			Coal Shortage	
	Matbarani 2600 MW (CPGCL)	Coal		575	575	568	505	580	580				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run	
Chattogram Zone Total			4404	4344	1426	1587	1535	1716	1141	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	41	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360			Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	310	300	300	50			Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	245	290	320	320	110			Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	8	8					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	20	12	100					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	33	0	33					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	10					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	1	38	24	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	17	11	17					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	70	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	47	9	48					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	0	17					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	56	55	55	55					
**	Import (Tripura)	India		160	160	116	102	128	140					
Cumilla Zone Total			2959	2951	1111	1222	1172	1395	520	384				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	35	35	50	167			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	57	80					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	28	19	28					
84	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutlakhal 50 MW Solar PP	Solar (IPP)												

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.01.24 (Yesterday)		16.01.24 (Today)		15.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance							
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening										
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	GT-1 Under maint.						
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			90	GT-4 Under maint.						
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0										
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	163	163										
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0										
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60										
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.						
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	50	50	84	84										
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	0	0										
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	15	16	20	20										
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10										
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16										
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	290	310										
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	239	400	0	0										
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	50	80			383	Under maint.						
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work						
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	0	0	46	46			50	Gas Shortage						
Sylhet Zone Total						2472	2427	1026	1135	782	832	50	930						
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0										
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			410		Gas Shortage					
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	32	48	0	48										
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	10	20	17	20										
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0										
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	93	93	90	93										
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0										
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	28	0	100	0										
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	32	32	32										
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8										
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0										
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0										
**	Bheramara (HVDc)	India		1000	1000	898	795	826	905										
Khulna Zone Total						3241	3237	1077	996	1065	1106	410	0						
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	32										
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	18	20	20										
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	55	0	65	65			194		Gas Shortage					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	590	622	622										
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54										
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	250	250	250										
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	220	220										
Barishal Zone Total						2265	2265	1061	1148	1194	1263	194	0						
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71		Gas Shortage					
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100		Under maint.					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	0	30										
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0										
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	20										
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	92	50	93										
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	7	46	0	40										
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42										
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	38										
132	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			210		Gas Shortage					
133	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0			220		Gas Shortage					
134	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0			220		Gas Shortage					
135	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	414	414	414			0		Gas Shortage					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11										
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8										
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35										
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	35	0	35										
140	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	6	28	28										
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0										
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	760	769	1300	1300										
Raishahi Zone Total						3653	3631	905	1540	1859	2094	721	100						
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85		Coal Shortage					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85		Under Overhauling					
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			104		Coal Shortage					
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	34	6	35										
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
148	Majpara, Talula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0										
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	70	70										
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	30	0										
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	32	0	130	0										
Rangpur Zone Total						1030	950	219	276	414	275	189	85						
Sub-total: Plants in operation						26301	25481	9335.0	10368	10042	11269	4590	2569						
(B) Plants under long term maintenance/ contract expired																			
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0										
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0										
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	0	0	0	0	0	0										
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0						
Gross Total						26504	25481	9335	10368	10042	11269	4590	2569						
(C) Actual data of 15.01.24 (Yesterday) Monday :																			
01.	Max. Demand at eve. peak (Generation end)	:	10368	MW,	at =	19:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	9857	MW,	at =	19:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	10368	MW,	at =	19:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	6722	MW,	at =	5:00	hrs	Dhaka	3717	3717	0	Mymensingh	881	881	0				
05.	Day-peak Generation (Generation end)	:	9335	MW,	at =	12:00	hrs	Chattogram	906	906	0	Sylhet	353	353	0				
06.	Evening-peak Generation (Generation end)	:	10368	MW,	at =	19:00	hrs	Khulna	1187	1187	0	Barisal	288	288	0				
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:00	hrs	Rajshahi	997	997	0	Rangpur	704	704	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6811	MW,	at =	5:00	hrs	Cumilla	825	825	0								
09.	Generation shortfall at evening peak due to :	:						Total											
	a) Gas/LF limitation	:	4401	MW				(a) Gas = 93685786 Taka				(c) Coal = 357162002 Taka							
	d) Coal supply Limitation	:	189	MW				(b) Oil = 307258932 Taka				Total = 758106720 Taka							
	b) Low water level in Kaptai lake	:	0	MW				14. Maximum Temperature in Dhaka was : 18.1°C											
	c) Plants under shut down/ maintenance	:	2569	MW				15. Export through East-West interconnections :											
10.	Total Energy (Generation + India Import)	:	211.22	MKWh				At evening peak-hour : 9335 MW, at 19:00 hrs											
	By Gas = 104.985 MKWh			By Oil = 23.353 MKWh				Maximum : 106 MW, at 2:00 hrs											
	By Coal = 58.847 MKWh			By Hydro = 1.780 MKWh				Energy : 0 MKWh											
	By Solar= 0.894 MKWh																		
11.	Total Gas Supplied	:	789.36	MMCFD															
(D) Forecast of 16.01.24 (Today) Tuesday :																			
01.	Maximum Demand	:	10600	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	11269	MW	(Generation end)			05.	Total Generation	:	215.94	MKWh							
03.	Reserve / Shortage	:	669	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	21.4°C								