

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2024					Day : Wednesday					Date : 24.01.24				
Probable Maximum Demand : 10800 MW					Probable Maximum Generation : 10818 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 89.32 ft		Today = 89.12 ft		Rule Curve = 98.60 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.01.24 (Yesterday)		24.01.24 (Today)		23.01.24 (Yesterday)		24.01.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for r Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage	
b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	418	401	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	332	336	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	91	75	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	40					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	30	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	32	100					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	0	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	53	36	54	36					
26	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	39	53	53	72					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	35	17					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	85	93	92	92					
33	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	87	96	100	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	82	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	25	25	25	25					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0				Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				70	49	100	100				Test run	
Dhaka Zone Total				5655	5062	2214	2439	2298	2567	926	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	28	17	28	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	31	206	220	220	19			Gas Shortage	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	49	105	50	100					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	48	66	60	72					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	18	18					
*	Melancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			1	20	5	10					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	5	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	0					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	17	17	17					
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	447	400	400	400	824			Coal Shortage	
	Matarbari 2*600 MW (CPGCL)	Coal		575	575	419	271	450	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	1	10	10				Test run	
Chattogram Zone Total				4404	4344	1295	1397	1533	1136	1023	330			
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	44	44	50	45					
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	0	157	160	160		64		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0		360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	310	305	310	310	55			Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400			Gas Shortage	
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	117	8	0	0					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	8	6	20					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	25	25	25					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	10	10					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	17	11	18					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	78	9	78					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	0	18					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	44	45	45					
**	Impoport (Tripura)	India		160	160	110	108	128	141					
Cumilla Zone Total				2959	2951	784	959	893	1009	815	227			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	34	35	40	168			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	68	56	68					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutikahali 50 MW Solar PP	Solar (IPP)												

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.01.24 (Yesterday)		24.01.24 (Today)		23.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	40	40	40		50	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	63	60	60				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	20	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	300	310	310	41		Gas Shortage	
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.	
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	360	250	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1046	1099	996	1146	41	907
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	12	32	15	40				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	12	20	20	20				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	93	93	93	93				
110	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	16	33				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	765	794	922	922				
Khulna Zone Total						3241	3237	975	979	1166	1124	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	18	20	20				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	135	135	135	135	59		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	622	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	250	200	200				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1261	1315	1214	1267	59	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	32	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	15	0	16				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	91	50	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	32	0	34				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	25	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	25	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	375	319	400	400	95		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	21	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1271	1470	1400	1400				
Rajshahi Zone Total						3653	3631	1774	2127	1985	2171	816	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	41	6	35				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	0	70				
150	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0				
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	137	0	130	0				
Rangpur Zone Total						1030	950	346	281	344	275	189	85
Sub-total: Plants in operation						26301	25481	9797.0	10713	10583	10818	4447	2389
(B) Plants under long term maintenance/ contract expired													
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
153	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
154	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	20	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9797	10713	10583	10818	4447	2389
(C) Actual data of 23.01.24 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10713	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10172	MW, at =	19:00 hrs		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10713	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	6763	MW, at =	5:00 hrs		Dhaka	3772	3772	0	Mymensingh	848	848
05.	Day-peak Generation (Generation end)	:	9797	MW, at =	12:00 hrs		Chattogram	1012	1012	0	Sylhet	374	374
06.	Evening-peak Generation (Generation end)	:	10713	MW, at =	19:00 hrs		Khulna	1214	1214	0	Barisal	283	283
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs		Rajshahi	1069	1069	0	Rangpur	753	753
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6840	MW, at =	5:00 hrs		Cumilla	847	847	0			
09.	Generation shortfall at evening peak due to :	:								Total	10172	10172	0
a)	Gas/LF limitation	:	4258	MW		13.	Fuel cost :	(a) Gas = 300725139 Taka	(c) Coal = 439774733 Taka				
c)	Coal supply Limitation	:	189	MW				(b) Oil = 465560959 Taka	Total = 1206060831 Taka				
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2389	MW		14.	Maximum Temperature in Dhaka was : 22.6°C						
10.	Total Energy (Generation + India Import)	:	215.77	MWKh		15.	Export through East-West interconnections :						
	By Gas = 97.249 MKWH			By Oil = 25.866 MKWh			At evening peak-hour : 9797 MW, at 19:00 hrs						
	By Coal = 70.318 MKWH			By Hydro = 1.841 MKWh			Maximum : 328 MW, at 7:00 hrs						
	By Solar = 1.778 MKWH						Energy : 0 MWKh						
11.	Total Gas Supplied	:	772.04	MMCFD									
(D) Forecast of 24.01.24 (Today) Wednesday :													
01.	Maximum Demand	:	10800	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	10818	MW	(Generation end)	05.	Total Generation : 217.52 MKWh						
03.	Reserve / Shortage	:	18	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 22.6°C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation