

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2024					Day : Monday					Date : 29.01.24					
Probable Maximum Demand : 10700 MW					Probable Maximum Generation : 11703 MW										
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 88.10 ft	Today = 87.86 ft					Rule Curve = 97.60 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.24 (Yesterday)		29.01.24 (Today)		28.01.24 (Yesterday)		29.01.24 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work	
a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			180		Gas Shortage		
b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180							
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365		Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12			96		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0					Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0			412		Under maintenance	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	333	335	335	335						
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	91	50	91						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	41	40	42						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	30	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	21	30	30						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	70						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	98						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	60	80	130						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	21	54	35	35						
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17						
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35						
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	54	54	54						
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	17	17						
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0						
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17						
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	60	90	90						
33	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	51	49	90	90						
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	48	80	80						
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	0	25	25						
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
	Meghnaghat Unique Power	Gas				0	0	0	0					Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					Test run	
Dhaka Zone Total				5655	5062	1509	1761	1689	1979	926	1152				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	20						
43	Sikalbaha 105 MW PP (Baraka Siklabaha)	HFO (IPP)	6x18.415	105	105	17	17	28	28						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	204	220	220						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	49	100	45	150						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	68	68	68						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	72	48	70						
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	15	15	15						
*	Melancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	0	5	20						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	13	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	29	18	30	17						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25						
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	12	17	17	17						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	72	35	163						
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	430	430	400	400			794		Coal Shortage	
	Matarbari 2*600 MW (CPGCL)	Coal		575	575	566	363	600	390					Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				11	20	10	10					Test run	
Chattogram Zone Total				4404	4344	1672	1596	1711	1785	974	330				
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	45	41	48	48						
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	155	157	150	150					Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0			360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	280	280	280	280			80		Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0			400		Gas Shortage	
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	45	45			187		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	26	6	20						
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	24	25	25						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	13	18						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	7	7						
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	15	15						
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0						
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	57	9	58						
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	2	17	17	17						
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	18						
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	57	55	55	55						
**	Import (Tripura)	India		160	160	118	108	128	141						
Cumilla Zone Total				2959	2951	834	915	907	1006	1027	227				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	61	73	72	72			129		Gas Shortage	
81	Tangail 22 MW PP (Doreen														

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.01.24 (Yesterday)		29.01.24 (Today)		28.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance														
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date													
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)															
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.														
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.														
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51																	
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	130	163	163																	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0																	
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	29	60	60																	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.														
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86																	
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.														
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	18	20	20																	
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10																	
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16																	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	310	310	71		Gas Shortage														
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.														
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	155	375	350	400																	
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work														
103	Fenchuganj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	50	50	50	50																	
Sylhet Zone Total						2472	2427	914	1110	1199	1249	71	1138													
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0																	
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage														
106	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	42	15	40																	
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	20	37	20	44																	
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0																	
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	74	93	93	93																	
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0																	
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	80	0	100	0																	
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16																	
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	0	0	8																	
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	557	556	600	600																	
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0																	
**	Bheramara (HVDC)	India		1000	1000	908	804	927	927																	
Khulna Zone Total						3241	3237	1673	1548	1771	1728	410	0													
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16																	
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	7	20	20																	
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	137	137	137	57		Gas Shortage														
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	590	622	622																	
120	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54																	
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	307	307	307																	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220																	
Barishal Zone Total						2265	2265	1082	1331	1323	1376	57	0													
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage														
b) Baghabari 100 MW GTPP	Gas (PDB)		1 x 100	100	100	0	0	0	0		100	Under maint.														
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	32	34																	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0																	
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	16																	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	84	50	92																	
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0																	
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	16	34	42																	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	25	38																	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage														
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage														
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage														
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	291	414	414	123		Gas Shortage														
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11																	
136	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	8	8	0	0																	
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35																	
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35																	
139	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	0	28	28																	
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0																	
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1226	1275	1400	1400																	
Rajshahi Zone Total						3653	3631	1678	1838	2000	2145	844	100													
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage														
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0		85	Under Overhauling														
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	170	170	170	104		Coal Shortage														
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0																	
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	42	6	42																	
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0																	
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0																	
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	113	0	70																	
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	30	0																	
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	141	0	130	0																	
Rangpur Zone Total						1030	950	394	325	344	282	189	85													
Sub-total: Plants in operation						26301	25481	9930.0	10580	11135	11703	4627	3032													
(B) Plants under long term maintenance/ contract expired																										
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0																	
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0																	
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	20	0	0	0	0	0																	
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0													
Gross Total						26504	25481	9930	10580	11135	11703	4627	3032													
(C) Actual data of 28.01.24 (Yesterday) Sunday :																										
01.	Max. Demand at eve. peak (Generation end)	:	10580	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :																				
02.	Max. Demand at eve. peak (Sub-station end)	:	10143	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW													
03.	Highest Generation (Generation end)	:	10580	MW, at =	19:00 hrs	Dhaka	3676	3676	0	Mymensingh	854	854	0													
04.	Minimum Generation (Generation end)	:	6939	MW, at =	5:00 hrs	Chattogram	984	984	0	Sylhet	364	364	0													
05.	Day-peak Generation (Generation end)	:	9930	MW, at =	12:00 hrs	Khulna	1208	1208	0	Barisal	288	288	0													
06.	Evening-peak Generation (Generation end)	:	10580	MW, at =	19:00 hrs	Rajshahi	1130	1130	0	Rangpur	790	790	0													
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	849	849	0																	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7013	MW, at =	5:00 hrs																					
09.	Generation shortfall at evening peak due to :	:																								
a) Gas/LF limitation	:	4438	MW			13.	Fuel cost :	(a) Gas = 280677518 Taka		(c) Coal = 510056845 Taka																
d) Coal supply Limitation	:	189	MW		(b) Oil = 366325084 Taka			Total = 1157059447 Taka																		
b) Low water level in Kaptai lake	:	0	MW																							
c) Plants under shut down/ maintenance	:	3032	MW				14.					Maximum Temperature in Dhaka was : 26.2°C														
10.	Total Energy (Generation + India Import)	:	217.54	MKWh								15.	Export through East-West interconnections :													
	By Gas =	87.052	MKWh	By Oil =			20.681					At evening peak-hour : 9930 MW, at 19:00 hrs														
	By Coal =	84.708	MKWh	By Hydro =			1.854					Maximum : 400 MW, at 6:00 hrs														
	By Solar =	2.030	MKWh									Energy : 0 MKWh														
11.	Total Gas Supplied	:	693.33	MMCFD																						
(D) Forecast of 29.01.24 (Today) Monday :																										
01.	Maximum Demand	:	10700	MW			(Generation end)					04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)													
02.	Maximum Generation	:	11703	MW			(Generation end)					05.	Total Generation : 220.01 MKWh													
03.	Reserve / Shortage	:	1003	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 26.2°C																			