

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2024					Day : Monday					Date : 22.01.24									
Probable Maximum Demand : 10800 MW					Probable Maximum Generation : 11175 MW														
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 89.65 ft					Today = 89.44 ft					Rule Curve = 99.00 ft				
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.01.24 (Yesterday)		22.01.24 (Today)		21.01.24 (Yesterday)		22.01.24 (Today)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)							
						Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date						
(A) Plants in operation:																			
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work					
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage					
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	180	180	180										
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365		Awaiting for HGPI					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	15	96				Gas Shortage					
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105				Gas Shortage					
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0										
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0					Contract Expired					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450										
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling					
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	25	400	412	387				Gas Shortage					
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210				Gas Shortage					
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335				Gas Shortage					
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335				Gas Shortage					
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	2	15	15	15										
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	91	70	90										
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0										
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	39	39	40	40										
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	30	33										
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	23	21	23										
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17										
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	105	17	105										
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	149	32	149										
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	0										
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	148	260	80	260										
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	96	35	50										
27	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17										
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17										
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	39	72	35	51										
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	17	17										
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	35	0										
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17										
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	73	70	73										
34	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	81	53	100	100										
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	82	30	82										
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	25	30	30										
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0										
38	Meghnaghat Unique Power	Gas				0	0	0	0					Test run					
39	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	200	200					Test run					
Dhaka Zone Total				5655	5062	1304	1868	1924	2443	1648	740								
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76										
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage					
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180			Under maint.					
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0										
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17										
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0										
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19										
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	16	16	15	16										
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150			Under maint.					
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225				Gas Shortage					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	49	106	50	105										
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25										
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51										
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	64	64	60	64										
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	18	18										
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	15	5	10										
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0										
54	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	1	0	0	0										
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17										
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25										
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25										
58	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17										
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	72	36	17	36										
60	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	396	480	400	480	744				Coal Shortage					
61	Matarbari 2*600 MW (CPGCL)	Coal		575	575	154	419	400	420					Test run					
62	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10					Test run					
Chattogram Zone Total				4404	4344	1048	1427	1250	1431	1149	330								
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0										
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	156	147	130	145		74			Under Maint.					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360				Gas Shortage					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	330	320	330	30				Gas Shortage					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400				Gas Shortage					
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0										
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51										
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	13	6	13										
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	25	25	25										
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163			Under maint.					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17										
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	13	13	13										
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	8	10	10										
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33										
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8										
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	18	11	18										
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0										
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	78	9	78										
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17										
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	17										
79	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0										
80	Import (Tripura)	India		160	160	106	106	128	141										
Cumilla Zone Total				2959	2951	795	864	778	916	790	237								
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	73	60	75	129									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.01.24 (Yesterday)		22.01.24 (Today)		21.01.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	40	40	40		50	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	60	60	60				
93	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	82	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	20	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	300	51		Gas Shortage	
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.	
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	350	250	350				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1114	1074	986	1086	51	907
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
106	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	11	28	15	40				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	20	20				
108	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	93	93	93	93				
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	13	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	33	16	33				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	16				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	580	599	580	600				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	765	671	789	789				
Khulna Zone Total						3241	3237	1478	1450	1613	1591	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	20	20	20				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	67	67	67	67	127		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	622	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	200	250	250				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1245	1162	1212	1212	127	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	16				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	52	92	90	92				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	40	40				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	25	38				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	242	218	300	300	196		Gas Shortage	
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35				
139	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1404	1423	1400	1400				
Rajshahi Zone Total						3653	3631	1814	2006	1974	2069	917	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	35	6	35				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	35				
148	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	27	0	130	0				
Rangpur Zone Total						1030	950	209	240	414	240	189	85
Sub-total: Plants in operation						26301	25481	91330	10276	10330	11175	5410	2399
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	20	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9133	10276	10330	11175	5410	2399
(C) Actual data of 21.01.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10276	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9714	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10276	MW, at =	20:00 hrs	Dhaka	3587	3587	0	Mymensingh	817	817	0
04.	Minimum Generation (Generation end)	:	6956	MW, at =	5:00 hrs	Chattogram	931	931	0	Sylhet	361	361	0
05.	Day-peak Generation (Generation end)	:	9133	MW, at =	12:00 hrs	Khulna	1157	1157	0	Barishal	303	303	0
06.	Evening-peak Generation (Generation end)	:	10276	MW, at =	20:00 hrs	Rajshahi	1005	1005	0	Rangpur	701	701	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	20:00 hrs	Cumilla	853	853	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6937	MW, at =	5:00 hrs	Total							
09.	Generation shortfall at evening peak due to :	:				Total							
	a) Gas/LF limitation	:	5221	MW		13.	Fuel cost :	(a) Gas = 214701518 Taka				(c) Coal = 567994403 Taka	
	d) Coal supply Limitation	:	189	MW	(b) Oil = 582583545 Taka				Total = 1365279466 Taka				
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2399	MW									
10.	Total Energy (Generation + India Import)	:	206.63	MKWh		14.	Maximum Temperature in Dhaka was : 23.6°C						
	By Gas = 67.523 MKWH			By Oil = 32.138 MKWh		15.	Export through East-West interconnections :						
	By Coal = 86.056 MKWH			By Hydro = 1.844 MKWh		At evening peak-hour : 9133 MW, at 20:00 hrs							
	By Solar= 1.124 MKWH					Maximum : 850 MW, at 19:30 hrs							
11.	Total Gas Supplied	:	599.60	MMCFD		Energy : 0 MKWh							
(D) Forecast of 22.01.24 (Today) Monday :													
01.	Maximum Demand	:	10800	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	11175	MW	(Generation end)	05.	Total Generation : 217.17 MKWh						
03.	Reserve / Shortage	:	375	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.3°C						

* Captive Power ** Imported Power
#Remarks: