

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Friday				Date : 02.02.24					
Probable Maximum Demand : 10300 MW						Probable Maximum Generation : 11091 MW									
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 87.39 ft		Today = 87.30 ft		Rule Curve = 96.86 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.02.24 (Yesterday)		02.02.24 (Today)		01.02.24 (Yesterday)		02.02.24 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW						
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage		
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI		
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired		
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0			412	Under maintenance		
12	Siddhirgonj 2'120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage		
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	186	171	160	160						
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	91	91	91						
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0						
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	40						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	21	30	30						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	72	17	105						
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	32	98						
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	281	80	130						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	45						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	17						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	54	54						
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	35	17						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	15	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17						
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	68	67	90	92						
34	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	82	51	100	100						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	19	85	85						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	25	25						
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
38	Meghnaghat Unique Power	Gas				0	0	0	0				Test run		
39	Meghnaghat 589 MW CCPP(Summit)	Gas				80	80	80	80				Test run		
Dhaka Zone Total				5655	5062	1469	1897	1687	1959	926	1152				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage		
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20						
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	31	17	17	17						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	206	220	220						
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	51	104	50	100						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25						
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	40	40						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	13	15	15						
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	14	30	30						
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17						
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	32	17	17	17						
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25						
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25						
58	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	13	17	17	17						
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	145	35	163						
60	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	490	462	470	470	762			Coal Shortage		
61	Matarbari 2'600 MW (CPGCL)	Coal		575	575	535	532	540	570				Test run		
62	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run		
Chattogram Zone Total				4404	4344	1660	1771	1672	1912	942	330				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	48	48	48						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1'75	221	221	152	154	155	155			67	Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360			Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	350	280	300	300	80			Gas Shortage		
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400			Gas Shortage		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	36	73	120	100	122			Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	16	6	20						
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	16	32	25	32						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	7	7						
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	0	15	15						
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0						
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	58	35	48						
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17						
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	18	0	17						
79	Ashugani 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	54	55	55						
80	Import (Tippura)	India		160	160	126	116	128	141						
Cumilla Zone Total				2959	2951	926	995	1030	1074	962	230				
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	71	35	70	131			Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0						
82	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9						
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	59	67	56	66						
84	Sariatbari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
85	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0						
86															

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.02.24 (Yesterday)		02.02.24 (Today)		01.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	30	30		60	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51				
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	59	60	60				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.	
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	15	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	23	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	341	285	310	310				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.	
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energypirima)	Gas (NENP)	12*3.3+5*2	50	50	47	47	50	50				
Sylhet Zone Total						2472	2427	1226	1171	1229	1229	0	1148
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	46	15	48				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	20	44				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	93	93	90	92				
110	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	58	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	748	731	600	600				
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	906	791	921	921				
Khulna Zone Total						3241	3237	1805	1717	1746	1737	410	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	6	2	10	10				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	70	100	135	135	94		Gas Shortage	
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	530	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	184	150	150				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	220	220				
Barishal Zone Total						2265	2265	1063	1066	1154	1207	94	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	32	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	16				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	90	50	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	11	40	0	33				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	25	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	295	414	414	119		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	1	12	35				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	767	766	760	760				
Rajshahi Zone Total						3653	3631	1341	1375	1385	1543	840	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	0	35	6	35				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	0	74				
150	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0				
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	140	0	130	0				
Rangpur Zone Total						1030	950	343	279	344	279	189	85
Sub-total: Plants in operation						26301	25481	9975.0	10424	10401	11091	4494	3045
(B) Plants under long term maintenance/ contract expired													
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
153	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
154	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	20	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9975	10424	10401	11091	4494	3045
(C) Actual data of 01.02.24 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	10424	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9833	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10424	MW, at =	19:00 hrs	Dhaka	3613	3613	0	Mymensingh	890	890	0
04.	Minimum Generation (Generation end)	:	6958	MW, at =	5:00 hrs	Chattogram	956	956	0	Sylhet	357	357	0
05.	Day-peak Generation (Generation end)	:	9975	MW, at =	12:00 hrs	Khulna	1144	1144	0	Barisal	267	267	0
06.	Evening-peak Generation (Generation end)	:	10424	MW, at =	19:00 hrs	Rajshahi	1034	1034	0	Rangpur	790	790	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	783	783	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7025	MW, at =	5:00 hrs					Total	9833	9833	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 284680554 Taka	(c) Coal = 545665493 Taka				
	a) Gas/LF limitation	:	4305	MW				(b) Oil = 4091950333 Taka	Total = 1239541080 Taka				
	d) Coal supply Limitation	:	189	MW		14.	Maximum Temperature in Dhaka was : 26.4°C						
	b) Low water level in Kaptai lake	:	0	MW		15.	Export through East-West interconnections :						
	c) Plants under shut down/ maintenance	:	3045	MW			At evening peak-hour	:	9975	MW, at	19:00 hrs		
10.	Total Energy (Generation + India Import)	:	221.07	MKWh			Maximum	:	340	MW, at	6:00 hrs		
	By Gas = 91.319 MKWH			By Oil = 22.307 MKWh			Energy	:	0	MKWh			
	By Coal = 80.383 MKWH			By Hydro = 1.104 MKWh									
	By Solar = 1.771 MKWH												
11.	Total Gas Supplied	:	732.50	MMCFD									
(D) Forecast of 02.02.24 (Today) Friday :													
01.	Maximum Demand	:	10300	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	11091	MW	(Generation end)	05.	Total Generation : 218.44 MKWh						
03.	Reserve / Shortage	:	791	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 26.4°C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation