

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Saturday				Date : 03.02.24					
Probable Maximum Demand : 10300 MW						Probable Maximum Generation : 11340 MW						Rule Curve = 96.72 ft.			
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 87.30 ft		Today = 87.18 ft.							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.02.24 (Yesterday)		03.02.24 (Today)		02.02.24 (Yesterday)		03.02.24 (Today)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
(A) Plants in operation:															
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365		Awaiting for HGPI	
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96				Gas Shortage	
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105				Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0					Contract Expired	
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	420	420	450						
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0			412		Under maintenance	
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210				Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	166	170	130	130						
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335				Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	64	58	92						
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0						
18	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	40						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	33	33						
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	32	30	30						
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16						
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	0	17	105						
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	98						
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17						
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	0	80	130						
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	19	35	45						
27	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	53	53						
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	35	17						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	0	17						
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	36	9	75	75						
34	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	30	9	93	100						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	81	17	85	85						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	0	25	25						
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
38	Meghnaghat Unique Power	Gas				0	0	0	0					Test run	
39	Meghnaghat 589 MW CCPP(Summit)	Gas				80	80	80	80					Test run	
Dhaka Zone Total				5655	5062	1318	1334	1555	1897	926	1152				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Gas Shortage	
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20						
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	206	204	220	220						
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	45	45	65	200						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25						
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	68	68	68						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	24	40	40						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	15	15						
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	108	108	34	42	10	25						
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	0	17						
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17						
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25						
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	0	25	25						
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	13	17	17	17						
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	53	34	145						
60	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	382	383	450	450	841				Coal Shortage	
61	Matarbari 2*600 MW (CPGCL)	Coal		575	575	537	567	600	600					Test run	
62	Cox's Bazar Wind PP	(Wind) (IPP)				7	0	10	10					Test run	
Chattogram Zone Total				4404	4344	1571	1591	1723	1999	1021	330				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	45	47	48	48						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	148	152	155	155			69		Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360				Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	285	300	300	75				Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400				Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	73	45	45	73	150				Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	13	25	43	43						
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	25	6	20						
67	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	25	25	32						
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163		Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17						
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18						
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	8	7	7						
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	15	15	15						
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	60	114						
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	39	57	35	48						
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17						
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	0	17						
79	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	47	55	55						
80	** Import (Tippura)	India		160	160										

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.02.24 (Yesterday)		03.02.24 (Today)		02.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance						
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date					
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)							
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.						
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.						
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	53	51	51									
90	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163									
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0									
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	59	60	60									
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.						
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	84	86	86									
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.						
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	20	20	20									
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10									
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16									
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	310	310									
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.						
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400									
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work						
103	Fenchuganj 44MW (Energypima)	Gas (NENP)	12*3.3+5*2	50	50	48	45	50	50									
Sylhet Zone Total						2472	2427	1232	1179	1239	1239	0	1148					
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0									
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage						
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	15	48									
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	0	20	40									
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0									
109	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	35	35	94	95									
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0									
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	64	0	100	0									
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0									
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16									
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	725	724	570	570									
115	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0									
**	Bheramara (HVDC)	India		1000	1000	903	794	923	923									
Khulna Zone Total						3241	3237	1749	1553	1722	1692	410	0					
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16									
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	10	10									
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	90	100	135	135	94		Gas Shortage						
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	530	622	622									
120	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	0	17	54									
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	307	307									
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	200	220	220									
Barishal Zone Total						2265	2265	901	1052	1311	1364	94	0					
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage						
b) Baghabari 100 MW GTPP	Gas (PDB)		1 x 100	100	100	0	0	0	0		100	Under maint.						
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	32	34									
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0									
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16									
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	50	50	92									
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	48	48	48									
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	42	42									
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	25	38									
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage						
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	370	325	414	414	89		Gas Shortage						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8									
136	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	8	0	8	8									
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	35									
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	6	0	0	35									
139	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	0	28	28									
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0									
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	624	713	760	760									
Rajshahi Zone Total						3653	3631	1110	1182	1421	1558	810	100					
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage						
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0		85	Under Overhauling						
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage						
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	6	42	6	35									
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0									
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	74									
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0									
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	134	0	130	0									
Rangpur Zone Total						1030	950	338	284	344	279	189	85					
Sub-total: Plants in operation						26301	25481	9253.0	9311	10484	11340	4563	3047					
(B) Plants under long term maintenance/ contract expired																		
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0									
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0									
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	20	0	0	0	0	0									
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0					
Gross Total						26504	25481	9253	9311	10484	11340	4563	3047					
(C) Actual data of 02.02.24 (Yesterday) Friday :																		
01.	Max. Demand at eve. peak (Generation end)	:	9311	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
02.	Max. Demand at eve. peak (Sub-station end)	:	8924	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
03.	Highest Generation (Generation end)	:	9578	MW, at =	13:00 hrs	Dhaka	3024	3024	0	Mymensingh	846	846	0					
04.	Minimum Generation (Generation end)	:	7025	MW, at =	5:00 hrs	Chattogram	934	934	0	Sylhet	341	341	0					
05.	Day-peak Generation (Generation end)	:	9253	MW, at =	12:00 hrs	Khulna	1074	1074	0	Barisal	266	266	0					
06.	Evening-peak Generation (Generation end)	:	9311	MW, at =	19:30 hrs	Rajshahi	935	935	0	Rangpur	707	707	0					
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Cumilla	797	797	0									
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6526	MW, at =	5:00 hrs					Total	8924	8924	0					
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 273937743 Taka		(c) Coal = 502332624 Taka								
a) Gas/LF limitation	:	4374	MW															
d) Coal supply Limitation	:	189	MW					(b) Oil = 327385086 Taka		Total = 1103655452 Taka								
b) Low water level in Kaptai lake	:	0	MW															
c) Plants under shut down/ maintenance	:	3047	MW		14.	Maximum Temperature in Dhaka was : 27.4°C												
10.	Total Energy (Generation + India Import)	:	202.98	MKWh		15.	Export through East-West interconnections :											
	By Gas = 88.028 MKWH			By Oil = 17.994 MKWh			At evening peak-hour		9253	MW, at	19:30 hrs							
	By Coal = 74.091 MKWH			By Hydro = 1.094 MKWh			Maximum		28	MW, at	7:00 hrs							
	By Solar = 1.752 MKWH						Energy		0	MKWh								
11.	Total Gas Supplied	:	707.81	MMCFD														
(D) Forecast of 03.02.24 (Today) Saturday :																		
01.	Maximum Demand	:	10300	MW	(Generation end)	04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	11340	MW	(Generation end)	05.	Total Generation		:	218.28	MKWh							
03.	Reserve / Shortage	:	1040	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :		:	26.4°C								