

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Wednesday				Date : 07.02.24			
Probable Maximum Demand : 11000 MW						Probable Maximum Generation : 12107 MW							
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 86.86 ft		Today = 86.66 ft		Rule Curve = 96.19 ft			
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.02.24 (Yesterday)		07.02.24 (Today)		06.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	190	190	190	190				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maintenance
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12			96	Gas Shortage
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	280	400			412	Under maintenance
12	Siddhirgonj 210 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	101	100	100			109	Gas Shortage
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0				
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	91	40	91				
17	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x8.73	80	80	41	41	41	41				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105				
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	98				
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	82	130				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	35	17	50				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	53				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	19	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	69	52	90	90				
34	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	92	8	85	85				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	72	80	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	13				
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
38	Meghnaghat Unique Power	Gas				0	0	0	0				Test run
39	Meghnaghat 589 MW CCPP(Summit)	Gas				80	120	370	370				Test run
Dhaka Zone Total				5655	5062	1316	1762	2028	2577	645	1342		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46				
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
44	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	5	19	6	19				
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	17	17	17				
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
49	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	204	205	205				
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	49	104	50	100				
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
52	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68				
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	8	8				
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	15	15	18				
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	21	7	15				
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	0				
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	10	17	17	17				
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	17				
63	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	300	400	0	0			824	Coal Shortage
64	Matarbari 21600 MW (CPGCL)	Coal	1x575	575	575	571	568	0	570				
65	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				Test run
Chattogram Zone Total				4404	4344	1450	1733	574	1219	1004	330		
66	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	30	44	20	20				
67	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1175	221	221	147	154	150	150			67	Under Maint.
68	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	84	140	300	300			220	Gas Shortage
69	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	270	280	280	280			80	Gas Shortage
70	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0			400	Gas Shortage
71	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	2019.73+1116	195	195	0	0	8	8			195	Gas Shortage
72	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
73	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	26	6	25				
74	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	41	40	40				
75	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.
76	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
77	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	13	16	16				
78	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9				
79	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
80	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
81	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	17	15	15				
82	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	114	114	114	114				
83	Chowmuhani 113 MW	HFO (IPP)	1219.78+213.1	113	113	28	57	9	57				
84	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17				
85	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	18	0	17				
86	Ashugani 55 MW PP (Precision)	Gas (RPP)	154	55	55	10	25	10	25				
87	** Import (Tijura)	India		160	160	118	122	128	141				
Cumilla Zone Total				2959	2951	998	1161	1223	1335	895	230		
88	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	75	35	75			127	Gas Shortage
89	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
90	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9				
91	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	67	56	66				
92	Sariatbari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
93	Sutahkhal 50 MW Solar PP												

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.02.24 (Yesterday)		07.02.24 (Today)		06.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	40	30	30		50	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	52	60	60	60					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	143	145	150	150					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	24	24	24					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	325	310	320	320					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	135	135		400	Under maint.		
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	370	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	48	50	50					
Sylhet Zone Total						2472	2427	1361	1382	1492	1522	0	907	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	52	15	53					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	16	83	60	84					
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	36	17	75					
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	48	0	100	0					
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8					
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	358	358	350	350					
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	906	798	924	924					
Khulna Zone Total						3241	3237	1345	1335	1466	1494	410	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	8	10	10					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	130	130	130	64		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	910	1200	1240					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	108	115	115					
Barishal Zone Total						2265	2265	1049	1426	1672	1765	64	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	25	25					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	13	0	15					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	91	50	90					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	48	50					
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	34	42					
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	25	38					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	159	220	220	61		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	407	378	414	414					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	8	8					
137	Natore 52 MW PP (Rajshahi)	HFO (IPP)	6x8.92	52	52	8	0	0	0					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	0	35					
140	Annura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28					
141	Sirajgoni 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	773	765	760	760					
Rajshahi Zone Total						3653	3631	1525	1655	1618	1760	562	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	35	6	35					
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	3	0	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	74					
149	Lalmohinat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	17	0	30	0					
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	80	0	130	0					
Rangpur Zone Total						1030	950	276	277	344	279	189	85	
Sub-total: Plants in operation						26301	25481	9431.0	10888	10571	12107	3896	2994	
(B) Plants under long term maintenance/ contract expired														
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0	
Gross Total						26504	25481	9431	10888	10571	12107	3896	2994	
(C) Actual data of 06.02.24 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10888	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10308	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10888	MW, at =	19:00 hrs									
04.	Minimum Generation (Generation end)	:	6988	MW, at =	5:00 hrs		Dhaka	3853	3853	0	Mymensingh	862	862	0
05.	Day-peak Generation (Generation end)	:	9431	MW, at =	12:00 hrs		Chattogram	997	997	0	Sylhet	370	370	0
06.	Evening-peak Generation (Generation end)	:	10888	MW, at =	19:00 hrs		Khulna	1196	1196	0	Barishal	291	291	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs		Rajshahi	1059	1059	0	Rangpur	797	797	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7294	MW, at =	5:00 hrs		Cumilla	883	883	0				
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	a) Gas = 303899762 Taka	(c) Coal = 515623371 Taka				
	a) Gas/LF limitation	:	3707	MW					b) Oil = 404372730 Taka	Total = 1223895863 Taka				
	d) Coal supply Limitation	:	189	MW										
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2994	MW										
10.	Total Energy (Generation + India Import)	:	218.08	MKWh			14.	Maximum Temperature in Dhaka was : 25.4°C						
	By Gas = 98.418 MKWh			By Oil = 22.001 MKWh			15.	Export through East-West interconnections :						
	By Coal = 77.546 MKWh			By Hydro = 1.102 MKWh				At evening peak-hour	:	9431	MW, at	19:00 hrs		
	By Solar= 1.373 MKWh							Maximum	:	840	MW, at	7:00 hrs		
								Energy	:	0	MKWh			
11.	Total Gas Supplied	:	819.60	MMCFD										
(D) Forecast of 07.02.24 (Today) Wednesday :														
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	12107	MW	(Generation end)	05.	Total Generation : 220.33 MKWh							
03.	Reserve / Shortage	:	1107	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 28.1°C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00
(Md. Helalur Rahman)
Deputy Secretary, Generation