

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Thursday				Date : 08.02.24			
Probable Maximum Demand : 11200 MW						Probable Maximum Generation : 12615 MW							
Water Level of Kaptai Lake at 06:00 AM						Rule Curve = 96.02 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.02.24 (Yesterday)		08.02.24 (Today)		07.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW				
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	190	200	200				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maintenance	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	40	0	280	400		412	Under maintenance	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	99	62	100	100	148		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0				
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	91	40	91				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	41	41	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	22	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	149	16	132				
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	75	82	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	35	17	50				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	51	17	53				
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17				
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	67	8	90	90				
33	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	100	43	85	100				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	4	0	0	13				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas				0	0	0	0			Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				340	300	370	370			Test run	
Dhaka Zone Total				5655	5062	1716	1874	2038	2651	684	1342		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	205	204	205	205				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	50	105	50	100				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	16	8	16				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	18	18				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	20	15	20				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	0				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	145				
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	0	0	0	0	1224		Coal Shortage	
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	566	156	570				
	Cox's Bazar Wind PP	(Wind) (IPP)				0	3	10	10			Test run	
Chattogram Zone Total				4404	4344	552	1327	716	1335	1404	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	144	152	150	150		69	Under Maint.	
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	290	290	360	360	70		Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	350	280	360	360	80		Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	15	6	25				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	41	33	40	40				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	16	16				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9				
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	16	15	15				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	114	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	30	57	9	57				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	0	17	17				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	37	0	37				
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0				
**	Import (Tippura)	India		160	160	128	130	128	141				
Cumilla Zone Total				2959	2951	1247	1252	1338	1455	745	232		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	36	35	75	166		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	67	56	66				
85	Sariatbari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.02.24 (Yesterday)		08.02.24 (Today)		07.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	0	0	51	51					
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	0	30	30					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	145	145	150	150					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	25	24	24					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	305	320	320					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	135	150	315	315					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	390	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	50	50					
Sylhet Zone Total						2472	2427	1324	1281	1606	1616	0	507	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	8	53	15	53					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	56	50	60	84					
109	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	75	17	75					
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	61	0	100	0					
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8					
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	357	359	360	360					
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	906	799	924	924					
Khulna Zone Total						3241	3237	1405	1336	1476	1504	410	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	10	10					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	125	130	130	130		64	Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1200	1000	1200	1240					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	54					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	200	200					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	110	115	115					
Barishal Zone Total						2265	2265	1716	1516	1672	1765	64	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	25	25					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	15					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	91	50	90					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	49	48	50					
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	34	42					
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	4	32	25	38					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	178	173	220	220		47	Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	0	0					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	8	8					
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	0	35					
140	Annura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	14	28	28					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	752	1020	1260	1260					
Rajshahi Zone Total						3653	3631	1463	1907	1712	1854	548	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage		
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	35	6	35					
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	0	74					
149	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0					
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	172	0	130	0					
Rangpur Zone Total						1030	950	386	275	344	279	189	85	
Sub-total: Plants in operation						26301	25481	9964.0	10886	11056	12615	4210	2596	
(B) Plants under long term maintenance/ contract expired														
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Bosila 108MW PP(QCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0	
Gross Total						26504	25481	9964	10886	11056	12615	4210	2596	
(C) Actual data of 07.02.24 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10980	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10488	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10886	MW, at =	19:00 hrs									
04.	Minimum Generation (Generation end)	:	7294	MW, at =	5:00 hrs		Dhaka	3851	3843	8	Mymensingh	945	863	82
05.	Day-peak Generation (Generation end)	:	9964	MW, at =	12:00 hrs		Chattogram	1045	1045	0	Sylhet	364	364	0
06.	Evening-peak Generation (Generation end)	:	10886	MW, at =	19:00 hrs		Khulna	1219	1219	0	Barishal	278	278	0
07.	Evening Peak Load-shed (Sub-station end)	:	90	MW, at =	19:00 hrs		Rajshahi	1099	1099	0	Rangpur	790	790	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7297	MW, at =	5:00 hrs		Cumilla	897	897	0				
09.	Generation shortfall at evening peak due to :	:					Total		10488	10398	90			
	a) Gas/LF limitation	:	4021	MW			13. Fuel cost :		(a) Gas = 299483044 Taka	(c) Coal = 469174515 Taka				
	d) Coal supply Limitation	:	189	MW					(b) Oil = 408911719 Taka	Total = 1177569278 Taka				
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2596	MW										
10.	Total Energy (Generation + India Import)	:	222.45	MKWh			14. Maximum Temperature in Dhaka was :		26.3°C					
	By Gas =	103.984	MKWh	By Oil =	22.207	MKWh	15. Export through East-West interconnections :							
	By Coal =	70.341	MKWh	By Hydro =	1.113	MKWh	At evening peak-hour		:	9964	MW, at	19:00 hrs		
	By Solar=	2.349	MKWh				Maximum		:	950	MW, at	5:00 hrs		
11.	Total Gas Supplied	:	849.76	MMCFD			Energy		:	0	MKWh			
(D) Forecast of 08.02.24 (Today) Thursday :														
01.	Maximum Demand	:	11200	MW	(Generation end)	04.	Maximum Load-shed							
02.	Maximum Generation	:	12615	MW	(Generation end)	05.	Total Generation							
03.	Reserve / Shortage	:	1415	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :							
* Captive Power ** Imported Power														

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation