

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Saturday				Date : 10.02.24							
Probable Maximum Demand : 10800 MW						Probable Maximum Generation : 12455 MW											
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 86.43 ft				Today = 86.33 ft				Rule Curve = 95.74 ft			
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.24 (Yesterday)		10.02.24 (Today)		09.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Day	Evening	Day	Evening				
(A) Plants in operation:																	
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work				
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	130	190	190								
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maintenance				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12			96	Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0								
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	0	0								
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling				
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	342	400	350	400								
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	335	335								
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	0	15	30								
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	40	91								
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0								
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	39	24	41	41								
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33								
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	16	33	33								
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	0	8	17								
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	17	105								
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	16	132								
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17								
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	82	130								
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	19	17	50								
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17								
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35								
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	3	17	53								
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	17	35								
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0								
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	17								
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90								
33	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	0	0	85	100								
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	80	80								
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	13								
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
	Meghnaghat Unique Power	Gas				0	0	0	0				Test run				
	Meghnaghat 589 MW CCPP(Summit)	Gas				320	100	100	100				Test run				
Dhaka Zone Total				5655	5062	1416	1245	1613	2156	746	930						
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46								
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.				
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0								
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17								
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0								
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	19								
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	17	17								
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.				
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	210	205	205								
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	50	116								
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	25	25								
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	51	68								
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	8	16								
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18								
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			31	30	42	42								
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0								
52	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	0								
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	10	17	17								
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	25	25								
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0								
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17								
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	17	145								
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	0	305	305	305								
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	561	565	0	0								
	Cox's Bazar Wind PP	(Wind) (IPP)				28	32	10	10				Test run				
Chattogram Zone Total				4404	4344	920	1233	892	1108	180	330						
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	10	30	30								
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	141	156	150	160			65	Under Maint.				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	270	300	300			90	Gas Shortage				
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	300	300	300								
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0			400	Gas Shortage				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	8	8			195	Gas Shortage				
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43								
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	13	25								
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	40	40								
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	17	17								
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	16	16								
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10								
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33								
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	8	8								
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	16	15	15								
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114								
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	55	9	57								
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17								
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	1	38	0	37								
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	22	10	17	24								
**	Import (Tippura)	India		160	160	108	106	128	141								
Cumilla Zone Total				2959	2951	961	1065	1268	1395	685	228						
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	73	88	88			129	Gas Shortage				
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0								

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.02.24 (Yesterday)		10.02.24 (Today)		09.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	24	35	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)		11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	20	20	20				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	14	0	24	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	320	320				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	316	315	315				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	390	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1304	1372	1436	1446	0	507
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	15	53				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	84				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	94				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	356	360	360	360				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	898	794	917	917				
Khulna Zone Total						3241	3237	1345	1154	1469	1516	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	10	10				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	66	130	130	128		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	700	680	1200	1240				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	200	200				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1139	1122	1777	1870	128	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	48	50				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	140	195	180	200				
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	193	180	200				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	414	350	414				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	0	35				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	901	924	1300	1300				
Raishahi Zone Total						3653	3631	1506	1731	2217	2508	281	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	0	6	42				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	0	74				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	160	0	130	0				
Rangpur Zone Total						1030	950	365	205	344	286	189	85
Sub-total: Plants in operation						26301	25481	9108.0	9282	11223	12455	2748	2180
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9108	9282	11223	12455	2748	2180

(C) Actual data of 09.02.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	9345	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8942	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9670	MW, at =	13:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7165	MW, at =	5:00 hrs	Dhaka	2948	2948	0	Mymensingh	890	830	60
05.	Day-peak Generation (Generation end)	:	9108	MW, at =	12:00 hrs	Chattogram	840	840	0	Sylhet	354	354	0
06.	Evening-peak Generation (Generation end)	:	9282	MW, at =	19:00 hrs	Khulna	1122	1122	0	Barishal	267	267	0
07.	Evening Peak Load-shed (Sub-station end)	:	60	MW, at =	19:00 hrs	Rajshahi	1008	1008	0	Rangpur	714	714	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6604	MW, at =	5:00 hrs	Cumilla	799	799	0				
09.	Generation shortfall at evening peak due to :	:								Total	8942	8882	60
a)	Gas/LF limitation	:	2559	MW		13.	Fuel cost :	(a) Gas = 303748880 Taka		(c) Coal = 467182188 Taka		Taka	
d)	Coal supply Limitation	:	189	MW				(b) Oil = 50953846 Taka		Total = 821884915 Taka		Taka	
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2180	MW		14.	Maximum Temperature in Dhaka was : 26.4°C						
10.	Total Energy (Generation + India Import)	:	202.31	MKWh		15.	Export through East-West interconnections :						
	By Gas = 104.884 MKWH			By Oil = 3.037 MKWh			At evening peak-hour : 9108 MW, at 19:00 hrs						
	By Coal = 69.891 MKWH			By Hydro = 1.102 MKWh			Maximum : 670 MW, at 7:00 hrs						
	By Solar = 2.524 MKWH						Energy : 0 MKWh						
11.	Total Gas Supplied	:	789.19	MMCFD									

(D) Forecast of 10.02.24 (Today) Saturday :												
01.	Maximum Demand	:	10800	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	12455	MW	(Generation end)	05.	Total Generation : 225.95 MKWh					
03.	Reserve / Shortage	:	1655	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 26.4°C					

* Cative Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation