

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Sunday				Date : 11.02.24				
Probable Maximum Demand : 11000 MW						Probable Maximum Generation : 12377 MW								
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 86.33 ft		Today = 86.11 ft		Rule Curve = 95.60 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.02.24 (Yesterday)		11.02.24 (Today)		10.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	190	190	190					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maintenance		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	415	380	400	400					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	300	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	41	50	40	91					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	32	41	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	15	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	82	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	132					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	82	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	26	35	17	50					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	53					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	55	90	90					
33	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	0	36	50	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	68	80	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	13					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0			Test run		
	Meghnaghat 589 MW CCPP(Summit)	Gas				100	150	115	150			Test run		
Dhaka Zone Total				5655	5062	1336	1758	1643	2211	746	930			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	16	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	15	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	212	205	205					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	15	50	50	150					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	68					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	18	18					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	27	42	42					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	108	17	145					
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	280	280	305	305					
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				7	6	10	10			Test run		
Chattogram Zone Total				4404	4344	756	948	884	1143	180	330			
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	5	30	30					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	149	155	0	150		66	Under Maint.		
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	270	300	300	90		Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	335	290	330	330					
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	8	8	195		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	28	13	28					
68	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	25	40	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	52	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	44	38	57					
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x5.428	115	115	0	38	0	37					
80	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	13	0	17	24					
**	Import (Tippura)	India		160	160	118	114	128	141					
Cumilla Zone Total				2959	2951	1115	1196	1177	1418	685	229			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	60	70	88	88	132		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	58	69	56	67					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	9	9					
85	Sariatshani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	2	6					
Mymensingh Zone Total				622										

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.02.24 (Yesterday)		11.02.24 (Today)		10.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40	50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51			
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	163	163			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	56	0	0			
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0			
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	120	120			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	20	0	0			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	320	320			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	305	304	315	315			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	340	390	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0			
Sylhet Zone Total					2472	2427	1406	1300	1476	1486	0	507
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	15	53			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	60	84			
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	90	17	94			
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0			
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	360	361	360	360			
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	901	796	917	917			
Khulna Zone Total					3241	3237	1360	1277	1469	1516	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	10	10			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65	129	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	660	1030	1200	1240			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	63	17	63			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	227	200	225			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	200	220			
Barishal Zone Total					2265	2265	1099	1628	1692	1839	129	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	19	25	25			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	7	0	15			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	82	50	90			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	48	50			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	42			
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	38			
132	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	140	0	0	0	220	Gas Shortage	
134	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	141	200	200	79	Gas Shortage	
135	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	300	350	414	114	Gas Shortage	
136	Ulapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	8	8			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	54	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	11	35			
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1111	1345	1300	1300			
Raishahi Zone Total					3653	3631	1754	2087	2068	2308	694	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	47	6	42			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	50	0	74			
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	180	0	130	0			
Rangpur Zone Total					1030	950	390	267	344	286	189	85
Sub-total: Plants in operation					26301	25481	9394.0	10615	10960	12377	3165	2181

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					203	0	0	0	0	0	0	
Gross Total					26504	25481	9394	10615	10960	12377	3165	2181

(C) Actual data of 10.02.24 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	10645	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	10283	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	10615	MW, at =	19:00 hrs	Dhaka	3705	3705	0	Mymensingh	925	905
04.	Minimum Generation (Generation end)	:	6604	MW, at =	5:00 hrs	Chattogram	1002	1002	0	Sylhet	383	383
05.	Day-peak Generation (Generation end)	:	9394	MW, at =	12:00 hrs	Khulna	1239	1230	9	Barishal	285	285
06.	Evening-peak Generation (Generation end)	:	10615	MW, at =	19:00 hrs	Rajshahi	1091	1091	0	Rangpur	768	768
07.	Evening Peak Load-shed (Sub-station end)	:	29	MW, at =	19:00 hrs	Cumilla	886	886	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7140	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	10283	10254
a)	Gas/LF limitation	:	2976	MW		13.	Fuel cost :	(a) Gas = 296831849 Taka	(c) Coal = 515679912 Taka			
d)	Coal supply Limitation	:	189	MW				(b) Oil = 201935701 Taka	Total = 1014447462 Taka			
b)	Low water level in Kaptai lake	:	0	MW								
c)	Plants under shut down/ maintenance	:	2181	MW								
10.	Total Energy (Generation + India Import)	:	212.91	MKWh		14.	Maximum Temperature in Dhaka was :	27.4°C				
	By Gas = 100.597 MKWH			By Oil = 11.392 MKWh		15.	Export through East-West interconnections :					
	By Coal = 76.158 MKWH			By Hydro = 1.082 MKWh			At evening peak-hour	:	9394	MW, at	19:00 hrs	
	By Solar = 2.560 MKWH						Maximum	:	670	MW, at	7:00 hrs	
							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	794.73	MMCFD								

(D) Forecast of 11.02.24 (Today) Sunday :												
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12377	MW	(Generation end)	05.	Total Generation	:	220.63	MKWh		
03.	Reserve / Shortage	:	1377	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	22.6°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation