

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024					Day : Monday				Date : 12.02.24				
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 12383 MW					Rule Curve = 95.46 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 86.11 ft		Today = 85.99 ft						
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.02.24 (Yesterday)		12.02.24 (Today)		11.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	130	180	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maintenance	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	430	412	412				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	270	335	335				
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	91	40	91				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	33	41	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	132				
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	60	60	82	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	30	116	35	149				
26	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17				
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	60	60	90	90				
33	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	46	74	50	100				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	80	80	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas				0	0	0	0			Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				67	50	120	60			Test run	
Dhaka Zone Total				5655	5062	1490	1806	1668	2198	746	930		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	16	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	210	210				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	115	65	150				
47	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	18	18				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	13	2	20				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	0				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	0	0	0				
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	145				
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	375	527	400	550				
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				0	1	10	10			Test run	
Chattogram Zone Total				4404	4344	942	1280	976	1354	180	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	44	25	44				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	0	152	150	150				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	270	300	300	90		Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	330	330				
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0	400		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	22	13	28				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	32	40	40				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	16	16				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10				
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	13	15	15				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	88	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	62	38	57				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	37				
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	46	52	0	0				
**	Import (Tripura)	India		160	160	118	116	128	141				
Cumilla Zone Total				2959	2951	1080	1319	1297	1400	677	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	70	35	70	132		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	69	57	69				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	9	9				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3								

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.02.24 (Yesterday)		12.02.24 (Today)		11.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	43	43	28	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40	51	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	51	51			
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	120	0	0			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	60	60			
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0			
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	116	65	120			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	8	24	24			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	320	320			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	305	219	300	300			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	340	390	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	20	20			
Sylhet Zone Total					2472	2427	1360	1184	1323	1388	0	509
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	15	53			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	47	60	84			
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	42	55	55	55			
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	80	0	100	0			
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	354	359	360	360			
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	908	908	925	925			
Khulna Zone Total					3241	3237	1384	1369	1515	1485	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	10	10			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	0	65	65	194	Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1010	960	1200	1240			
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	63			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	168	150	250	250			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	54	180	200	220			
Barishal Zone Total					2265	2265	1318	1367	1742	1864	194	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	25	25			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	15			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	83	50	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	2	48	48	50			
130	Katakali 50 MW PP (Northern)	HFO (QRP)	6x8.9	50	50	8	8	34	42			
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	30	0	38			
132	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	178	156	160	180	64	Gas Shortage	
135	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	300	350	380	114	Gas Shortage	
136	Ulapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	8	8			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	11	35			
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	14	0	28	28			
141	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1206	1211	1300	1300			
Raishahi Zone Total					3653	3631	1929	1888	2028	2254	679	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	35	6	42			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	74			
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	163	0	130	0			
Rangpur Zone Total					1030	950	380	277	344	286	189	85
Sub-total: Plants in operation					26301	25481	10031.0	10644	11048	12383	3207	2117

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					203	0	0	0	0	0	0	
Gross Total					26504	25481	10031	10644	11048	12383	3207	2117

(C) Actual data of 11.02.24 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	10740	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10305	MW, at =	19:00 hrs	Zone						
03.	Highest Generation (Generation end)	:	10644	MW, at =	19:00 hrs	Demand MW Supply MW Load Shed MW Zone Demand MW Supply MW Load Shed MW						
04.	Minimum Generation (Generation end)	:	7140	MW, at =	5:00 hrs	Dhaka 3780 3780 0 Mymensingh 971 879 92						
05.	Day-peak Generation (Generation end)	:	10031	MW, at =	12:00 hrs	Chattogram 989 989 0 Sylhet 379 379 0						
06.	Evening-peak Generation (Generation end)	:	10644	MW, at =	19:00 hrs	Khulna 1207 1207 0 Barishal 286 286 0						
07.	Evening Peak Load-shed (Sub-station end)	:	92	MW, at =	19:00 hrs	Rajshahi 1041 1041 0 Rangpur 771 771 0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7115	MW, at =	5:00 hrs	Cumilla 881 881 0						
09.	Generation shortfall at evening peak due to :	:				Total 10305 10213 92						
	a) Gas/LF limitation	:	3018	MW		13. Fuel cost : (a) Gas = 294028733 Taka (c) Coal = 526977050 Taka						
	d) Coal supply Limitation	:	189	MW		(b) Oil = 326601112 Taka Total = 1147606896 Taka						
	b) Low water level in Kaptai lake	:	0	MW								
	c) Plants under shut down/ maintenance	:	2117	MW		14. Maximum Temperature in Dhaka was : 28.6°C						
10.	Total Energy (Generation + India Import)	:	221.82	MKWh		15. Export through East-West interconnections : At evening peak-hour : 10031 MW, at 19:00 hrs Maximum : 670 MW, at 7:00 hrs Energy : 0 MKWh						
	By Gas = 100.020 MKWH			By Oil = 18.048 MKWh								
	By Coal = 77.449 MKWH			By Hydro = 1.081 MKWh								
	By Solar = 2.541 MKWH											
11.	Total Gas Supplied	:	787.02	MMCFD								

(D) Forecast of 12.02.24 (Today) Monday :												
01.	Maximum Demand	:	11500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12383	MW	(Generation end)	05.	Total Generation	:	239.66	MKWh		
03.	Reserve / Shortage	:	883	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	28.6°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation