

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024						Day : Tuesday				Date : 13.02.24				
Probable Maximum Demand : 11300 MW						Probable Maximum Generation : 12276 MW								
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 85.99 ft		Today = 85.84 ft		Rule Curve = 95.32 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.24 (Yesterday)		13.02.24 (Today)		12.02.24 (Yesterday)		13.02.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	180	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maintenance	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12		96		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	390	104	412	412					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	62	105	105		148		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	83	40	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	34	34	41	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	32	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	98					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	62	82	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	24	142	17	51					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	0	17	17					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	30	84	60	60					
33	Meghnaghat 100 MW(IECL)	HFO (NENP)	12x8.9	100	100	54	90	100	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	50	65	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0				Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				100	38	340	340				Test run	
Dhaka Zone Total				5655	5062	1438	1686	2000	2389	684	930			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	211	211	210	210					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	128	60	150					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	18	18					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			12	20	2	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	0					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	25	25	25					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	145					
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	498	540	550	550					
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				6	10	20	20				Test run	
Chattogram Zone Total				4404	4344	1023	1314	1156	1372	180	330			
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	28	35	25	35					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	151	151	150	150					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	280	280			120	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	285	280	280			75	Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0			400	Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0			195	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	18	13	28					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	32	40	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	30	17	17	17					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	16	16					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	13	15	15					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	60	114	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	18	78	48	65					
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	40	0	36					
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0					
**	Imphorti (Tripura)	India		160	160	126	108	128	141					
Cumilla Zone Total				2959	2951	1094	1257	1237	1328	790	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x7											

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.02.24 (Yesterday)		13.02.24 (Today)		12.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	43	43		28	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	59	60	60				
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	121	207	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	20	16	20	20				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	12	24	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	320	320				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	250	309	300	310				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	340	390	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	20	20	20	20				
Sylhet Zone Total						2472	2427	1318	1388	1488	1508	0	508
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	50	0	55				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	94	74				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	359	0	0	0				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	907	624	926	926				
Khulna Zone Total						3241	3237	1377	709	1120	1055	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	7	10	10				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	70	70	194		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1040	1210	1200	1240				
121	Potuaikhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	307	307	307				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	180	200	220				
Barishal Zone Total						2265	2265	1460	1870	1822	2013	194	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	8	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	82	50	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	48	48	50				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	25	34	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	164	160	180	56		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	380	350	380				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	54	35	35				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	35	35	0				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1211	1305	1300	1300				
Raishahi Zone Total						3653	3631	1807	2168	2079	2199	557	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	34	6	34				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	74				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	170	0	130	0				
Rangpur Zone Total						1030	950	387	276	344	278	189	85
Sub-total: Plants in operation						26301	25481	10051.0	10798	11394	12276	3160	2116
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0		0	0	
Gross Total						26504	25481	10051	10798	11394	12276	3160	2116

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0	
Gross Total				26504	25481	10051	10798	11394	12276	3160	2116	

(C) Actual data of 12.02.24 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	10900	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	10417	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	10798	MW, at =	19:00 hrs	Dhaka	3840	3840	0	Mymensingh	954	857
04.	Minimum Generation (Generation end)	:	7115	MW, at =	5:00 hrs	Chattogram	989	989	0	Sylhet	373	373
05.	Day-peak Generation (Generation end)	:	10051	MW, at =	12:00 hrs	Khulna	1209	1209	0	Barishal	285	285
06.	Evening-peak Generation (Generation end)	:	10798	MW, at =	19:00 hrs	Rajshahi	1101	1101	0	Rangpur	777	777
07.	Evening Peak Load-shed (Sub-station end)	:	97	MW, at =	19:00 hrs	Cumilla	890	890	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7288	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	10417	10320
a)	Gas/LF limitation	:	2971	MW		13.	Fuel cost :	(a) Gas = 297477896 Taka	(c) Coal = 527256769 Taka			
d)	Coal supply Limitation	:	189	MW				(b) Oil = 365428458 Taka	Total = 1190163122 Taka			
b)	Low water level in Kaptai lake	:	0	MW								
c)	Plants under shut down/ maintenance	:	2116	MW		14.	Maximum Temperature in Dhaka was :	29.3°C				
10.	Total Energy (Generation + India Import)	:	222.25	MKWh		15.	Export through East-West interconnections :					
	By Gas = 99.819 MKWH			By Oil = 20.180 MKWh			At evening peak-hour	:	10051	MW, at	19:00 hrs	
	By Coal = 77.537 MKWH			By Hydro = 1.080 MKWh			Maximum	:	1000	MW, at	7:00 hrs	
	By Solar = 2.543 MKWH						Energy	:	0	MKWh		
11.	Total Gas Supplied	:	787.09	MMCFD								

(D) Forecast of 13.02.24 (Today) Tuesday :												
01.	Maximum Demand	:	11300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12276	MW	(Generation end)	05.	Total Generation	:	232.58	MKWh		
03.	Reserve / Shortage	:	976	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	29.3°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation