P				POWER GRID COMPAN NATIONAL LOAD	Y OF BANG DESPATCH	LADESH LTD. CENTER				
				DAILY	REPORT			Reporting Date :	14-Feb-24	
Till now the maximum	generation is : - day's			Material Memory (Material Memory Memo		12:00	Today's Actual Min Gen. & Pro			7431
Day Peak Generation : Evening Peak Generation : E.P. Demand (at gen end) : Maximum Generation :			10295.0 MW 10836.0 MW 10930.0 MW 10836.0 MW	/ Hour : / Hour :		12:00 19:00 19:00 19:00	Min. Gen. at Available Max Generation Max Demand (Evening) : Reserve(Generation end)	4:00		12246 11000 1246
Total Gen. (MKWH) :			227.293 EXPOI	System Load Fa RT / IMPORT THROUGH EAST-WEST INTER	RCONNECTO	87.40% DR	Load Shed :			0
Export from East grid to We Import from West grid to Ea	st grid :- Maximum	Kaptai Lake at 6:00 A M on	14-	- Feb-24	960	MW at MW at	7:00	Energy Energy		
Actual :		85.72 Ft.(N	MSL),	Ru	tule curve :	95.18	Ft.(MSL)			
Gas Consumed :		Total =	836.27 MM	ICFD.		Oil Consumed (PDI	в):	HSD : FO :		
Cost of the Consumed Fuel :	(PDB+Pvt):		Gas : Coal :	Tk316,659,614 Tk503,648,518		Oil	: Tk414,165,984	Total :	Tk1,234,474,115	
		Load	Shedding & Other Informat	tion						
Area		Yesterday		Estimated Demand (S/S end)			Today Estimated Shedding (S/S end)		Rates of Shedding	
Dhaka Chittagong Area		MW 0	0:00	MW 3823 1046				0	(On Estimated Demand) 0%	
Chittagong Area Khulna Area Rajshahi Area		0 0 0	0:00 0:00 0:00	1046 1464 1271				0 0 0	0% 0% 0%	
Cumilla Area Mymensingh Area		0 90	0:00 0:00	1046 778				0	0% 0%	
Sylhet Area Barisal Area Bangarur Area		0	0:00 0:00 0:00	437 363 710				0	0% 0% 0%	
Rangpur Area Total		90		10938				0	0.8	
		Information of the Generatin	g Units under shut down.			Forced Shut-Dow	vn			
						1) Barapukuria ST: 2) Ghorasal-3,5,7 3) Shajibazar 330 N 4) Baghabari-71,10t 5) Raozan unit-2 6) Siddhiroani 210 N 7) Ashuoani East 8) Megnaghat-450 I	Ünit- 1,2 IW D MW			
Outage	Restore	Additional Info	rmation of Machines, lines	, Interruption / Forced Load shed etc.						Remark
08:02	17:23	Ishurdi 132/33kV S/S 132 kV Bagi								
08:09	18:08	Fenchuganj 230/132/33kV S/S AT								
08:18	14:54	Munshigani 132/33kV S/S Sinha F Annual Maintenance.	Peoples Energy Limited (SPE)	L) 52.5 MW IPP Scheduled S/D Due to						
08:20	18:19	Mirpur 132/33kV S/S T3 HT Scheduled S/D Due to T-3, Annual maintenance work .								
08:27 08:32	12:55 16:35	Chattak-Sylhet 132 kV Ckt-1 Sche Hasnaharl-Keranigani 230kV Ckt-		3kV end Due to maintenance bad 230/132kV end Due to Shvampur-Magnagha						
		one ckt shutdown. Probability is h	nigh other ckt Overloaded. So	Hasnabad-Keranigani both ckt CB off at Hasnab	bad end.					
08:33	16:37			bad 230/132kV end Due to Shvamour-Magnagha snabad-Keranigani both ckt CB off at Hasnabad e						
08:40		AKSML-Baroaulia 132kV Ckt-1 Sc 132/33kV end Due to AKSPL to B		132/33kV end Due to Annual maintenance and fro Shutdown.	rom AKS					
08:46	11:25	Cumilla(N)-Cumilla(S) 132 kV Ckt-1 Project Work S/D from Cumilla(S) 132/33kV end.								
08:55 08:55	17:14	Ishurdi 230/132kV S/S 230/132 kV		200/400ls/ and Durate Malatanass of						
		Meghnaghat-Shyampur 230kV Ckt-2 Forced S/D from Shyampur 230/132kV end Due to Maintenance of Meghnaghat ckt-2 End								
08:55 08:55	13:12 17:14	Ishurdi 230/132kV S/S 230 kV Bus 1 Scheduled S/D Due to Annual Maintenance Ishurdi 230/132kV S/S 230/132 kV T-03 HT Scheduled S/D								
08:58	16:48	Ishurdi 230/132kV S/S 230/132 kV T-03 HT Scheduled S/D Keranigani-Nawabgani 132kV Ckt-1 Scheduled S/D from Nawabgani 132/33kV end Due to Deadline checking/annual								
09:02	Netfandam-kwakodam 152KY CAL-1 Schedued son in tifin kwakodam 1,32KK CAL Due to Deadline checkminal maintenance) and form Keranjoon (200152733K) end Due to Dead line checkmin from Nawabpart of 16:21 Haripur-Sonargaon 132KV Ckt-2 Scheduled S/D from Sonargaon 132/38KV end Due to Annual maintenance de									
09:34	18:01	checking, Shutdown taken by Shiddhirganj Sub-station Incharge, and from Haripur 230/132kV end Due to Annual Deadline Checking by Sddhirganj Grid.								
09:46	18:27	Kallyanpur 132/33kV S/S Main bus Scheduled S/D Due to Annual Maintenance. Kallyanpur-Laibaq 132kV Ckt-1 Scheduled S/D from Kallyanpur 132/33kV end Due to Annual Maintenance								
09:52		Siddhirgani 132/33kV S/S 120MW Maintained by EGCB.	EGCB GT1 Forced S/D Due	e to Maintenace work 132/33 KV Transformer oil o	centrifuge					
	09:52	Naogaon 132/33kV S/S T-3 HT is	restored.							
	09:53	Naogaon 132/33kV S/S T-3 LT is	restored.							
09:53	17:00			to Due to Bay extension work by Rooppur Project	ct.					
10:09	10:43	Rampal 400/230kV S/S Bus Read Gollamari 132/33kV S/S Tr-2 LT is		b Bus voltage low						
	10:45	Thakurgaon 132/33kV S/S T-1(42)								
	10:45	Thakurgaon 132/33kV S/S T-1(42	2T) HT is restored.							
11:36	13:06	Cumilla(S) 132/33kV S/S Cumilla								
12:01 12:03				oject Work S/D Due to Maintenance purpose oject Work S/D Due to Maintenance purpose						
12:15	15:17	Kalurghat 132/33kV S/S TRFO-02								
15:53	16:35	Mirzapur 132/33kV S/S Transform in PBS(33 kv Vadgram Outgoing F	er-01(E05) LT Tripped showin	ng Lockout Relay 86.1/2 relays Due to O/C fault s	Show			22.5MW load interruption.		
15:53	16:31	Mirzapur 132/33kV S/S Transform O/C fault Show in PBS(33 kv Vad)	er-01(E05) HT Tripped show	ng 87T Relay general Trip OC/EF Trip. relays Du	ue to					
15:53	16:34	Mirzapur 132/33kV S/S Transform	er-02(E07) LT Tripped showing	na Lockout Relay 86.1/2 relays Due to O/C fault \$	Show					
	18:19	in PBS(33 kv Vadgram Outgoing F Mirpur 132/33kV S/S T3 LT is rest		r.						
19:00	10.19	Evening peak generation:10836 N								
	22:57	Chauddagram-Feni 132 kV Ckt-2	is restored.							
	22:57	Chauddagram-Feni 132 kV Ckt-2								
	23:47	Madaripur 132/33kV S/S T2-415T Madaripur 132/33kV S/S T2-415T								
04:00	23:49	Madaripur 132/33kV S/S T2-415T Minimum generation 7431 MW	L i is restored.							
04:00		Biblyana-III 400 MW CCPP Syr	ncronized with remarks:- ST							
06:55		Thakurgaon 132/33kV S/S Auxiliar Removal Work	ry Transformer-1 LT Schedule	ed S/D Due to RPC Capacitor Bank Bus Isolator I	RedHot					
06:55			2T) LT Scheduled S/D Due to	RPC Capacitor Bank Bus Isolator RedHot Remo	oval Work					
06:55				o RPC Capacitor Bank Bus Isolator RedHot Rem						
07:24		Chauddagram-Feni 132 kV Ckt-1 grid s/s and from Feni 132/33kV e		agram 132/33kV end Due to Bay Maintenance for placement work	or feni					
N	Sub Divisional Engi etwork Operation Div	I Divisional Engineer rk Operation Division					neer n Division	Superintendent Engineer Load Despatch Circle		