

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2024						Day : Wednesday				Date : 14.02.24							
Probable Maximum Demand : 11000 MW						Probable Maximum Generation : 12246 MW											
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 85.84 ft		Today = 85.72 ft		Rule Curve = 95.18 ft							
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.02.24 (Yesterday)		14.02.24 (Today)		13.02.24 (Yesterday)		14.02.24 (Today)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :							
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
(A) Plants in operation:																	
1	Ghorasal Repowered CCPP Unit-3 (GT)		Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4		Gas (PDB)	1 x 210	210	180	160	190	190	190							
	b) Ghorasal TPP Unit-5		Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maintenance			
3	Ghorasal 365 MW CCPP Unit-7		Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI			
4	Ghorashal 108MW PP (Regent)		Gas (IPP)	34x3.35	108	108	12	12	12	12			96	Gas Shortage			
5	Tongi 80 MW GTPP		Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage			
6	Haripur GTPP		Gas (PDB)	1 x 32	32	20	0	0	0	0							
7	Haripur 360MW CCPP(HPL)		Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired			
8	Meghnaghat 450 MW CCPP(MPL)		Gas (IPP)	2x140+1x170	450	450	0	0	0	0							
9	210 MW Siddhirgonj TPP		Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling			
10	Haripur 412 MW CCPP		Gas (EGCB)	1x273+1x139	412	412	401	402	412	412							
11	Siddhirgonj 2*120 MW GTPP		Gas (EGCB)	2 x 105	210	210	99	39	100	100			171	Gas Shortage			
12	Siddhirganj 335 MW CCPP		Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335							
13	Meghnaghat 335MW CCPP(Summit)		Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage			
14	Madanganj-55 MW PP(Summit)		HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15							
15	Gagnagar 102 MW PP (Digital Power)		HFO (IPP)	12x8.924	102	102	41	91	40	91							
16	Narsingdi 22 MW PP (Doreen)		Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0							
17	Summit Power (Madhabdi+Ashulia)		Gas (SIPP, REB)	6x3.67+7x8.73	80	80	34	34	34	34							
18	Maona 33 MW PP(Summit)		Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33							
19	Rupganj 33 MW PP(Summit)		Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33							
20	Gazipur 52 MW PP		HFO (RPCL)	6x8.90	52	52	8	17	8	17							
21	Gazipur 100 MW PP		HFO (RPCL)	6x18.415	105	105	17	105	17	105							
22	Kodda 150MW PP		HFO (BRPgen)	9x17.06	149	149	32	98	16	98							
23	Kamalaghat 54 MW PP (Barco Energy)		HFO (IPP)	3x18.69	54	54	0	17	0	17							
24	Kodda 300 MW PP Unit-2 (Summit)		HFO (IPP)	18x17.076	300	300	92	127	82	130							
25	Kodda 149 MW PP Unit-1 (Summit)		HFO (IPP)	8x18.415+1x8.97	149	149	17	35	17	35							
26	Nababganj 55 MW PP (Southern power)		HFO (IPP)	3x19.3	55	55	17	0	0	17							
27	Manikganj 55 MW PP (Northern)		HFO (IPP)	3x19.3	55	55	0	17	0	17							
28	Meghnaghat 104 MW PP (OPSL)		HFO (IPP)	6x18.5	104	104	17	22	17	17							
29	Manikgonj 162MW PP(MPGL)		HFO (IPP)	9x18	162	162	17	17	17	17							
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)		Solar (IPP)	1x35	35	35	28	0	35	0							
31	Kanchan Purbachal Power Generation Ltd.		HFO (IPP)	3x19.404	55	55	0	17	0	17							
32	Siddhirganj 100 MW PP(Dutch Bangla)		HFO (NENP)	12x8.9	100	100	60	68	60	68							
33	Meghnaghat 100 MW(IECL)		HFO (NENP)	12x8.9	100	100	57	29	100	100							
34	Madanganj 102 PP(Summit)		HFO (NENP)	6x17	102	102	34	82	85	85							
35	Keraniganj 100 MW PP (Powerpac)		HFO (NENP)	8x13.45	100	75	0	0	0	25							
36	Katpotti 52 MW PP (Sinha)		HFO (IPP)	7x7.90	51	0	0	0	0	0							
	Meghnaghat Unique Power		Gas				0	0	0	0				Test run			
	Meghnaghat 589 MW CCPP(Summit)		Gas				120	120	340	340				Test run			
Dhaka Zone Total					5655	5062	1678	1952	1998	2360	707	930					
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5		Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40							
38	a) Chattogram TPP-1		Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage			
	b) Chattogram TPP-2		Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.			
39	Kaptai 7 MW Solar PP		Solar (PDB)		7	7	4	0	5	0							
40	Raozan 25 MW PP		HFO (RPCL)	3x8.9	25	25	8	17	8	17							
41	Teknaf 20MW PP (Solartech)		Solar (IPP)	1x20	20	20	20	0	20	0							
42	Patenga 50MW PP (Baraka)		HFO (IPP)	8x6.89	50	50	6	18	6	18							
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)		HFO (IPP)	6x18.415	105	105	17	17	17	17							
44	Shikalbaha Peaking GT		Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.			
45	Sikalbaha 225 MW CCPP		Gas (PDB)	1 x 150+1 x 75	225	225	212	211	210	210							
46	Anwara 300 MW PP (United)		HFO (IPP)	17x17.076+ 3x8.04	300	300	68	104	60	150							
47	Juldah 100 MW PP Unit-3 (Accom)		HFO (IPP)	8x13.45	100	100	25	25	25	25							
48	Dohazari-Kalaish 100 MW Peaking		HFO (PDB)	6x17.0	102	102	41	51	51	51							
49	Hathazari 100 MW peaking PP		HFO (PDB)	11x8.9	98	98	0	0	0	0							
50	Barabkunda 22 MW PP (Regent)		Gas (SIPP, PDB)	8x2.90	22	22	9	12	12	12							
*	Malancha, Ctg EPZ (United)		Gas	5x8.73+3x9.34			4	14	5	15							
51	Chattogram 108 MW PP (ECPV)		HFO (IPP)	16x7.00	108	108	0	0	0	0							
52	Sikalbaha 54 MW PP(Jodiac Power)		HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	0							
53	Karnaphuli Power Ltd.		HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17							
54	Juldah unit-2 (Accom)		HFO (IPP)	8x13.6	100	100	25	24	25	25							
55	Juldah 100 MW Unit-1 (Accom)		HFO (QRPP)	8x13.45	100	100	25	35	25	25							
56	Chattogram 116 MW PP (Anilma Energy Ltd.)		HFO (IPP)	6x21.06	116	116	17	17	17	17							
57	Mirsharai 150 MW		HFO (BRPgen)	9x18.5	163	163	17	145	17	145							
58	Chattogram 2*612MW Coal Based PP (SS Power)		Coal (IPP)	2x612	1224	1224	540	581	550	580							
59	Matarbari 2*600 MW (CPGCL)		Coal (CPGCL)	1x575	575	575	0	0	0	0							
	Cox's Bazar Wind PP		(Wind) (IPP)				4	18	20	20				Test run			
Chattogram Zone Total					4404	4344	1116	1346	1147	1384	180	330					
60	Ashuganj 50 MW PP		Gas (APSCL)	14x3.968	53	45	20	35	25	35							
61	Ashuganj 225 MW CCPP		Gas (APSCL)	1x142+1*75	221	221	147	152	150	150							
62	Ashuganj 450 MW CCPP(South)		Gas (APSCL)	1x360	360	360	250	270	280	280			90	Gas Shortage			
63	Ashuganj 450 MW CCPP(North)		Gas (APSCL)	1x361	360	360	310	305	300	305			55	Gas Shortage			
64	Ashuganj 420 MW CCPP(East)		Gas (APSCL)	1x284+1x116	400	400	0	0	0	0			400	Gas Shortage			
65	Ashuganj 195MW PP (APSCL-United)		Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0			195	Gas Shortage			
66	Ashuganj 51 MW PP (Midland)		Gas (IPP)	6x9.34	51	51	51	51	51	51							
67	Ashuganj 150MW PP (Midland)		HFO (IPP)	23x7.015	150	150	6	15	13	25							
68	Titas 50 MW Peaking PP		HFO (PDB)	6x8.92	52	52	32	41	40	41							
69	Chandpur 150 MW CCPP		Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.			
70	Chandpur 200MW (Desh energy)		HFO (IPP)	12x18.415	200	200	17	17	17	17							
71	Feni 22MW PP (Doreen)		Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16							
72	Feni 11 MW PP (Doreen)		Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10							
73	Jangalia 33 MW PP (Summit)		Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33							
74	Jangalia 52 MW PP (Lakdanavi)		HFO (IPP)	6x8.92	52	52	8	16	8	16							
75	Cumilla 25 MW PP (Summit)		Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	15	15	15							
76	Feni 114 MW (Lakdanavi)		HFO (IPP)	7*18.415+1*9.78	114	114	93	98	114	114							
77	Chowmuhani 113 MW		HFO (IPP)	12*9.78+2*3.1	113	113	16	68	48	68							
78	Bharob 54 MW PP		HFO (IPP)	3x18.2	54	54	0	17	17	17							
79	Chandpur 115MW PP (Doreen)		HFO (IPP)	4x18.516+2x25.428	115	115	0	37	0	36							
80	Ashugani 55 MW PP (Precision)		Gas (RPP)	15*4	55	55	0	0	0	0							
**	Import (Tripura)		India														

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.02.24 (Yesterday)		14.02.24 (Today)		13.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	42	42	42		28	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	51	51					
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	60	60					
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	209	210	210					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	16	16	16					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	8	16	16					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	310					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	301	80	300	310					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	290	350	360					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	8	5	5	5					
Sylhet Zone Total						2472	2427	1366	1056	1400	1430	0	508	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	35	0	50					
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0					
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	55	50	55					
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0					
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	69	0	100	0					
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0					
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
116	Khulna 330 MW CCPP	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	907	624	926	926					
Khulna Zone Total						3241	3237	993	759	1076	1076	410	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	7	7					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	70	66	66	66	128		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	960	1130	1200	1240					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	136	35	150					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	290	307	307					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	200	220					
Barishal Zone Total						2265	2265	1421	1865	1815	2006	128	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	25	26					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	15					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	49	82	50	82					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	40	42					
130	Katakali 50 MW PP (Northern)	HFO (QRP)	6x8.9	50	50	16	34	34	34					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	35					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	190	161	160	170	59		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	381	350	380					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8					
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	0	35	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	35	0					
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28					
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1253	1372	1300	1350					
Raishahi Zone Total						3653	3631	2030	2165	2068	2210	560	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	34	6	34					
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	72					
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0					
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	176	0	130	0					
Rangpur Zone Total						1030	950	390	276	344	276	189	85	
Sub-total: Plants in operation						26301	25481	10295.0	10836	11281	12246	3082	2116	
(B) Plants under long term maintenance/ contract expired														
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0	
Gross Total						26504	25481	10295	10836	11281	12246	3082	2116	

(C) Actual data of 13.02.24 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10930	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10486	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10836	MW, at =	19:00 hrs		Dhaka	3908	3908	0	Mymensingh	989	899	90
04.	Minimum Generation (Generation end)	:	7288	MW, at =	5:00 hrs		Chattogram	1024	1024	0	Sylhet	374	374	0
05.	Day-peak Generation (Generation end)	:	10295	MW, at =	12:00 hrs		Khulna	1192	1192	0	Barishal	286	286	0
06.	Evening-peak Generation (Generation end)	:	10836	MW, at =	19:00 hrs		Rajshahi	1091	1091	0	Rangpur	761	761	0
07.	Evening Peak Load-shed (Sub-station end)	:	90	MW, at =	19:00 hrs		Cumilla	861	861	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7431	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:									Total	10486	10396	90
	a) Gas/LF limitation	:	2893	MW			13.	Fuel cost :	(a) Gas = 316659614 Taka				(c) Coal = 503648518 Taka	
	d) Coal supply Limitation	:	189	MW				(b) Oil = 414165984 Taka				Total = 1234474115 Taka		
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2116	MW		14.	Maximum Temperature in Dhaka was : 30°C							
10.	Total Energy (Generation + India Import)	:	227.29	MKWh		15.	Export through East-West interconnections :							
	By Gas = 105.469 MKWH			By Oil = 22.654 MKWh			At evening peak-hour : 10295 MW, at 19:00 hrs							
	By Coal = 74.332 MKWH			By Hydro = 0.970 MKWh			Maximum : 960 MW, at 7:00 hrs							
	By Solar = 2.420 MKWH						Energy : 0 MKWh							
11.	Total Gas Supplied	:	836.27	MMCFD										

(D) Forecast of 14.02.24 (Today) Wednesday :														
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12246	MW	(Generation end)	05.	Total Generation	:	230.73	MKWh				
03.	Reserve / Shortage	:	1246	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C					

(D) Forecast of 14.02.24 (Today) Wednesday :												
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	12246	MW	(Generation end)	05.	Total Generation : 230.73 MKWh					
03.	Reserve / Shortage	:	1246	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.3°C					

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation