

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024					Day : Friday				Date : 16.02.24							
Probable Maximum Demand : 10300 MW					Probable Maximum Generation : 11803 MW											
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.59 ft				Today = 85.45 ft				Rule Curve = 94.90 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.02.24 (Yesterday)		16.02.24 (Today)		15.02.24 (Yesterday)		16.02.24 (Today)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW							
(A) Plants in operation:																
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	140	140	140							
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			190	Under maintenance			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Awaiting for HGPI			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0							
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0				Grid SS maint.			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	412	419	412	412							
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	99	0	0	0	210			Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335							
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15							
15	Gaggaraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	91	91	91							
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0							
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	33	39	39	39							
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33							
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	18	14	33	33							
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17							
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	17	105							
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	115	16	98							
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17							
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	130	95	82	130							
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	43	17	17	17							
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	0	0	17							
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17							
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17							
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17							
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	35	0							
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	0	17							
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	60	58	60	60							
33	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	48	60	50	60							
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80							
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	25							
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
	Meghnaghat Unique Power	Gas				0	0	0	0				Test run			
	Meghnaghat 589 MW CCPP(Summit)	Gas				390	405	400	400				Test run			
Dhaka Zone Total				5655	5062	2082	2131	1909	2204	746	930					
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190			Inadequate Reservoir Water Level			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0							
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17							
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0							
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	18							
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17							
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	212	210	210							
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	67	121	65	120							
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25							
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	67	68	51	68							
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0							
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12							
	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	23	10	30							
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	0							
52	Sikalbaha 54 MW PP(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	0							
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17							
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	24	25	25	25							
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	25	25	25							
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17							
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	145	17	145							
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	577	551	550	580							
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	0	0	0	0							
	Cox's Bazar Wind PP	(Wind) (IPP)				14	29	20	29				Test run			
Chattogram Zone Total				4404	4344	1188	1375	1157	1395	370	330					
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	47	47	45	47							
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	148	120	130	140							
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	200	290	290	160			Gas Shortage			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360			Gas Shortage			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	150	300	300	320	100			Gas Shortage			
65	Ashuganj 195MW PP (APSL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195			Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51							
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	11	13	25							
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	40	40	40							
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17							
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	16	16							
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10							
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x3.73	33	33	33	33	33	33							
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8							
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	13	13	15	15							
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	85	70	114	114							
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	55	48	68							
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17							
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	28	0	30							
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	14	20	20	20							

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.02.24 (Yesterday)		16.02.24 (Today)		15.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	50	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	28	28	30				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	209	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	16	16				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	8	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	362	364	350	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	340	350	350				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5				
Sylhet Zone Total				2472	2427	1404	1387	1419	1472	0	670		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	59	70	54	70				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Under Maint.	
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	904	619	922	633				
Khulna Zone Total				3241	3237	1044	759	1076	823	410	617		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	70	70	70	70	124		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1100	1060	1200	1240				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	150	150	150	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	250	250	307				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110				
Barishal Zone Total				2265	2265	1634	1662	1787	1900	124	0		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	25	26				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	7	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	46	92	50	92				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	48	40	50				
130	Katakhali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	25	34	34	34				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	137	142	140	150	78		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	307	325	350	350	89		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	35				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	35	0				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1312	1306	1300	1350				
Raishahi Zone Total				3653	3631	1931	2106	2013	2178	668	100		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	17	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	3	42	6	42				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tahula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	0	72				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	138	0	130	0				
Rangpur Zone Total				1030	950	364	247	344	284	189	85		
Sub-total: Plants in operation				26301	25481	10886.0	10944	11168	11803	3494	2895		
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0		
Gross Total				26504	25481	10886	10944	11168	11803	3494	2895		

(C) Actual data of 15.02.24 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	11040	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10538	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11024	MW, at =	13:00 hrs	Dhaka	4128	4108	20	Mymensingh	962	890	72
04.	Minimum Generation (Generation end)	:	7492	MW, at =	5:00 hrs	Chattogram	1092	1092	0	Sylhet	386	386	0
05.	Day-peak Generation (Generation end)	:	10886	MW, at =	12:00 hrs	Khulna	1078	1078	0	Barishal	287	287	0
06.	Evening-peak Generation (Generation end)	:	10944	MW, at =	19:00 hrs	Rajshahi	1077	1077	0	Rangpur	765	765	0
07.	Evening Peak Load-shed (Sub-station end)	:	92	MW, at =	19:00 hrs	Cumilla	762	762	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6950	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	10538	10446	92
	a) Gas/LF limitation	:	3115	MW		13.	Fuel cost :	(a) Gas = 300827478 Taka	(c) Coal = 528462952 Taka				
	d) Coal supply Limitation	:	189	MW				(b) Oil = 395765638 Taka	Total = 1225056068 Taka				
	b) Low water level in Kaptai lake	:	190	MW									
	c) Plants under shut down/ maintenance	:	2895	MW									
10.	Total Energy (Generation + India Import)	:	233.09	MKWh		14.	Maximum Temperature in Dhaka was : 29.3°C						
	By Gas = 108.828 MKWH			By Oil = 21.603 MKWh		15.	Export through East-West interconnections :						
	By Coal = 78.201 MKWH			By Hydro = 0.929 MKWh			At evening peak-hour	:	10886	MW, at	19:00 hrs		
	By Solar = 2.147 MKWH						Maximum	:	990	MW, at	8:00 hrs		
							Energy	:	0	MKWh			
11.	Total Gas Supplied	:	824.28	MMCFD									
(D) Forecast of 16.02.24 (Today) Friday :													
01.	Maximum Demand	:	10300	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	11803	MW	(Generation end)	05.	Total Generation : 217.78 MKWh						
03.	Reserve / Shortage	:	1503	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 30.3°C						

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation