

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024					Day : Tuesday				Date : 20.02.24			
Probable Maximum Demand : 11700 MW					Probable Maximum Generation : 12297 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 85.11 ft Today = 84.99 ft				Rule Curve = 94.34 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.02.24 (Yesterday)		20.02.24 (Today)		19.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	190	190	190			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maintenance
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	12	12	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0			Grid SS maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	300	300			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	100	102	0	0	108		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	280	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	58	80	82			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x6.73	80	80	39	39	39	39			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x6.73	33	33	26	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	149	64	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	0	0	0			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	132	195	95			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	36	100	17			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	25	17	60	60			
33	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	17	9	50	75			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	76	80	80	80			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	14	36			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas				250	65	230	230			Test run
	Meghnaghat 589 MW CCPP(Summit)	Gas				187	388	390	390			Test run
Dhaka Zone Total				5655	5062	1563	1867	2305	2387	656	930	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190	Inadequate Reservoir Water Level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	211	210	210			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	66	96	15	120			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	51	68			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	56	19	50			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	8	8	8			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	14	10	15			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	17	0			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	25	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	145	17	145			
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	341	315	350	355			
59	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	156	157	150	150			
	Cox's Bazar Wind PP	(Wind)				16	8	20	29			Test run
Chattogram Zone Total				4404	4344	1150	1278	1072	1352	370	330	
60	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	44	47	45				
61	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	0	0	0	0		221	Under maint.
62	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	280	290	300	320	70	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360	Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	395	393	350	360			
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	102	102	167	167	93	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	26	13	25			
68	Titash 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	40	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	16	16			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	9	10	10			
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	34	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	9	15	15			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	88	88	98	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	34	69	38	68			
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	1	17	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	37	0	42			
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	52	40	40			
**	Import (Tripura)	India		160	160	106	104	128	141			
Cumilla Zone Total				2959	2951	1272	1398	1405	1546	523	384	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	32	44	65	170	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	69	57	69			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	9	9			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total				622	614	142	116	162	149	170	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.02.24 (Yesterday)		20.02.24 (Today)		19.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	35	35	35		35	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	28	28	28				
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	209	208	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	16	15	15				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	310	315	315				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	315	410	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	380	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5				
Sylhet Zone Total						2472	2427	1532	1649	1618	1638	0	515
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	53				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	73	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	36	17	50				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	61	0	100	0				
113	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Under Maint.	
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	902	667	921	632				
Khulna Zone Total						3241	3237	980	803	1038	805	410	617
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	6	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	40	70	60	60	124		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1160	1190	1200	1244				
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	17				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	244	247	250	250				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	200	220	220	220				
Barishal Zone Total						2265	2265	1666	1782	1754	1814	124	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	24	24				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	49	90	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	40	50				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	34	34	34	34				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	0	35				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	152	146	160	180	74		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	414	410	414				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	0	36				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	35	0				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1363	1398	1300	1400				
Raishahi Zone Total						3653	3631	2053	2268	2092	2319	575	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	42	6	42				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	53	0	75				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	162	0	130	0				
Rangpur Zone Total						1030	950	375	265	344	287	189	85
Sub-total: Plants in operation						26301	25481	10733.0	11426	11790	12297	3017	2961
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	10733	11426	11790	12297	3017	2961

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0	
Gross Total				26504	25481	10733	11426	11790	12297	3017	2961	

(C) Actual data of 19.02.24 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	11600	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11075	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	11426	MW, at =	19:00 hrs	Dhaka	4209	4199	10	Mymensingh	1025	869
04.	Minimum Generation (Generation end)	:	7644	MW, at =	5:00 hrs	Chattogram	1130	1130	0	Sylhet	380	380
05.	Day-peak Generation (Generation end)	:	10733	MW, at =	12:00 hrs	Khulna	1251	1251	0	Barishal	295	295
06.	Evening-peak Generation (Generation end)	:	11426	MW, at =	19:00 hrs	Rajshahi	1135	1135	0	Rangpur	763	763
07.	Evening Peak Load-shed (Sub-station end)	:	166	MW, at =	19:00 hrs	Cumilla	887	887	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7763	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	11075	10909
a)	Gas/LF limitation	:	2638	MW		13.	Fuel cost :	(a) Gas = 312708542 Taka	(c) Coal = 531596580 Taka			
d)	Coal supply Limitation	:	189	MW				(b) Oil = 446158429 Taka	Total = 1290463550 Taka			
b)	Low water level in Kaptai lake	:	190	MW								
c)	Plants under shut down/ maintenance	:	2961	MW								
10.	Total Energy (Generation + India Import)	:	235.42	MKWh		14.	Maximum Temperature in Dhaka was :	30.2°C				
	By Gas = 107.062 MKWH			By Oil = 24.482 MKWh		15.	Export through East-West interconnections :					
	By Coal = 79.325 MKWH			By Hydro = 0.956 MKWh			At evening peak-hour	:	10733	MW, at	19:00 hrs	
	By Solar = 2.359 MKWH						Maximum	:	776	MW, at	7:00 hrs	
11.	Total Gas Supplied	:	826.86	MMCFD			Energy	:	0	MKWh		

(D) Forecast of 20.02.24 (Today) Tuesday :												
01.	Maximum Demand	:	11700	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12297	MW	(Generation end)	05.	Total Generation	:	241.07	MKWh		
03.	Reserve / Shortage	:	597	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.2°C			

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation