

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month February, 2024					Day : Friday					Date : 23.02.24				
Probable Maximum Demand : 10500 MW					Probable Maximum Generation : 11832 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 84.75 ft	Today = 84.63 ft			Rule Curve = 93.93 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.24 (Yesterday)		23.02.24 (Today)		22.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	190	150	190					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maintenance			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGI			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Grid SS maint.			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	394	425	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage			
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	58	16	42					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	17	39	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	17	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	17	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	40	98	48	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	45	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	17	17	35					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	7	54	17	53					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	0	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	0	16	16					
33	Meghnaghat 100 MW(IE)	HFO (NENP)	12x8.9	100	100	0	9	9	9					
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	0	14	34					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			240	240	250	250			Test run			
	Meghnaghat 589 MW CCPP(Summit)	Gas			100	100	100	100			Test run			
Dhaka Zone Total					5655	5062	1586	1927	1724	2195	758	1380		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190	Inadequate Water Level			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	19	6	6					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	24	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	212	212	220	220					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	49	115	65	120					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	59	68					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	64	0	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	23	20	30					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	0	25	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	144	17	145					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	295	341	350	355					
59	Metarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	160	157	150	150					
	Cox's Bazar Wind PP	(Wind) (IPP)				9	8	20	29		Test run			
Chattogram Zone Total					4404	4344	1115	1302	1116	1403	370	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	47	20	20					
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	153	153	221	Under maint.			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	360	310	310	320	50	Gas Shortage			
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Gas Shortage			
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	320	326	325	325	74	Gas Shortage			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	55	102	0	0	93	Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	9	9					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	13	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	40	40	48					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	8	9	9					
73	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	0	11	11					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	70	52	100	100					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	58	38	75					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	42					
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	52	5	5					
**	Import (Tirupura)	India		160	160	98	112	128	141					
Cumilla Zone Total					2959	2951	1179	1249	1246	1356	577	384		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	64	88	50	65	114	Gas Shortage			
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	69	57	69					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	9	9	9					
85	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	6	0	6					
Mymensingh Zone Total					622	614	190	172	168	149	114	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.24 (Yesterday)		23.02.24 (Today)		22.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	38	38	38		32	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0					
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163					
92	Hobigangj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	30	28	28					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	210	210	210	210					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	17	17					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	315	315					
101	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	355	364	400	400					
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	340	380	380					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	30	0	0			Test run		
104	Fenchugangj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	0	0	0	0					
Sylhet Zone Total						2472	2427	1457	1531	1601	1601	0	412	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
107	Ferdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	4	0	0	70					
109	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17					
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	10	0	100	0					
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0					
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0					
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPOL)	1x617	617	617	356	357	350	350					
116	Khulna 330 MW CCPP	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVCDC)	India		1000	1000	908	624	925	636					
Khulna Zone Total						3241	3237	1278	981	1392	1123	410	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	0	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	7	7					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	60	60			under maint.		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	880	700	900					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	35					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	180	140	200	200					
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	180	220	220					
Barishal Zone Total						2265	2265	1184	1240	1204	1454	0	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	25	25					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	15					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	26	91	50	90					
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	50	40	50					
130	Katakhal 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	37	16	35					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	158	192	160	175	28		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	303	414	414	111		Gas Shortage		
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5					
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	8	0	0	8					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	35					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	35	35	35					
140	Amkhura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1136	1115	1300	1300					
Rajshahi Zone Total						3653	3631	1842	1812	2156	2257	640	100	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	40	6	49					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	0	75					
149	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	30	0					
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	43	0	130	0					
Rangpur Zone Total						1030	950	236	284	344	294	189	85	
Sub-total: Plants in operation						26301	25481	10067.0	10598	10951	11832	3058	2691	
(B) Plants under long term maintenance/ contract expired														
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
152	Bosilla 108MW PP(CICI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0	
Gross Total						26504	25481	10067	10598	10951	11832	3058	2691	

(C) Actual data of 22.02.24 (Yesterday) Thursday :																
01.	Max. Demand at eve. peak (Generation end)	:	10598	MW,	at =	19:30	hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10190	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10598	MW,	at =	19:30	hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7368	MW,	at =	5:00	hrs	Dhaka	3825	3825	0	Mymensingh	839	839	0	
05.	Day-peak Generation (Generation end)	:	10067	MW,	at =	12:00	hrs	Chattogram	1128	1128	0	Sylhet	366	366	0	
06.	Evening-peak Generation (Generation end)	:	10598	MW,	at =	19:30	hrs	Khulna	1179	1179	0	Barishal	309	309	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Rajshahi	1031	1031	0	Rangpur	688	688	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7210	MW,	at =	5:00	hrs	Cumilla	825	825	0					
09.	Generation shortfall at evening peak due to :	:										Total	10190	10190	0	
	a) Gas/LF limitation	:	2679	MW				13.	Fuel cost :	(a) Gas = 308252378	Taka	(c) Coal = 479023332	Taka			
	d) Coal supply Limitation	:	189	MW			(b) Oil = 381868321			Taka	Total = 1169144031	Taka				
	b) Low water level in Kaptai lake	:	190	MW												
	c) Plants under shut down/ maintenance	:	2691	MW				14.	Maximum Temperature in Dhaka was :		29°C					
10.	Total Energy (Generation + India Import)	:	225.63	MKWh				15.	Export through East-West interconnections :							
	By Gas = 111.038 MKWh				By Oil = 20.747 MKWh				At evening peak-hour	:	10067	MW,	at	19:30	hrs	
	By Coal = 70.346 MKWh				By Hydro = 0.910 MKWh				Maximum	:	940	MW,	at	5:00	hrs	
	By Solar = 1.336 MKWh								Energy	:	0.033	MKWh				
11.	Total Gas Supplied	:	797.32	MMCFD												
(D) Forecast of 23.02.24 (Today) Friday :																
01.	Maximum Demand	:	10500	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	11832	MW	(Generation end)			05.	Total Generation	:	223.55	MKWh				
03.	Reserve / Shortage	:	1332	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	29°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation