

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month February, 2024					Day : Saturday				Date : 24.02.24			
Probable Maximum Demand :					11250 MW		Probable Maximum Generation :				12423 MW	
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 84.63 ft		Today = 84.51 ft		Rule Curve = 93.75 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.02.24 (Yesterday)		24.02.24 (Today)		23.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	200	150	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HSGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0		Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Grid SS maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	428	387	412	412			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	335	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	32	16	42			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x37+7x8.73	80	80	24	32	39	39			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	8	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	17	8	17			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	17	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	64	48	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	32	17	35			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	51	17	51			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	0	35			
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	13	0	17			
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	16	16			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	9	9			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	14	26			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			242	242	400	400			Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas			100	100	100	100			Test run	
Dhaka Zone Total					5655	5062	1460	1638	1879	2325	948	1190
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	35	35	190	Inadequate Water Level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	6	6	6	6			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	13	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	216	220	220			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	80	65	100			
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	25	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	51			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	72	0	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			28	42	10	10			
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	10	17	17			
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	25	25	25			
55	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	0	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	7	13	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	90	17	145			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	280	280	280	280			
59	Metarbari 2*600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	159	153	150	150			
	Cox's Bazar Wind PP	(Wind) (IPP)				9	1	20	29		Test run	
Chattogram Zone Total					4404	4344	804	1076	972	1266	370	330
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	44	20	20			
61	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	150	153	155	155			
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	310	310	320	50	Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360	Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	286	320	350	330	80	Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	24	0	0	171	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	2	5	6	6			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	41	40	48			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	9	9			
73	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	16	11	11			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	98	70	100	100			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	26	36	78			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	12	32	0	42			
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	17	52	5	5			
**	Import (Tripura)	India		160	160	104	104	128	141			
Cumilla Zone Total					2959	2951	1119	1328	1313	1408	661	163
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	76	50	70	126	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	68	57	69			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	19	9	9			
85	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	6	0	6			
Mymensingh Zone Total					622	614	186	169	168	154	126	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.02.24 (Yesterday)		24.02.24 (Today)		23.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	38	38	38	38			32	GT-1 Under maint.
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40			50	GT-4 Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	53	51	51				
91	Kushihara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	28	28	28				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.
95	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	210	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	17	17				
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	285	315	315				
101	Bibiyan-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	374	364	400	400				
102	Bibiyan South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	350	310	380	380				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	50	0	0				Test run
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	0	48	40	40				
Sylhet Zone Total						2472	2427	1519	1405	1500	1500	0	412
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCGP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410			Gas Shortage
107	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
109	Khulna 225 MW CCGP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	35	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	357	359	350	350				
116	Khulna 330 MW CCGP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	906	623	927	927				
Khulna Zone Total						3241	3237	1298	982	1394	1414	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	6	7	7				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	70	70	80	80				GT-1, ST under maint.
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	790	1000	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	50				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	150	200	200				
123	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2285	1015	1236	1542	1789	0	0
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Under maint.
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	52	50	90				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	50	40	50				
130	Katakhal 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	16	35				
132	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	210			Gas Shortage
133	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	0	0	0	0	220			Gas Shortage
134	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	160	179	200	200	41			Gas Shortage
135	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	356	365	414	414	49			Gas Shortage
136	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	5	5	5	5				
137	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	35				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	35				
140	Amkhura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1096	1119	1300	1300				
Rajshahi Zone Total						3653	3631	1622	1807	2196	2282	591	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104			Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	40	6	40				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatulia 8 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	42	0	75				
149	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	113	0	130	0				
Rangpur Zone Total						1030	950	323	252	344	285	189	85
Sub-total: Plants in operation						26301	25481	9346.0	9893	11308	12423	3295	2280
(B) Plants under long term maintenance/ contract expired													
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosilia 108MW PP(CICI)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	9346	9893	11308	12423	3295	2280
(C) Actual data of 23.02.24 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	9893	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9564	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9893	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7210	MW, at =	5:00 hrs	Dhaka	3324	3324	0	Mymensingh	844	844	0
05.	Day-peak Generation (Generation end)	:	9346	MW, at =	12:00 hrs	Chattogram	1090	1090	0	Sylhet	339	339	0
06.	Evening-peak Generation (Generation end)	:	9893	MW, at =	19:00 hrs	Khulna	1147	1147	0	Barishal	277	277	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	1032	1032	0	Rangpur	716	716	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7133	MW, at =	5:00 hrs	Cumilla	796	796	0				
09.	Generation shortfall at evening peak due to :	:						Total		9564	9564	0	
	a) Gas/LF limitation	:	2916	MW		13. Fuel cost :		(a) Gas =	302439091 Taka	(c) Coal =	462514061 Taka		
	d) Coal supply Limitation	:	189	MW	(b) Oil =			128769378 Taka	Total =	893722530 Taka			
	b) Low water level in Kaptai lake	:	190	MW		14. Maximum Temperature in Dhaka was :		28.0°C					
	c) Plants under shut down/ maintenance	:	2280	MW									
10.	Total Energy (Generation + India Import)	:	207.65	MKWh		15. Export through East-West interconnections :							
	By Gas =	108.694	MKWh	By Oil =	7.220								
	By Coal =	67.883	MKWh	By Hydro =	0.895								
	By Solar=	2.157	MKWh										
11.	Total Gas Supplied	:	821.43	MMCFD									
(D) Forecast of 24.02.24 (Today) Saturday :													
01.	Maximum Demand	:	11250	MW	(Generation end)	04. Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12423	MW	(Generation end)	05. Total Generation		:	236.14	MKWh			
03.	Reserve / Shortage	:	1173	MW	(Generation end)	06. Probable Max. Temperature in Dhaka :		28.0°C					