

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024					Day : Monday					Date : 26.02.24				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 12703 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 84.42 ft					Today = 84.34 ft				
					Rule Curve = 93.60 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.02.24 (Yesterday)		26.02.24 (Today)		25.02.24 (Yesterday)		26.02.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	210	150	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI		
4	Ghorshal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	Grid SS maint.		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	419	100	412	412					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	280	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	16	80					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	39	32	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	17	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	12	13	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	133	48	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	97	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	17	35					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	37	17	51					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	35	17					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	35	0	10					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	14	9	14					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	45	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	25					
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			242	622	240	300				Test run		
	Meghnaghat 589 MW CCPP(Summit)	Gas			100	60	100	300				Test run		
Dhaka Zone Total					5655	5062	1529	1985	1711	2420	948	1190		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	35	40	190		Inadequate Water Level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	4	19	6	18					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	8	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	215	220	220					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	102	65	100					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	44	0	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	32	0	68					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	23	10	30					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	5	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	12	25	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	144	17	145					
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	340	227	340	340					
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	157	156	150	150					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	7	20	29			Test run		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				42	0	0	0			Test run		
Chattogram Zone Total					4404	4344	1044	1171	1032	1360	370	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	47	44	45	45					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	115	116	140	150					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	270	320	320	90		Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage		
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	285	285	330	320	115		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+116	195	195	8	55	0	0	140		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	33	40	42					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	9	9					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	15	11	15					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	0	114	100	114					
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.3	113	113	0	47	36	60					
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	42					
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	50	25	10	25					
**	Imporpt (Tripura)	India		160	160	114	112	128	141					
Cumilla Zone Total					2959	2951	1073	1292	1318	1432	705	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	35	35	65	167		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	9	9	9					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	67	9	68					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0	</				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.02.24 (Yesterday)		26.02.24 (Today)		25.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	30	0	30				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	20	30	30				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	138	138	138	138				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	16	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	275	310	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	335	365	300	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	340	380	380				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	90	101	0	0			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1448	1471	1396	1526	0	460
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	12	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	49	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	358	0	350	360				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	907	624	926	926				
Khulna Zone Total						3241	3237	1314	711	1393	1423	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	0	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	2	7	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	110	136	140	140			GT-1, ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1000	760	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	42	35	50				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	0	200	200				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1482	1197	1802	1849	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	79	50	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	40				
130	Katakhali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	186	140	150	150	80		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	315	363	414	414	51		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	35				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1160	1305	1300	1300				
Raishahi Zone Total						3653	3631	1668	2060	2146	2245	632	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	63	6	55				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	0	75				
149	Lalmohirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	176	0	130	0				
Rangpur Zone Total						1030	950	394	303	344	300	189	85
Sub-total: Plants in operation						26301	25481	10066.0	10307	11247	12703	3421	2328
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0		
Gross Total						26504	25481	10066	10307	11247	12703	3421	2328

(C) Actual data of 25.02.24 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10307	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	9838	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	10307	MW, at =	19:00 hrs								Load Shed MW
04.	Minimum Generation (Generation end)	:	7439	MW, at =	6:00 hrs		Dhaka	3577	3577	0	Mymensingh	861	861
05.	Day-peak Generation (Generation end)	:	10066	MW, at =	12:00 hrs		Chattogram	1018	1018	0	Sylhet	352	352
06.	Evening-peak Generation (Generation end)	:	10307	MW, at =	19:00 hrs		Khulna	1174	1174	0	Barishal	289	289
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs		Rajshahi	964	964	0	Rangpur	734	734
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6491	MW, at =	5:00 hrs		Cumilla	868	868	0			
09.	Generation shortfall at evening peak due to :	:									Total	9838	9838
a)	Gas/LF limitation	:	3042	MW			13.	Fuel cost :	(a) Gas = 308648225 Taka	(c) Coal = 482061832 Taka			
d)	Coal supply Limitation	:	189	MW					(b) Oil = 176208969 Taka	Total = 966919026 Taka			
b)	Low water level in Kaptai lake	:	190	MW									
c)	Plants under shut down/ maintenance	:	2328	MW									
10.	Total Energy (Generation + India Import)	:	218.14	MKWh			14.	Maximum Temperature in Dhaka was :	26.8°C				
	By Gas = 112.452 MKWH			By Oil = 9.872 MKWh			15.	Export through East-West interconnections :					
	By Coal = 71.221 MKWH			By Hydro = 0.880 MKWh				At evening peak-hour	:	10066	MW, at	19:00 hrs	
	By Solar = 1.808 MKWH							Maximum	:	950	MW, at	22:00 hrs	
11.	Total Gas Supplied	:	837.10	MMCFD				Energy	:	0	MKWh		
(D) Forecast of 26.02.24 (Today) Monday :													
01.	Maximum Demand	:	10000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12703	MW	(Generation end)	05.	Total Generation	:	211.84	MKWh			
03.	Reserve / Shortage	:	2703	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation