

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024					Day : Tuesday				Date : 27.02.24					
Probable Maximum Demand : 11400 MW					Probable Maximum Generation : 12219 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 84.34 ft				Today = 84.26 ft					
					Rule Curve = 93.30 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.02.24 (Yesterday)		27.02.24 (Today)		26.02.24 (Yesterday)		27.02.24 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening	Day	Evening		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	210	140	140					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI		
4	Ghorshal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	450	450		450	Grid SS maint.		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	352	413	412	412					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	335	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	16	80					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	17	39	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	17	17	17	17					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	21	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	60	36					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	17	35					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	10	17	17	51					
29	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	0	0	35	17					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	15	15					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	9	14					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	15	25					
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				242	355	250	0			Test run		
	Meghnaghat 589 MW CCPP(Summit)	Gas				230	230	230	230			Test run		
Dhaka Zone Total					5655	5062	1289	1781	2325	2344	948	1190		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	18					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	186	216	220	220					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	15	65	100					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	68					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			29	32	5	15					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	0	0	25	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	17	145					
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	280	300	340	340					
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	158	156	150	150					
	Cox's Bazar Wind PP	(Wind) (IPP)				5	0	20	29			Test run		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				53	0	20	0			Test run		
Chattogram Zone Total					4404	4344	775	851	1052	1345	370	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	40	45	45					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	72	129	150	150					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	325	295	320	320	65		Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage		
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	260	300	330	330	100		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	0	8	0	0	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	40	42					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	34	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	11	15					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	0	17	100	114					
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	0	17	36	60					
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	36	0	42					
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	0	25	50	50					
**	Impoport (Tripura)	India		160	160	90	116	128	141					
Cumilla Zone Total					2959	2951	785	1132	1370	1469	712	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	96	96	98	98	106		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	19	9	9					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	73	9	68					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0					
87	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.02.24 (Yesterday)		27.02.24 (Today)		26.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	30	0	30				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	140	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	60	30	30				
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	138	135	138	138				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	310	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	362	400	300	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	360	380	380				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1370	1506	1396	1526	0	460
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x817	617	617	360	360	360	360				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	916	204	210	500				
Khulna Zone Total						3241	3237	1365	574	687	997	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	6	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	140	140	140			GT-1, ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	970	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	50				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total						2265	2265	904	1476	1742	1789	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	15				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	52	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	16	38				
132	Siragaj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Siragaj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Siragaj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	173	150	173	47		Gas Shortage	
135	Siragaj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	220	408	414	414				
136	Ulapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	35				
140	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Siragaj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	841	1109	1300	1300				
Raishahi Zone Total						3653	3631	1211	1784	2146	2268	548	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	40	6	55				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	43	0	75				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	95	0	130	0				
Rangpur Zone Total						1030	950	303	253	344	300	189	85
Sub-total: Plants in operation						26301	25481	8230.0	9551	11230	12219	3283	2328

(C) Actual data of 26.02.24 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	9551	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9248	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9551	MW, at =	19:00 hrs									
04.	Minimum Generation (Generation end)	:	6491	MW, at =	6:00 hrs		Dhaka	3097	3097	0	Mymensingh	858	858	0
05.	Day-peak Generation (Generation end)	:	8230	MW, at =	12:00 hrs		Chattogram	958	958	0	Sylhet	334	334	0
06.	Evening-peak Generation (Generation end)	:	9551	MW, at =	19:00 hrs		Khulna	1147	1147	0	Barishal	282	282	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs		Rajshahi	1032	1032	0	Rangpur	710	710	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7118	MW, at =	5:00 hrs		Cumilla	831	831	0				
09.	Generation shortfall at evening peak due to :	:									Total	9248	9248	0
	a) Gas/LF limitation	:	2904	MW		13.	Fuel cost :	(a) Gas =	285454940	Taka	(c) Coal =	444412085	Taka	
	d) Coal supply Limitation	:	189	MW				(b) Oil =	50737839	Taka	Total =	780604864	Taka	
	b) Low water level in Kaptai lake	:	190	MW										
	c) Plants under shut down/ maintenance	:	2328	MW										
10.	Total Energy (Generation + India Import)	:	194.26	MKWh		14.	Maximum Temperature in Dhaka was : 29.0°C							
	By Gas = 107.056 MKWH			By Oil =	2.784 MKWh	15.	Export through East-West interconnections :							
	By Coal = 65.106 MKWH			By Hydro =	6.006 MKWh		At evening peak-hour : 8230 MW, at 19:00 hrs							
	By Solar= 2.389 MKWH						Maximum : 950 MW, at 22:00 hrs							
							Energy : 0 MKWh							
11.	Total Gas Supplied	:	856.27	MMCFD										
(D) Forecast of 27.02.24 (Today) Tuesday :														
01.	Maximum Demand	:	11400	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	12219	MW	(Generation end)	05.	Total Generation : 232.32 MKWh							
03.	Reserve / Shortage	:	819	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 29.0°C							

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation