

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2024					Day : Thursday					Date : 29.02.24				
Probable Maximum Demand : 11600 MW					Probable Maximum Generation : 12993 MW					Rule Curve = 93.07 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 84.17 ft					Today = 83.98 ft.				
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.24 (Yesterday)		29.02.24 (Today)		28.02.24 (Yesterday)		29.02.24 (Today)		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
						Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date	
(A) Plants in operation:														
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	b) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	200	200	200					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0	190		365	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0				Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	370	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	414	406	412	412					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	329	335	335	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	50	8	50					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	39	17	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	30	25	30					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	13	12	12	12					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	90	17	90					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	64	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	80	195	95					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	97	17	100	17					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	20	51	34	51					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	0	0	0					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	6	22	8	8					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	13	8	15	15					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	24	24	24					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				300	535	500	500				Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas											Test run	
Dhaka Zone Total				5655	5062	2223	2560	2576	2641	948	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190			Inadequate Water Level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	220	220	220					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	68	103	65	100					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	50					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	33	71	50	70					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
52	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	10	5	30					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
57	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	25	25	25					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	126	17	145					
60	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	452	461	450	460					
61	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	155	156	150	156					
62	Cox's Bazar Wind PP	(Wind) (IPP)				12	9	20	29				Test run	
63	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				53	0	20	0				Test run	
Chattogram Zone Total				4404	4344	1275	1420	1229	1490	370	330			
64	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	44	45	45					
65	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	135	147	150	150					
66	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	290	270	280	300	90			Gas Shortage	
67	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360			Gas Shortage	
68	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	270	280	330	330	120			Gas Shortage	
69	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	0	0	0	0	195			Gas Shortage	
70	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
71	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	6	6	6					
72	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	39	40	40					
73	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
74	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34					
75	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
76	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
77	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
78	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	8	8	8					
79	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	11	17					
80	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	88	114	114	114					
81	Chowmuhani 113 MW	HFO (IPP)	1219.78+213.1	113	113	83	50	50	113					
82	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
83	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	8	22	18	36					
84	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	30	30	16	30					
85	Import (Tripura)	India		160	160	120	122	128	141					
Cumilla Zone Total				2959	2951	1296	1295	1342	1476	765	163			
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	38	50	60	164			Gas Shortage	
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	19	115	9					
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	67	9	9					
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
91	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0					
92	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	0	6	0	6					
Mymensingh Zone Total				622										

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.24 (Yesterday)		29.02.24 (Today)		28.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	30	30	30	30				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	130	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	66	66				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0			Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	206	200	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	40	270	310	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	392	366	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	340	340	350				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total						2472	2427	1262	1463	1566	1586	0	460
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	359	357	360	360				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	624	625	921	810				
Khulna Zone Total						3241	3237	1067	999	1398	1307	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	7	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	135	140	140	140			GT-1, ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	660	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1240	1199	1740	1793	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	0	21				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	90	50	90				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	40	50				
130	Katakhali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	25	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	153	153	150	160	67		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	250	414	414	164		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	0	35	0				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1217	1412	1300	1400				
Raishahi Zone Total						3653	3631	1907	2089	2146	2336	732	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	6	40	35				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	30	75				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	190	0	130	0				
Rangpur Zone Total						1030	950	435	248	408	280	189	85
Sub-total: Plants in operation						26301	25481	10864.0	11403	12631	12993	3578	1878
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						203	0	0	0	0	0	0	0
Gross Total						26504	25481	10864	11403	12631	12993	3578	1878

(C) Actual data of 28.02.24 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11424	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10952	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11403	MW, at =	19:00 hrs	Dhaka	4115	4115	0	Mymensingh	967	947	20
04.	Minimum Generation (Generation end)	:	7604	MW, at =	5:00 hrs	Chattogram	1228	1228	0	Sylhet	367	367	0
05.	Day-peak Generation (Generation end)	:	10864	MW, at =	12:00 hrs	Khulna	1255	1255	0	Barishal	295	295	0
06.	Evening-peak Generation (Generation end)	:	11403	MW, at =	19:00 hrs	Rajshahi	1143	1143	0	Rangpur	767	767	0
07.	Evening Peak Load-shed (Sub-station end)	:	20	MW, at =	19:00 hrs	Cumilla	815	815	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7937	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:								Total	10952	10932	20
	a) Gas/LF limitation	:	3199	MW		13.	Fuel cost :	(a) Gas = 342866310 Taka	(c) Coal = 519761303 Taka				
	d) Coal supply Limitation	:	189	MW				(b) Oil = 315003025 Taka	Total = 1177630639 Taka				
	b) Low water level in Kaptai lake	:	190	MW									
	c) Plants under shut down/ maintenance	:	1878	MW		14.	Maximum Temperature in Dhaka was :	30.1°C					
10.	Total Energy (Generation + India Import)	:	236.14	MKWh		15.	Export through East-West interconnections :						
	By Gas = 121.149 MKWH			By Oil = 17.422 MKWh			At evening peak-hour	:	10864	MW, at	19:00 hrs		
	By Coal = 76.409 MKWH			By Hydro = 0.907 MKWh			Maximum	:	632	MW, at	7:00 hrs		
	By Solar = 2.929 MKWH						Energy	:	0	MKWh			
11.	Total Gas Supplied	:	903.44	MMCFD									
(D) Forecast of 29.02.24 (Today) Thursday :													
01.	Maximum Demand	:	11600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12993	MW	(Generation end)	05.	Total Generation	:	240.22	MKWh			
03.	Reserve / Shortage	:	1393	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation