

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Friday					Date : 01.03.24				
Probable Maximum Demand : 11000 MW					Probable Maximum Generation : 12615 MW					Rule Curve = 93.07 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.98 ft					Today = 83.82 ft				
Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.02.24 (Yesterday)		01.03.24 (Today)		29.02.24 (Yesterday)		01.03.24 (Today)		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
						Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:														
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	130	130	130					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGP1		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	340	400	400					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	333	400	412	412					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	0	0	0					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	50					
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	38	37	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	25	25	30					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	12	12	12	12					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	90					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	133	64	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	95	195	95					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	79	17	17	17					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	0	0	17					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	34	51					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	0	0					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	8					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	9	15	15					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	72	80	80					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	20	25	24	24					
36	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				540	540	500	500			Test run		
	Meghnaghat 589 MW CCPP(Summit)	Gas				540	540	500	500			Test run		
Dhaka Zone Total					5655	5062	2017	2118	2038	2186	948	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level		
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	217	220	220					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	49	102	65	100					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	17	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	41	72	50	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	12	10	35					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	0	0	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	25	25	25					
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	25	25	25	25					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	126	17	145					
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	449	476	450	460					
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	157	156	155	156					
	Cox's Bazar Wind PP	(Wind) (IPP)				5	8	20	29			Test run		
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				58	0	20	0			Test run		
Chattogram Zone Total					4404	4344	1306	1433	1239	1495	370	330		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	42	20	45	45					
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	122	146	150	150					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	270	270	300	90		Gas Shortage		
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	30	30	360		Gas Shortage		
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	350	180	0	250	220		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+1116	195	195	8	8	50	50	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	5	6	6					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	31	40	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	11	11					
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	11	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	11	17					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	114	114	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	13	98	50	113					
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	37	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	35	18	36					
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	40	20	16	30					
**	Import (Tripura)	India		160	160	126	122	128	141					
Cumilla Zone Total					2959	2951	1326	1241	1082	1476	857	163		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	34	50	60	168		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	69	59	115					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	9	9					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0					
87	Tangail 22 MW PP(PGCL)	HFO												

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.02.24 (Yesterday)		01.03.24 (Today)		29.02.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	30	30	30	40	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	29	30	30	61	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	30	0	30	30			
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	0	66	66			
94	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	0	0	0	0		Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	207	203	200	210			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	295	310	310			
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	413	400	400			
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	340	350			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	100	50	100		Test run	
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0			
Sylhet Zone Total					2472	2427	1597	1660	1646	1716	0	431
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17			
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0			
112	Mongla Orion 105 MW Solar PP	Solar (IPP)		100	100	90	0	100	0			
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0			
114	Nacopara 40 MW PP (Khangshan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	358	358	360	360			
116	Khulna 330 MW CCPP	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	915	719	935	646			
Khulna Zone Total					3241	3237	1363	1077	1412	1143	410	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	32			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	5	6	7	7			
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	140	140	140		GT-1, ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	740	1200	1200			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1037	1246	1740	1793	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	25	25			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	21			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	89	50	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	26	40	50			
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	8	25	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	38			
132	Siragajonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Siragajonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Siragajonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	160	193	150	160	27	Gas Shortage	
135	Siragajonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	349	414	414	414			
136	Ulipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5			
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	0	35	55			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	0			
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
141	Siragajonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1011	1385	1300	1400			
Raishahi Zone Total					3653	3631	1679	2241	2146	2336	528	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	6	40	35			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	75	30	75			
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	35	0	0	30	0			
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	186	0	130	0			
Rangpur Zone Total					1030	950	507	251	408	280	189	85
Sub-total: Plants in operation					26301	25481	11039.0	11385	11881	12615	3470	1849

(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					203	0	0	0	0	0	0	0
Gross Total					26504	25481	11039	11385	11881	12615	3470	1849

(C) Actual data of 29.02.24 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	11437	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	11139	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	11385	MW, at =	19:00 hrs	Dhaka	4284	4284	0	Mymensingh	950	900
04.	Minimum Generation (Generation end)	:	7937	MW, at =	5:00 hrs	Chattogram	1151	1151	0	Sylhet	375	375
05.	Day-peak Generation (Generation end)	:	11039	MW, at =	12:00 hrs	Khulna	1255	1255	0	Barishal	287	287
06.	Evening-peak Generation (Generation end)	:	11385	MW, at =	19:00 hrs	Rajshahi	1147	1147	0	Rangpur	760	760
07.	Evening Peak Load-shed (Sub-station end)	:	50	MW, at =	19:00 hrs	Cumilla	930	930	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7900	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	11139	11089
a)	Gas/LF limitation	:	3091	MW		13.	Fuel cost :	(a) Gas = 324395333 Taka	(c) Coal = 510546796 Taka			
d)	Coal supply Limitation	:	189	MW				(b) Oil = 341957329 Taka	Total = 1176899458 Taka			
b)	Low water level in Kaptai lake	:	190	MW								
c)	Plants under shut down/ maintenance	:	1849	MW								
10.	Total Energy (Generation + India Import)	:	240.82	MKWh		14.	Maximum Temperature in Dhaka was :	30.5°C				
	By Gas = 120.539 MKWH			By Oil = 18.826 MKWh		15.	Export through East-West interconnections :					
	By Coal = 74.893 MKWH			By Hydro = 0.915 MKWh			At evening peak-hour	:	11039	MW, at	19:00 hrs	
	By Solar = 3.311 MKWH						Maximum	:	632	MW, at	7:00 hrs	
							Energy	:	0	MKWh		
11.	Total Gas Supplied	:	894.22	MMCFD								

(D) Forecast of 01.03.24 (Today) Friday :												
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	12615	MW	(Generation end)	05.	Total Generation	:	232.68	MKWh		
03.	Reserve / Shortage	:	1615	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.5°C			

* Cative Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation