

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2024					Day : Saturday				Date : 02.03.24				
Probable Maximum Demand : 11300 MW					Probable Maximum Generation : 12826 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 83.82 ft				Today = 83.70 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.03.24 (Yesterday)		02.03.24 (Today)		01.03.24 (Yesterday)		02.03.24 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Day	Evening	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	220	210	210				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x254+1x126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	370	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	421	412	412				
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	25				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	41	16	42				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	24	27	39	39				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x6.73	33	33	14	15	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	17				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	17	17	100				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	48	133				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	35	0	50				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
29	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	17	35	0	0				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17				
32	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	3	0	0	8				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	1	0	17	25				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	52	17	64	80				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	0	24	24				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas				0	0	0	0			Test run	
	Meghnaghat 589 MW CCPP(Summit)	Gas				560	565	550	550			Test run	
Dhaka Zone Total					5655	5062	1797	1963	2052	2430	1283	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190		Inadequate Water Level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	217	220	220				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	145	50	120				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	34	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	64	40	64				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			28	38	15	25				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	3	0	0	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	15	15	15	15				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Acom)	HFO (NENP)	8x13.45	100	100	12	0	25	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	126	17	145				
58	Chattogram 21612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	422	375	450	460				
59	Matarbari 21600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	154	155	155	300				
	Cox's Bazar Wind PP	(Wind) (IPP)				44	42	40	40			Test run	
	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)				68	0	20	0			Test run	
Chattogram Zone Total					4404	4344	1303	1368	1254	1636	370	330	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	20	45	45				
61	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1175	221	221	150	111	150	150				
62	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	270	300	300	90		Gas Shortage	
63	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	90	5	0	0	355		Gas Shortage	
64	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	9	70	280	280	330		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	2019.73+116	195	195	45	8	0	0	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	24	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	6	6				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	48	40	40				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	33	34	34				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9				
73	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	11	17				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	718.415+119.78	114	114	98	52	114	114				
77	Chowmuhani 113 MW	HFO (IPP)	1219.78+21.31	113	113	22	34	36	78				
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	26	18	36				
80	Ashuganj 55 MW PP (Precision)	Gas (RPP)	1514	55	55	5	5	10	30				
**	Import (Tirupura)	India		160	160	0	0	128	141				
Cumilla Zone Total					2959	2951	865	780	1290	1389	962	163	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	70	35	70	132		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	109	115	50				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	9	9				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0				
87	Tangail 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	0	4	0	6				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.03.24 (Yesterday)		02.03.24 (Today)		01.03.24 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	27	27	30	30		43	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	0	0	0	0			Contact Expired	
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	206	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	17	17				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	310	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	360	344	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	345	340	350				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	100	100	100	100			Test run	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0				
Sylhet Zone Total				2472	2427	1507	1537	1610	1620	0	433		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
109	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	355	355	360	360				
116	Khulna 330 MW CCPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	919	625	934	645				
Khulna Zone Total				3241	3237	1362	980	1411	1142	410	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	4	7	7	7				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	74	135	140	140			GT-1, ST under maint.	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	530	730	1200	1200				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	54				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	145	140	140				
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
Barishal Zone Total				2265	2265	928	1237	1740	1793	0	0		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	25	25				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	21				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	50	90				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	40	50				
130	Katakali 50 MW PP (Northern)	HFO (NENP)	6x8.9	50	50	0	0	42	42				
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	38				
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	130	150	160	90		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	305	350	414	414	64		Gas Shortage	
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	5				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	0	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	30	0	35				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1021	1100	1400	1400				
Raishahi Zone Total				3653	3631	1469	1788	2176	2371	655	100		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	61	0	65				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	55	75	35	75				
149	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0				
150	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0				
Rangpur Zone Total				1030	950	447	306	373	310	189	85		
Sub-total: Plants in operation				26301	25481	9834.0	10151	12117	12826	4001	1851		
(B) Plants under long term maintenance/ contract expired													
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired				203	0	0	0	0	0	0	0		
Gross Total				26504	25481	9834	10151	12117	12826	4001	1851		

(C) Actual data of 01.03.24 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	10170	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9903	MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10151	MW, at =	19:00 hrs		Dhaka	3426	3426	0	Mymensingh	944	926	18
04.	Minimum Generation (Generation end)	:	7900	MW, at =	5:00 hrs		Chattogram	1008	1008	0	Sylhet	360	360	0
05.	Day-peak Generation (Generation end)	:	9834	MW, at =	12:00 hrs		Khulna	1185	1185	0	Barishal	282	282	0
06.	Evening-peak Generation (Generation end)	:	10151	MW, at =	19:00 hrs		Rajshahi	1093	1093	0	Rangpur	748	748	0
07.	Evening Peak Load-shed (Sub-station end)	:	18	MW, at =	19:00 hrs		Cumilla	857	857	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7303	MW, at =	5:00 hrs						Total	9903	9885	18
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 304318167 Taka	(c) Coal = 476117888 Taka				
a)	Gas/LF limitation	:	3622	MW					(b) Oil = 176670346 Taka	Total = 957106402 Taka				
d)	Coal supply Limitation	:	189	MW		14.	Maximum Temperature in Dhaka was : 31°C							
b)	Low water level in Kaptai lake	:	190	MW		15.	Export through East-West interconnections :							
c)	Plants under shut down/ maintenance	:	1851	MW			At evening peak-hour : 9834 MW, at 19:00 hrs							
10.	Total Energy (Generation + India Import)	:	219.97	MKWh			Maximum : 632 MW, at 7:00 hrs							
	By Gas = 115.186 MKWh			By Oil = 9.931 MKWh			Energy : 0 MKWh							
	By Coal = 69.820 MKWh			By Hydro = 0.905 MKWh										
	By Solar = 3.251 MKWh													
11.	Total Gas Supplied	:	854.81	MMCFD										
(D) Forecast of 02.03.24 (Today) Saturday :														
01.	Maximum Demand	:	11300	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12826	MW	(Generation end)	05.	Total Generation	:	244.87	MKWh				
03.	Reserve / Shortage	:	1526	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 31°C							

* Cative Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation